

WEST VIRGINIA
SECRETARY OF STATE
KEN HECHLER
ADMINISTRATIVE LAW DIVISION

Form #1

Do Not Mark In this Box

FILED

JUN 16 9 56 AM '99

OFFICE OF THE SECRETARY OF STATE
WEST VIRGINIA

NOTICE OF PUBLIC HEARING ON A PROPOSED RULE

AGENCY: WV Division of Environmental Protection TITLE NUMBER: 33

RULE TYPE: Legislative; CITE AUTHORITY 22-15-5(a)

AMENDMENT TO AN EXISTING RULE: YES NO

IF YES, SERIES NUMBER OF RULE BEING AMENDED: 2

TITLE OF RULE BEING AMENDED: "Sewage Sludge Management Rule"

IF NO, SERIES NUMBER OF NEW RULE BEING PROPOSED: _____

TITLE OF RULE BEING PROPOSED: _____

DATE OF PUBLIC HEARING: July 22, 1999 TIME: 6:00 p.m.

LOCATION OF PUBLIC HEARING: Office of Waste Management - Conference Room
1356 Hansford Street
Charleston, WV 25301

COMMENTS LIMITED TO: ORAL , WRITTEN , BOTH

COMMENTS MAY ALSO BE MAILED TO THE FOLLOWING ADDRESS: WV DEP-Public Information Office


1356 Hansford Street

Charleston, WV 25301-1401

The Department requests that persons wishing to make comments at the hearing make an effort to submit written comments in order to facilitate the review of these comments.

The issues to be heard shall be limited to the proposed rule.

ATTACH A BRIEF SUMMARY OF YOUR PROPOSAL


Authorized Signature

\$12.60



Environmental Enforcement
1356 Hansford Street
Charleston, West Virginia 25301
Phone: 304-558-2497
Fax: 304-558-3948

West Virginia Division of Environmental Protection

Cecil H. Underwood
Governor

Michael P. Miano
Director

June 23, 1999

Judy Cooper
Administrative Law Division
Secretary of State
Building 1, Suite 157K
1900 Kanawha Blvd. East
Charleston, WV 25305-0770

OFFICE OF THE SECRETARY OF STATE
JUN 23 12 37 PM '99
FILED

RE: 33CSR2

Dear Ms. Cooper:

I had just noticed a typographical error in one of the proposed changes to the Sewage Sludge Management rule (Title 33, Series 2) filed with your office for public comment. Subdivision 3.2.b. of the rule should reference Subdivision 3.2.a **NOT** 3.1.b.

This error will be corrected in the filing of the "Agency Approved Rule" following the public comment period. However, I would like for anyone requesting a copy of the rule during the public comment period be given notification of the typographical error to avoid confusion.

Thanks you for your assistance in this matter. Please contact me at (304) 558-2497, if you have any questions.

Sincerely,

James P. Summers
Environmental Inspector

"To use all available resources to protect and restore West Virginia's environment in concert with the needs of present and future generations."



West Virginia
Division of
Environmental Protection



Executive Office
10 McJunkin Road
Nitro, West Virginia 25143-2506
Telephone: 304-759-0515
Fax: 304-759-0526

West Virginia Bureau of Environment

Cecil H. Underwood
Governor

Michael P. Miano
Commissioner

June 14, 1999

Ms. Judy Cooper
Director, Administrative Law Division
Office of the Secretary of State
Capitol Complex
Charleston, West Virginia 25305


RE: 33CSR2 - "SEWAGE SLUDGE MANAGEMENT RULE"

Dear Ms. Cooper:

This is to advise that I am giving approval to file the above-referenced rule with your Office as "Notice of Public Hearing/Comment Period."

If you should have questions or require additional information, please contact Carrie Chambers in my office at 759-0515. Your cooperation in this regard is very much appreciated.

Sincerely yours,


Michael P. Miano
Commissioner

MPM:cc

Attachment

cc: Cap Smith
James Summers
Carrie Chambers



DIVISION OF ENVIRONMENTAL PROTECTION

1356 Hansford Street
Charleston, WV 25301-1401

CECIL H. UNDERWOOD
GOVERNOR

MICHAEL P. MIANO
DIRECTOR

June 11, 1999

**BUREAU OF ENVIRONMENT
DIVISION OF ENVIRONMENTAL PROTECTION**

BRIEFING DOCUMENT

Rule Title: Sewage Sludge Management Rule

A. AUTHORITY: WV Code §§22-15-5(a)

B. SUMMARY OF RULE:

In response to a 1996 legislative mandate, the proposed Legislative Rule change proposes revisions to the soil limits for sewage sludge land application sites and updates other related areas of the rule in order to provide better management of sewage sludge within the state. These include specifying the analytical method used for soil analysis; placing strict conditions on any variances from the soil limits for land application sites; adjusting the sewage sludge limits for four metals; and providing an incentive for municipalities to produce higher quality "Class A" compost products.

C. STATEMENT OF CIRCUMSTANCES WHICH REQUIRE RULE:

The proposed Legislative Rule change is necessary to comply with the 1996 West Virginia Legislative mandate in Title 33, Series 2, Section 3.2.b requiring the West Virginia Division of Environmental Protection to propose revisions to the soil limits for sewage sludge land application sites by June 30, 1999.

D. FEDERAL COUNTERPART REGULATIONS - INCORPORATION
BY REFERENCE/DETERMINATION OF STRINGENCY:

The general federal counterpart regulation (40 CFR, Part 503) has been previously incorporated by reference into this rule. There are no federal counterpart regulations to the rule amendments being proposed, except for the metals' concentration limits in the sewage sludge; proposed limits for three of the metals are the same as the federal limits, while the proposed limit for arsenic is more stringent than the federal limit. A more stringent limit is proposed for arsenic because West Virginia's soil background levels of arsenic are higher than the national average values

used in determining the federal sewage sludge limit, and because the quantity of arsenic that could be ingested without a negative health impact was over-estimated in the risk assessment calculation used to determine the federal arsenic limit.

E. CONSTITUTIONAL TAKINGS DETERMINATION:

In accordance with §22-1a-1 and 3(c), the Director has determined that this rule will not result in taking of private property within the meaning of the constitutions of West Virginia and the United States of America.

**F. CONSULTATION WITH THE ENVIRONMENTAL PROTECTION
ADVISORY COUNCIL:**

After review of 33CSR2 at their June 10, 1999 meeting, the DEP Advisory Council recommended to the Director that this rule be filed as amended. No further amendments were recommended.

MINUTES

ENVIRONMENTAL PROTECTION ADVISORY COUNCIL

June 10, 1999, Director's Conference Room, Nitro

The sixteenth meeting of the DEP Advisory Council was held Thursday, June 10, 1999, in the Director's Conference Room located in Nitro. Chairman Mike Miano called the meeting to order at 10:00 a.m.

ATTENDING:

Advisory Council Members:

Mike Miano, Chairman
Jacqueline Hallinan
William Raney
Rick Roberts
William Samples

Environmental Protection:

Bill Adams	Pam Nixon
Andy Gallagher	Rocky Parsons
Tony Grbac	Cap Smith
Randy Huffman	Charlie Sturey
Mike Johnson	Barbara Taylor
Mike Lewis	Karen Watson
Robert Keatley	Mike Zeto

1) Review and Approval of March 22, 1999 Minutes. Chairman Miano called the meeting to order at 10:00 a.m. The first item on the agenda was approval of the minutes of the March 22 Advisory Council; they were approved as written.

2) Discussion of Proposed Rule Amendments - 2000 Legislative Session. In accordance with WV Code §22-1-1(c), and DEP's new rule-making procedure that was implemented by Director Miano in September 1998 to involve the Advisory Council in DEP's rule-making process as early as possible to enable the Council to review, comment, and make recommendations to the Director on DEP's proposed legislative rule changes before they are filed for public hearing, the following proposed rules were brought to the Council's attention.

Chairman Miano said he would like to begin by saying he hoped all Council members had received their draft rules by E-mail without any complications and they were able to review them before the meeting. He informed the Council that due to the large number of rules being proposed for the 2000 Legislative Session, DEP's program offices would review them with the

Council as thoroughly as possible, in the allotted time frame, and try to answer any questions or concerns the Council may have.

The following Office of Air Quality's proposed rule amendments were discussed by Karen Watson, OAQ, with assistance from Richard Keatley, also from the OAQ office:

- **45CSR1 - "TO PREVENT AND CONTROL AIR POLLUTION FROM COAL REFUSE DISPOSAL AREAS"**
- **45CSR2 - "TO PREVENT AND CONTROL PARTICULATE AIR POLLUTION FROM COMBUSTION OF FUEL IN INDIRECT HEAT EXCHANGERS"**
- **45CSR3 - "TO PREVENT AND CONTROL AIR POLLUTION FROM THE OPERATION OF HOT MIX ASPHALT PLANTS"**
- **45CSR4 - "TO PREVENT AND CONTROL THE DISCHARGE OF AIR POLLUTANTS INTO THE OPEN AIR WHICH CAUSES OR CONTRIBUTES TO AN OBJECTIONABLE ODOR OR ODORS"**
- **45CSR5 - "TO PREVENT AND CONTROL AIR POLLUTION FROM THE OPERATION OF COAL PREPARATION PLANTS, COAL HANDLING OPERATIONS AND COAL REFUSE DISPOSAL AREAS"**
- **45CSR6 - "TO PREVENT AND CONTROL AIR POLLUTION FROM COMBUSTION OF REFUSE"**
- **45CSR7 - "TO PREVENT AND CONTROL PARTICULATE MATTER AIR POLLUTION FROM MANUFACTURING PROCESSES AND ASSOCIATED OPERATIONS"**
- **45CSR10 - "TO PREVENT AND CONTROL AIR POLLUTION FROM THE EMISSION OF SULFUR OXIDES"**
- **45CSR12 - "AMBIENT AIR QUALITY STANDARD FOR NITROGEN DIOXIDE"**
- **45CSR16 - "STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES PURSUANT TO 40 CFR PART 60"**
- **45CSR17 - "TO PREVENT AND CONTROL PARTICULATE MATTER AIR POLLUTION FROM MATERIALS HANDLING, PREPARATION, STORAGE AND OTHER SOURCES OF FUGITIVE PARTICULATE MATTER"**
- **45CSR18 - "TO PREVENT AND CONTROL PARTICULATE AIR POLLUTION FROM DIRECT MEAT-FIRING DEVICES"**
- **45CSR23 - "TO PREVENT AND CONTROL EMISSIONS FROM MUNICIPAL SOLID WASTE LANDFILLS"**
- **45CSR25 - "TO PREVENT AND CONTROL AIR POLLUTION FROM HAZARDOUS WASTE TREATMENT, STORAGE, OR DISPOSAL FACILITIES"**
- **45CSR33 - "ACID RAIN PROVISIONS AND PERMITS"**
- **45CSR34 - "EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS PURSUANT TO 40 CFR PART 63"**

Karen began by bringing the Council up to date on the status of two OAQ rules that were filed during the last session (or late in the session). 45CSR8 revised the ambient air quality for sulfur oxides and particulate matter, and 45CSR9 pertained to ambient air quality standards for carbon monoxide and ozone. The DC Circuit Court of Appeals has ordered EPA to show how they arrived at the new standards - EPA may go back to the previous standards. Karen also apprised the Council on the N_{ox} State Implementation Plan. The Circuit Court stayed the implementation of that rule and there are no plans to develop any other amendments in the

immediate future. 45CSR28, which is the emissions trading rule that was filed late in the 1999 Session, was not taken up by the Legislature, but plans are to put the rule on the July agenda of the Interim Legislative Committee.

Karen explained the reason for the unusually large number of DEP rules that are being filed for the next Legislative Session. She informed the Council that several of the rules were outdated and were amended for consistency and streamlining, and are a result of months of on-going meetings with stakeholders -- involving both the regulated community and citizens. A particulate matter and sulfur oxide work group was also involved. Those rule amendments as a result of the stakeholders process include: 45CSR1 (which is being repealed and replaced with language in 45CSR5), 45CSR2, 3, 4, 5, 6, 7, 10, 12, 17, and 18 (which is being repealed since the rule is no longer deemed necessary). The amendments to the remainder of the rules, 45CSR16, 23, 25, 33, and 34 were necessary to adopt by reference definitions, clarifications, technical amendments, etc., recently adopted by US EPA.

After several minutes of discussion, the Advisory Council recommended to the Director that the following amendments be made to the OAQ rules:

Mr. Samples pointed out that 45CSR2 and 45CSR7 contain different definitions for the term "opacity." The agency responded that this discrepancy was inadvertent and the language should be as it is in 45CSR2. The agency agreed to revise 45CSR7, subsection 2.23, accordingly.

Mr. Larry Harris was unable to attend the meeting; however, he expressed the following comments on 45CSR10 and 45CSR33 by e-mail. He stated that the State's rules should be more stringent than the federal counterpart regulations, since the State's streams are being adversely impacted. The agency responded that, at this point in time, it does not possess sufficient evidence to make the written finding that is required by WV Code §22-2-3a before promulgating a rule which is more stringent than a counterpart federal regulation.

Cap Smith and Mike Zeto discussed the following Office of Waste Management proposed rule amendments:

- 33CSR2 - "Sewage Sludge Management Rule"
- 33CSR20 - "Hazardous Waste Management Rule"

Mike Zeto briefed the Council on the proposed amendments to 33CSR2. He stated that in 1996 the Legislature mandated DEP to perform a study on soil limitations for sewage sludge land application sites. These amendments (as a result of the study) were to be proposed by June 30, 1999. Other amendments to the rule include specifying the analytical method used for soil analysis, placing conditions on variances from the soil limits for land application sites, providing an incentive for municipalities to produce higher quality compost products, and adjusting the sewage sludge limits for four metals. Mr. Zeto told the Council these amendments are being proposed to update other related areas of the rule in an attempt to provide better management of sewage sludge within the state.

Cap Smith discussed 33CSR20 with the Council. He informed the Council that amendments are proposed in section 2 of the rule that will allow the Office of Waste Management to delist hazardous wastes, which has previously been handled by EPA. The other significant amendments that are being proposed by adoption of the Federal Register pertain to revision standards for owners and operators of closed and closing hazardous waste management facilities, post closure permit requirements, and the closure process. These amendments are referenced throughout the rule and will hopefully expedite site cleanup while maintaining environmental protection.

There were several minutes of discussion on OWM's proposed rule amendments; however, no recommendations were made to the Director concerning the amendments.

Mike Lewis, Office of Oil and Gas, discussed the following new proposed rule:

- **35CSR7 - "Well Operations - Within and Around Gas Storage Reservoirs"**

Mike informed the Council that 35CSR7 is a proposed "new" rule for the O&G Office. The rule is needed to provide protection of the environment, the public, and the state's natural gas resources. It is the intent of the proposed rule to accomplish this by addressing certain operating procedures that oil and gas and gas storage operators are to use when drilling into or through a gas storage reservoir or the gas storage reservoir protective area. In order to assure absence of leaking gas, the proposed rule requires gas storage operators to conduct monitoring and inspections of gas storage wells.

There were no questions or discussion by the Council on this proposed rule.

The following proposed rules were discussed by the Office of Mining and Reclamation:

- **38CSR2 - "Surface Mining and Reclamation Rule"**
- **38CSR2A - "Rules for Mining and Restoration for Sandstone, Limestone, and Sand"**
- **38CSR2B - "RULES FOR MINING AND RECLAMATION OF MINERALS OTHER THAN COAL"**

Ed Griffith, Office of Surface Mining, discussed the proposed amendments to the Surface Mining and Reclamation Rule. Ed told the Council that there are only minor amendments being proposed to this year's rule. The proposed definition of "woodlands" in subsection 2.136 relates to the utilization of commercial woodlands in Approximate Original Contour variance areas. This change is being proposed in order for the state to meet the federal policy that is expected to change in July 1999. The proposed amendment to change the bonding requirements of mining operations that request variances from contemporaneous reclamation to the maximum amount per acre bond (\$5,000 per acre) is found in subdivision 14.15.f. All other amendments are being proposed in order to meet the requirements of the Office of Surface Mining's program amendments.

Rocky Parsons, OMR's Philippi Office, next addressed OMR's proposed rules 38CSR2A and 2B. Rocky explained to the Council members that 38CSR2B has been in place since 1983 and regulates all minerals other than coal. However, in accordance with the requirement that separate rules for limestone, sandstone, and sand are to be promulgated, DEP is proposing

38CSR2A which will regulate only those minerals - 38CSR2B will regulate all minerals other than limestone, sandstone, sand, and coal. Both proposed rules will regulate roads, blasting, drainage control, methods of operation, excess spoil disposal, revegetation, mapping, transfer of permits, permit renewals, revisions and incidental boundary revisions. 38CSR2A will provide provisions for restoration and 38CSR2B will include provisions for reclamation. Rocky gave the Council a brief history on the roadblocks the agency has encountered in the past several years in their attempt to amend the quarry statute. He said since the agency has been unsuccessful in that approach, it has become necessary to try to accomplish this through rule making. He informed the Council of a public meeting held the previous week to discuss the two proposed rules. He said the meeting was well attended and he believes the rules were well received by everyone in attendance.

The three OMR proposed rules were discussed by the Council members. Bill Raney said that although Rocky stated that the quarry rules have been well received by industry and the citizens, he is concerned about whether there has been enough time for the review of the proposed rules after they were drafted. He believes there would be a smoother transition into the rule making process, i.e., the public hearing/comment period, etc., if there had been more involvement from outside DEP during the drafting of the rules.

Mr. Larry Harris commented by e-mail 38CSR2A and 2B. His question is whether the siltation measures include silt fences where runoff might enter streams. He said it is not apparent what best management practices are for this situation, and he wonders if it needs to be spelled out. He knows of some operations in quarries where streams muddy after rainfalls, such as the Elkins and Waco quarries near Snowshoe, and he feels this is harming the streams. Do the new rules address this?

Rocky Parsons responded by saying that design criteria for drainage control structures is found in the technical handbook. Silt fences are not adequate for sediment control. The drainage system must be designed to hold .125 ac/ft of sediment for each acre of disturbed land. All runoff must pass through a drainage control structure. There is a provision for less sediment control (1/2 factor) for certain circumstances as approved by the Director. Effluent limits as established in the NPDES permit must be met.

Tony Grbac, Office of Surface Mining, addressed the following rule:

199CSR1 - "SURFACE MINING BLASTING RULE"

Tony began by briefing the Council on the history of the Surface Mining Blasting Rule. This rule is being proposed to comply with SB681 - passed during the last session. This bill created the Office of Explosives and Blasting and the Office of Coalfield Community Development, which is under the West Virginia Development Office. The proposed rule will regulate blasting laws and rules associated with all surface-mining operations. All duties currently performed by OMR related to blasting, and all rules which now regulate blasting (38CSR2C) will be transferred to this new office. Besides regulating blasting on all surface mining operations, it will also implement and oversee pre-blast survey processes; maintain and operate a system to receive and address questions, concerns and complaints relating to mining

operations; determine the qualifications for individuals and firms performing pre-blast surveys; establish the education, training, examination and certification of blasters; administer a claims process for property damage caused by blasting; and conduct a study of blasting and make recommendations regarding any appropriate rule or code changes.

Tony explained that the revenue generated by the proposed fee in 199CSR1 (one-half cent times the number of pounds of explosive material used during the preceding month for any purpose on the surface mining operations) would fund both the offices, as required by SB681. After one year of collection, both offices are to report to the Legislature as to whether the revenue collected is sufficient to operate both offices.

After several minutes of discussion between DEP and the Council members, Bill Raney expressed his concern in filing the rule for public hearing in the specified time frame. Mr. Raney asked if anyone outside DEP has been involved in drafting the rule. OMR answered by saying the rule was drafted by several staff within OMR. Mr. Raney replied that he believes there will be serious concerns with this rule once industry has had an opportunity to review it. He believes the rule drafting process definitely needs input from firms and individuals outside DEP, and he thinks the process will go smoother once everyone has had the opportunity to address their concerns. Mr. Raney recommended that the Director withhold this rule from the list of rules DEP proposes to file for public hearing/comment period in the coming week to give all interested parties a chance to participate in drafting the rule.

After discussion of this recommendation, Chairman Miano said he believes the best approach would be to continue with the filing of the proposed rule for public hearing, start the rule in the normal process and time frame, and in the meantime he would commit to putting together a work group of interested parties to discuss the rule. If DEP feels that more time is needed once the group begins their work on the rule, he will consider the possibility of either extending the comment period or filing for another public hearing. He said he will also decide in the near future whether DEP will file the rule as an "Emergency Rule" since HB 681 will become effective on June 11.

Council members also pointed out a typographical error in subdivision 3.9.a.3. of the rule relating to cross-references that will be corrected by DEP.

Barb Taylor and Mike Johnson, Office of Water Resources, briefed Council on the following rules:

- o 47CSR57A - "Groundwater Protection Standards at Steam Electric Generating Facilities"
- o 47CSR26 - "Water Pollution Control Permit Fee Schedule"
- o 47CSR31 - "State Water Pollution Control Revolving Fund Program Rule"

Barb described the proposed "new" rule relating to Groundwater Protection Standards at Steam Electric Generating Facilities. She noted that the rule is a result of a Notice of Intent filed on October 24, 1994, by the West Virginia Steam Electric Generation Industry, with the Director of DEP, in accordance with 47CSR57 to apply for a class variance for all West Virginia power stations and associated disposal sites. At that time, DEP provided AEP and AP with the

opportunity to conduct a four-year study to gather the necessary data to support their variance request. The objectives were met by assembling and reviewing data, estimating potential impacts to receptors, and performing an economic assessment impact analysis to the industry, commercial enterprises, and citizens at large if compliance with the Groundwater Protection Act were required without benefit of the variances. After review of the four-year study, the Director determined that granting this request for a variance at these locations would not pose adverse effects to human health or the environment. There are no human or environmental sensitive receptors between the coal storage areas or as ponds; therefore, it is unlikely there will be adverse affects. Barb gave each member a copy of the four-year study on which the Director made his determination.

Chairman Miano told Council that DEP is definitely willing to look at such cases where extensive research and study have been done by the regulated community to back up their findings before granting such variances, and believes DEP will see more studies like this in the future.

Barb next apprised the members on the proposed amendments of the Water Pollution Control Permit Fee Schedule. She stated that amendments are being proposed as a result of HB 2684, passed March 11, 1999, and effective ninety days from passage. The Director is required to implement an emergency rule to implement the fee schedule authorized by the amendments by July 1, 1999. This rule was filed as an "Emergency Rule" on June 7, 1999.

Mike Johnson, Office of Water Resources' Construction Assistance Office, briefed the Council on 47CSR31 - the Water Pollution Control Revolving Fund Program rule. The amendments to this rule are being proposed to allow the State Revolving Fund low interest terms to be extended from 20 years to 30 years for communities that qualify as "disadvantaged." There is only one other state in the country to receive such approval from EPA. Mike informed the Council that he was only recently made aware of this extension by EPA to extend the low interest loans from 20 to 30 years while attending a meeting out of state. This rule was filed as an "Emergency Rule" on May 24, 1999.

Council members unanimously agreed that Mike Johnson should be commended for gathering this information and proposing the amendment to the rule that will enable disadvantaged communities to immediately take steps toward constructing watershed projects that will provide affordable monthly sewer rates.

Open Discussion:

Chairman Miano and Council members expressed their compliments to the program offices for all their hard work, especially with the stakeholders process -- it is obvious a lot of hard work has gone into the process in order to make their efforts more productive.

Bill Raney asked a question relating to the "More or Less" Stringency statement that appears on the front of some DEP rules, but not on others, and voiced his concern if DEP is paying close attention to this, or if the same statement is appearing with all proposed rules. Carrie Chambers from the Director's Office explained that statement was once required to be included in the "General" section of each rule; however, it is now placed in the briefing document that is attached to each rule, and required by the Secretary of State's Office and the

Legislative Rule-Making Review Committee, before it is filed. She went on to explain that with the rush to get draft copies of the rules to Council members as soon as possible, some of the Briefing Documents had not been completed, but would be attached to all DEP rules before they are filed for public hearing. Chairman Miano went on to say it is his belief that all program offices are carefully scrutinizing each rule before that decision is made.

Chairman Miano thanked Council for taking time from their busy schedules to review the extensive list of DEP's proposed rules. He informed the Council that the minutes would be left open for comment until Wednesday, June 16, at which time the minutes will be attached to the rules and filed with the Secretary of State's Office and the Legislative Rule-Making Review Committee for notice of public hearing/comment period.

Before adjourning the meeting, the Council informed Chairman Miano that they would prefer beginning future meetings at 10:00 a.m., instead of the usual time of 1:00 p.m. The meeting was then adjourned at 3:30 p.m.

APPENDIX B

FISCAL NOTE FOR PROPOSED RULES

Rule Title: "Sewage Sludge Management Rule"

Type of Rule: **Legislative** **Interpretive** **Procedural**

Agency: WV Division of Environmental Protection

Address: 1356 Hansford Street
Charleston, WV 25301

No fiscal or economic impact is anticipated from this rule amendment.

1. Effect of Proposed Rule N/A

	ANNUAL FISCAL YEAR				
	INCREASE	DECREASE	CURRENT	NEXT	THEREAFTER
<u>ESTIMATED TOTAL COST</u>	\$	\$	\$	\$	\$
PERSONAL SERVICES					
CURRENT EXPENSE					
REPAIRS & ALTERNATIONS					
EQUIPMENT					
OTHER					

2. Explanation of above estimates:

N/A

3. Objectives of these rules:

Rule Title: "Sewage Sludge Management Rule"

4. Explanation of Overall Economic Impact of Proposed Rule.

A. Economic Impact on State Government.

N/A

B. Economic Impact on Political Subdivisions; Specific Industries; Specific groups of Citizens.

N/A

C. Economic Impact on Citizens/Public at Large.

N/A

Date:

6/17/99

Signature of Agency Head or Authorized Representative

Gario J. Chambers

FILED

JUN 16 9 30 AM '99

TITLE 33
LEGISLATIVE RULE
DIVISION OF ENVIRONMENTAL PROTECTION
OFFICE OF WASTE MANAGEMENT

OFFICE OF WASTE MANAGEMENT
SECRETARY OF STATE

SERIES 2
SEWAGE SLUDGE MANAGEMENT RULE

§33-2-1. General.

1.1. Scope. -- This legislative rule establishes requirements for the permitting siting, bonding, installation, establishment, construction, modification, and operation of any facility that generates, processes, recycles and/or disposes of sewage sludge by whatever means, including, but not limited to, land application, composting, incineration, mixed waste composting, or any other method of handling sewage sludge within the state. This rule applies to any person who owns or operates a sewage sludge facility or who is responsible for the processing or disposal of sewage sludge.

1.2. Authority. -- W. Va. Code §§22-15-8(e), 22-15-20(b) and 22-15-20(q).

1.3. Filing Date. -- ~~April 30, 1999~~

1.4. Effective Date. -- ~~April 30, 1999~~

1.5. Incorporation by Reference. -- Whenever federal or state statutes or regulations are incorporated into this rule by reference, the reference is to the statute or regulation in effect on the effective date of this rule.

§33-2-2. Definitions.

The following definitions shall apply to this rule unless otherwise specified herein:

2.1. "Agricultural Land" is land on which a food crop, feed crop, or fiber crop is grown. This includes, but is not limited to, range land and land used as pasture.

~~2.1.~~ 2.2. "Agronomic rate" means the whole

sewage sludge application rate, by dry weight, designed: (1) To provide the amount of nitrogen needed by the food crop, feed crop, fiber crop, cover crop or vegetation on the land; and (2) To minimize the amount of nitrogen in the sewage sludge that passes below the root zone of the crop or vegetation grown on the land to the ground water.

~~2.2.~~ 2.3. "Applicant" means the person applying for a commercial solid waste facility permit or similar renewal permit and any person related to such person by virtue of common ownership, common management or family relationships as the director may specify, including the following: spouses, parents, children and siblings.

~~2.3.~~ 2.4. "Approved solid waste facility" means a solid waste facility or practice which has a valid permit under W. Va. Code §22-15-1 et seq.

~~2.4.~~ 2.5. "Backhauling" means the practice of using the same container to transport solid waste and to transport any substance or material used as food by humans, animals raised for human consumption or reusable item which may be refilled with any substance or material used as food by humans.

~~2.5.~~ 2.6. "Bulking Agent" means materials mixed or composted with sewage sludge such as yard waste, wood chips, leaves and other living or dead plant tissues approved by the chief as suitable to promote the passage of air through a static pile or windrow.

2.7 "Bulk Sewage Sludge Product" is a material derived from sewage sludge that is sold or given away in quantities exceeding one metric ton.

~~2.6:~~ 2.8. "Chief" means the chief of the Office of Waste Management of the Division.

~~2.7:~~ 2.9. "Class A facility" means a commercial solid waste facility which handles an aggregate of between ten thousand and thirty thousand tons of solid waste per month. Class A facility includes two or more Class B solid waste landfills owned or operated by the same person in the same county, if the aggregate tons of solid waste handled per month by such landfills exceeds nine thousand nine hundred ninety-nine tons of solid waste per month.

~~2.8:~~ 2.10. "Class B facility" means a commercial solid waste facility which receives or is expected to receive an average daily quantity of mixed solid waste equal to or exceeding one hundred tons each working day, or serves or is expected to serve a population equal to or exceeding forty thousand persons, but which does not receive solid waste exceeding an aggregate of ten thousand tons per month. Class B facilities do not include construction/demolition facilities.

~~2.9:~~ 2.11. "Commercial composting facility" means any solid waste facility processing solid waste by composting, including sludge composting, organic waste or yard waste composting, but does not include a composting facility owned and operated by a person for the sole purpose of composting waste created by that person or such person and other persons on a cost-sharing or nonprofit basis and shall not include land upon which finished or matured compost is applied for use as a soil amendment or conditioner.

~~2.10:~~ 2.12. "Commercial recycler" means any person, corporation or business entity whose operation involves the mechanical separation of materials for the purpose of reselling or recycling at least seventy percent (70%) by weight of the materials coming into the commercial recycling facility.

~~2.11:~~ 2.13. "Commercial solid waste facility" means any solid waste facility which accepts solid waste generated by sources other than the owner or operator of the facility and does not include an

approved solid waste facility owned and operated by a person for the sole purpose of the disposal, processing, or composting of solid wastes created by that person or such person and other persons on a cost-sharing or nonprofit basis and shall not include land upon which reused or recycled materials are legitimately applied for structural fill, road base, mine reclamation and similar applications.

~~2.12:~~ 2.14. "Compost" means a humus like material resulting from aerobic, microbial, thermophilic decomposition of organic materials.

~~2.13:~~ 2.15. "Composting" means the aerobic, thermophilic decomposition of natural constituents of solid waste to produce a stable, humus-like material.

~~2.14:~~ 2.16. "Cured compost" or "finished compost" means compost which has a very low microbial or decomposition rate which will not reheat or cause odors when put into storage and that has been put through a separate aerated curing cycle stage of thirty to sixty days after the initial composting cycle or compost which meets all regulatory requirements after the initial composting cycle.

~~2.15:~~ 2.17. "Curing area" means an area where organic material that has undergone the rapid initial stage of decomposition is further stabilized into a humus-like material.

~~2.16:~~ 2.18. "Director" means the director of the division of environmental protection or such person to whom the director has delegated authority or duties pursuant to Chapter 22, Article 1 of the W. Va. Code.

~~2.17:~~ 2.19. "Distributor" is a person who prepares the product for distribution and marketing and is responsible for distributing and marketing the product.

~~2.18:~~ 2.20. "Division" means the Division of Environmental Protection.

~~2.19:~~ 2.21. "Domestic septage" means either

liquid or solid material (septage) removed from a septic tank, cesspool, portable toilet, Type III marine sanitation device, or similar treatment works that receives only domestic sewage. Domestic septage does not include liquid or solid material removed from a septic tank, cesspool, or similar treatment works that receives either commercial wastewater or industrial wastewater and does not include grease removed from a grease trap at a restaurant.

~~2-20.~~ 2.22. "Energy recovery incinerator" means any solid waste facility at which solid waste is incinerated with the intention of using the resulting energy for the generation of steam, electricity or any other use not specified herein.

~~2-21.~~ 2.23. "Incineration technologies" means any technology that uses controlled flame combustion to thermally break down solid waste, including refuse-derived fuel, to an ash residue that contains little or no combustible materials, regardless of whether the purpose is processing, disposal, electric or steam generation or any other method by which solid waste is incinerated.

~~2-22.~~ 2.24. "Incinerator" means an enclosed device using controlled flame combustion to thermally break down solid waste, including refuse-derived fuel, to an ash residue that contains little or no combustible materials.

~~2-23.~~ 2.25. "Landfill" means any solid waste facility for the disposal of solid waste on or in the land for the purpose of permanent disposal. Such facility is situated, for purposes of W. Va. Code §22-15-1 et seq., in the county where the majority of the spatial area of such facility is located.

~~2-24.~~ 2.26. "Materials recovery facility" means any solid waste facility at which source-separated materials or materials recovered through a mixed waste processing facility are manually or mechanically shredded or separated for purposes of reuse and recycling, but does not include a composting facility.

~~2-25.~~ 2.27. "Mature compost" means compost which has been produced in an aerobic, microbial,

thermophilic manner and which does not exhibit toxic effects to plant species.

~~2-26.~~ 2.28. "Mixed solid waste" means solid waste from which materials sought to be reused or recycled have not been source-separated from general solid waste.

~~2-27.~~ 2.29. "Mixed waste processing facility" means any solid waste facility at which materials are recovered from mixed solid waste through manual or mechanical means for purposes of reuse, recycling or composting.

~~2-28.~~ 2.30. "Municipal solid waste incineration" means the burning of any solid waste collected by any municipal or residential solid waste disposal company.

~~2-29.~~ 2.31. "Odor" means a sensation resulting from the stimulation of the human sense of smell.

~~2-30.~~ 2.32. "Open dump" means any solid waste disposal which does not have a permit under W. Va. Code §22-15-1 et seq., or is in violation of state law, or where solid waste is disposed in a manner that does not protect the environment.

2.33. "Other Container" is either an open or closed receptacle. This includes, but is not limited to, a bucket, box, carton, and vehicle or trailer with a load capacity of one metric ton or less.

~~2-31.~~ 2.34. "Person" or "persons" mean any industrial user, public or private corporation, institution, association, firm or company organized or existing under the laws of this or any other state or country; state of West Virginia; governmental agency, including federal facilities; political subdivision; county commission; municipal corporation; industry; sanitary district; public service district; drainage district; soil conservation district; watershed improvement district; partnership trust; estate; person or individual; group of persons or individuals acting individually or as a group; or any legal entity whatever.

~~2-32.~~ 2.35. "Producer" means any person

producing sewage sludge at a publicly owned treatment works (POTW).

~~2.33.~~ ~~2.36.~~ "Publicly owned treatment works" or "POTW" means any treatment works owned by the state or any political subdivision thereof, any municipality or any other public entity which processes raw domestic, industrial, or municipal sewage by artificial or natural processes in order to remove or so alter constituents as to render the waste less offensive or dangerous to the public health, comfort or property of any of the inhabitants of this state, before the discharge of the plant effluent into any waters of this state, and which produces sewage sludge.

~~2.34.~~ ~~2.37.~~ "Recycling facility" means any solid waste facility for the purpose of recycling at which neither land disposal nor biological, chemical or thermal transformation of solid waste occurs: Provided, That mixed waste recovery facilities, sludge processing facilities and composting facilities are not considered recycling facilities nor considered to be reusing or recycling solid waste within the meaning of W. Va. Code §§22C-4-1 et seq. and 20-11-1 et seq.

~~2.35.~~ ~~2.38.~~ "Representative sample" means a sample collected from a population or whole that exhibits the average or typical properties of the larger population or whole.

~~2.36.~~ ~~2.39.~~ "Sewage sludge" means solid, semi-solid or liquid residue generated during the treatment of domestic sewage in a treatment works. Sewage sludge includes, but is not limited to, domestic septage, scum or solids removed in primary, secondary or advanced wastewater treatment processes and a material derived from sewage sludge. "Sewage sludge" does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator.

~~2.37.~~ ~~2.40.~~ "Sewage sludge processing facility" is a solid waste facility that processes sewage sludge for land application, incineration or disposal at an approved landfill. Such processes include, but are not limited to,

composting, lime stabilization, thermophilic digestion and anaerobic digestion.

~~2.38.~~ ~~2.41.~~ "Sludge" means any solid, semisolid, residue or precipitate, separated from or created by a municipal, commercial or industrial waste treatment plant, water supply treatment plant or air pollution control facility or any other such waste having similar origin.

~~2.39.~~ ~~2.42.~~ "Solid waste" means any garbage, paper, litter, refuse, cans, bottles, waste processed for the express purpose of incineration; sludge from a waste treatment plant, water supply treatment plant or air pollution control facility; and other discarded materials, including offensive or unsightly matter, solid, liquid, semisolid or contained liquid or gaseous material resulting from industrial, commercial, mining or community activities but does not include solid or dissolved material in sewage or solid or dissolved materials in irrigation return flows or industrial discharges which are point sources and have permits under W. Va. Code §22-11-1 et seq., or source, special nuclear or by-product material as defined by the Atomic Energy Act of 1954, as amended, including any nuclear or by-product material considered by federal standards to be below regulatory concern, or a hazardous waste either identified or listed under W. Va. Code §22-18-1 et seq., or refuse, slurry, overburden or other wastes or material resulting from coal-fired electric power or steam generation, the exploration, development, production, storage and recovery of coal, oil, and gas and other mineral resources placed or disposed of at a facility which is regulated under W. Va. Code §§22-2-1 et seq., 22-3-1 et seq., 22-4-1 et seq., 22-6-1 et seq., 22-7-1 et seq., 22-8-1 et seq., 22-9-1 et seq. or 22-10-1-1 et seq., so long as such placement or disposal is in conformance with a permit issued pursuant to such chapters.

~~2.40.~~ ~~2.43.~~ "Solid waste disposal" means the practice of disposing of solid waste including placing, depositing, dumping or throwing or causing to be placed, deposited, dumped or thrown any solid waste.

~~2.41.~~ 2.44. "Solid waste facility" means any system, facility, land, contiguous land, improvements on the land, structures or other appurtenances or methods used for processing, recycling or disposing of solid waste, including landfills, transfer stations, materials recovery facilities, mixed waste processing facilities, sewage sludge processing facilities, commercial composting facilities and other such facilities not herein specified but not including land upon which sewage sludge is applied in accordance with W. Va. Code §22-15-20. Such facility shall be deemed to be situated, for purposes of this rule, in the county where the majority of the spatial area of such facility is located: Provided, That a salvage yard licensed and regulated pursuant to the terms of W. Va. Code §17-23-et seq., is not a solid waste facility.

~~2.42.~~ 2.45. "Solid waste facility operator" means any person or persons possessing or exercising operational, managerial or financial control over a commercial solid waste facility, whether or not such person holds a certificate of convenience and necessity or a permit for such a facility.

~~2.43.~~ 2.46. "Source separated materials" means materials separated from general solid waste at the point of origin for the purpose of reuse and recycling but does not mean sewage sludge.

~~2.44.~~ 2.47. "Source separated organic waste" means readily degradable organic material such as food waste, yard waste and wood waste, except pressure-treated wood waste, which is collected separately from the mixed solid waste stream. It does not include sewage sludge or domestic septage.

~~2.45.~~ 2.48. "Stabilization" means the decomposition of organic material to the point where it neither reheats when wetted nor gives off offensive odors and does not include pathogens, toxins or vectors in excess of Federal regulations 40CFR503.

§33-1-3. Standards for Use, Disposal and Processing of Sewage Sludge.

3.1. Incorporation of Federal Regulations. -- Federal regulations 40CFR503, excluding sections 503.10(b)(1) and 503.20 through 503.29 inclusive, in effect on the effective date this rule, are hereby fully incorporated and implemented as a part of this rule promulgated under the authority of W. Va. Code §22-15-20. Provided, That in instances where similar provisions exist, the more stringent requirements (state or federal) shall apply.

3.2. Sewage Sludge Land Application Siting Restrictions and Location Standards.

3.2.a. Except as provided in subsection 3.2.b of this rule, sewage S-sludge will shall not be applied to land that meets any of the following conditions:

3.2.a.1. Land that is frozen, snow-covered, or known to be flooded on a regular basis unless the applicant can demonstrate to the director that the land application will not cause runoff into streams or wetlands.

3.2.a.2. Land within fifty (50) feet of surface water to include streams, springs, ponds, wetlands, or other collection points for surface water.

3.2.a.3. Land within two hundred (200) feet of drinking water supply wells or other personal water supply.

3.2.a.4. Land within two hundred (200) feet of an occupied dwelling.

3.2.a.5. Land within fifty (50) feet of a federal or state highway.

3.2.a.6. Land within one hundred (100) feet of an adjacent property owner's property line.

3.2.a.7. Land from which drainage leads into a sinkhole.

3.2.a.8. Land that has been tested and determined to have a pH of less than 6.2, unless the pH is adjusted to 6.2 or greater.

3.2.a.9. Land that has a slope greater than 15%.

3.2.a.10. Land that has a seasonal high groundwater table less than 2 feet from the surface.

3.2.a.11. Land that has less than 6 inches of soil over bedrock or an impervious pan.

3.2.a.12. Land containing soil with surface permeability of less than 0.6 inches/hour or greater than 6 inches/hour.

3.2.a.13. Other land determined by the director to be unsuitable for application of sewage sludge.

3.2.b Sewage sludge products which have been treated to achieve Class A pathogen reduction and vector attraction reduction requirements in accordance with 40CRF503.32(a) and 40CFR503.33(b), and which are sold or given away in a bag or other container, are not subject to the requirements of 3.1.b of this rule except that these sewage sludge products shall not be applied to land that meets the any of the following conditions:

3.2.b.1. Land within 50 feet of any surface water, or surface water collection point.

3.2.b.2 Land with a slope greater than 15%.

~~3.2.b.~~ 3.2.c. No person or entity shall be allowed to apply sewage sludge to land in a manner that will result in exceeding the maximum soil concentration for arsenic, cadmium, chromium, copper, lead, mercury, molybdenum, nickel, selenium, and or zinc, as listed in Table 3 of this rule and the soil testing requirements of this rule. The director is authorized ~~until December 31, 1999~~ to issue variances to this subdivision to allow land

application to soils which where the background levels of metals in the soil exceed the maximum soil concentrations of metals listed in Table 3; where Provided, that the sewage sludge analyses, soil analyses, and pollutant loss rates from erosion, leaching, and volatilization demonstrate that other soil factors, including but not limited to, soil pH, cation exchange capacity, organic matter content, or clay content, will limit mobility and availability of the metals at a loading rate prescribed by the director, the land application of the sewage sludge will not cause additional net accumulation of any metal in the soil already exceeding the maximum soil concentration listed in Table 3. Any such variance issued by the director shall contain a requirement to annually monitor the soil concentration of each metal exceeding the Table 3 limit for as long as the site is utilized for the land application of sewage sludge or sewage sludge products. No later than June 30, 1999, the director shall propose revisions to Table 3 to adequately protect soil quality, human health and the environment.

3.2.c.1. Analytical methods in SW-846 shall be used to analyze all soil metals samples required by this rule.

~~3.2.b.1.~~ 3.2.c.2. The director shall assign an individual and lifetime loading rate for each land application site by considering background soil concentrations and maximum allowable pollutant concentrations as per Table 1 and per Table 3 of this rule. New soil analyses for those metals listed in Table 3 shall be required at each land application site whenever the site has received for land application fifty percent of the assigned lifetime loading rate.

~~3.2.b.2.~~ 3.2.c.3. If circumstances at sewage sludge processing facilities result in short term excursions of Table 1 criteria, written notification must be given to the Chief of the Office of Water Resources within five days of learning of the excursion. A written plan to identify and correct the problem must be submitted for the facility within sixty days. The

director may develop temporary loading rates, for a period not to exceed ~~six months~~ one year, based on the provisional limitations of Table 2 of this rule and on results from monthly sewage sludge and wastewater samples taken at the facility.

~~3.2.e.~~ 3.2.d. No person shall be allowed to land apply so much sewage sludge as to exceed the agronomic rate for that land or a rate of fifteen dry tons per acre per year, whichever is less: Provided, That up to twenty-five dry tons per acre per year may be applied in the reclamation of surface mine land.

~~3.2.d.~~ 3.2.e. No person shall be allowed to store sewage sludge at a land application site for a period longer than one week; except storage shall be allowed for no longer than three months where provisions, approved by the chief of the Office of Water Resources of the Division, have been made to prevent leachate runoff into surface or groundwater. Septage storage shall only be allowed in-tank and for no more than three days, or as otherwise authorized by the chief of the Office of Water Resources of the Division.

~~3.2.e.~~ 3.2.f. No person shall be allowed to land apply sludge except during the hours of daylight.

3.3. Sewage Sludge Processing Facility Operational and Design Requirements.

3.3.a. Sewage sludge processing facilities must adhere to the following requirements:

3.3.a.1. Areas used for processing, curing and storage of raw materials, intermediate and final products, loading and unloading areas, impoundments, pipelines, ditches, pumps and drums, sumps and tanks, must be designed, constructed and operated to prevent release of contaminants to the groundwater and surface water. Storage of finished products from the facility shall be limited to one year.

3.3.a.2. The facility must be designed and operated to control vectors and odors.

3.3.a.3. The facility must not be operated or constructed within the one hundred year flood plain unless provisions have been made to prevent the encroachment of flood waters upon the facility.

3.3.a.4. All land areas within the boundaries of a sewage sludge processing facility upon which sewage sludge, intermediate or final products come in direct contact with the land surface must be protected in accordance with the Groundwater Protection Act, W. Va. Code §22-12-1 et seq., and the rules promulgated thereunder, including 46CSR12, 46CSR58, and 46CSR59.

3.3.b. Any person operating a sewage sludge processing facility shall conduct off-site odor monitoring. The frequency of odor monitoring shall be quarterly or as otherwise specified by the director. The Barnebey-Cheney scentometer or other instrument, device or technique designated by the director may be used as a guide in the enforcement of this rule and may used in the determination of the objectionability of an odor.

3.3.b.1. When an odor is determined to be objectionable and repetitious by the director, the director may require the facility to conduct related studies within a specified time period. These studies may include, but are not limited to, sampling and analysis to identify the specific chemical compound(s) which are causing the objectionable odor, analysis of samples by odor panels, air dispersion modeling studies, and evaluation of applicable odor control devices and odor control programs.

3.4. Leachate Management Requirements.

3.4.a. Any liquid which comes in contact with sewage sludge at a sewage sludge processing facility must be handled as leachate and is subject to the requirements of W. Va.

Code §§22-11 and 12, and the rules promulgated thereunder.

3.5. Storm Water Requirements.

3.5.a. Storm water drainage must be directed around and away from the operating area. All storm water must be collected and discharged in compliance with State Water Quality Standards and the permit issued by the Office of Water Resources of the Division.

3.6. Landfill Disposal of Sewage Sludge.

3.6.a. Sewage sludge disposed in a landfill shall contain at least twenty percent (20%) solids by weight. This requirement may be met by adding or blending sand, sawdust, lime, soil, or other materials that have been approved by the director prior to disposal. Alternative sludge disposal methods can be utilized upon obtaining prior written approval from the chief.

3.6.b. Sewage sludge may not represent more than twenty-five percent (25%) by weight of the total weight of waste disposed of at the landfill on any working day.

3.6.c. No facility may accept for landfilling in any month sewage sludge in excess of twenty-five percent (25%) of the total tons of solid waste accepted at the facility for landfilling in the preceding month.

3.6.d. Sewage sludge shall not be used as daily cover by a landfill.

§33-2-4. Permits Required.

4.1. Applicability.

4.1.a. No person may construct or operate a sewage sludge processing facility (including mixed waste composting facilities which utilize sewage sludge) or a commercial solid waste facility which processes or handles sewage sludge or materials derived from sewage

sludge without first obtaining a solid waste facility permit.

4.1.b. On and after the effective date of this rule, all permitted facilities shall submit an application to modify such permit.

4.1.c. Except as provided in 4.1.c.1 and 4.1.c.2 of this rule, No person may land apply sewage sludge without first obtaining a land application permit: Provided, That land application permit requirements may be incorporated into a modification of a facility's WV/NPDES permit required under W. Va. Code §22-11-1 et seq.

4.1.c.1. A land application permit is not required for sewage sludge products which have been treated to achieve Class A pathogen reduction and vector attraction reduction requirements in accordance with 40CRF503.32(a) and 40CFR503.33(b), and which are sold or given away in a bag or other container;

4.1.c.2. A land application permit is not required for bulk sewage sludge products which have been treated to achieve Class A pathogen reduction and vector attraction reduction requirements in accordance with 40CRF503.32(a) and 40CFR503.33(b), when such products are applied on agricultural land less than two acres in size and the annual quantity of sludge product applied to that site does not exceed two dry tons per acre, except that those products derived from domestic septage shall not be exempt from permitting requirements. This exemption from permitting does not apply to multiple sites on the same parcel of land.

4.1.d. For those publicly owned treatment works (POTW's) or privately owned treatment works which produce sewage sludge and are regulated by the Division pursuant to a water pollution control permit, including a West Virginia national pollutant discharge elimination system WV/NPDES permit required under W.

Va. Code §22-11-1 et seq., a sewage sludge processing facility modification will be obtained by the applicant as a part of the existing WV/NPDES permit and shall include a sewage sludge management plan approved by the director. Upon approval by the director, POTWs may accept sewage sludge from other publicly or privately owned treatment works on a cost-sharing or non-profit basis under its WV/NPDES permit without being considered a commercial solid waste facility.

4.1.e. Facilities which are surface disposal sites as defined in 40CFR503, Subpart C, are hereby defined as "landfills" and must meet all requirements of 33CSR1 applicable to landfills.

4.1.f. Permits issued under subdivision 4.1.a of this rule, shall be subject to the provisions of 33CSR1, section 3 (excluding the provisions for liner requirements) and the closure requirements of 33CSR1, section 6.

4.1.g. Permits issued under subdivision 4.1.d. of this rule, shall be subject to the permit issuance procedures, procedures for permit modifications, suspension and revocation, procedures for transfer of permits, and the procedures for permit appeals of 47CSR10 but are not subject to the procedures outlined in subdivisions 4.1.e, 4.1.f and 4.1.h of this rule.

4.1.h. Permits issued under subdivision 4.1.e of this rule, shall be subject to the procedures of 33CSR1 section 3 and the closure requirements of 33CSR1 section 6.

4.1.i. Permits issued under subdivision 4.1.c of this rule except for land application modifications made in WV/NPDES permits under subdivision 4.1.d of this rule shall be subject to the permit issuance procedures (subsections 3.17 through 3.29 inclusive) of 33CSR1 and are not subject to the procedures outlined in subdivisions 4.1.e, 4.1.f and 4.1.g of this rule.

4.2. General, Processing Facility, and Land Application Permit Requirements. -- Persons required to obtain a permit pursuant to this rule must provide the following information, in the form and manner prescribed by the chief of the Office of Waste Management or the Office of Water Resources of the Division as appropriate. The form may require information in addition to that required by this subsection.

4.2.a. Permit Application General Requirements. -- All applicants must provide the following information:

4.2.a.1. The name, address, and location of the facility;

4.2.a.2. A description of the activities conducted or to be conducted by the applicant;

4.2.a.3. The operator's and owner's name, address, telephone number, ownership status, and status as a federal, state, private, public or other entity;

4.2.a.4. Other environmental permits issued by any local, state or federal agency;

4.2.a.5. A description of the specific source(s) of sewage sludge;

4.2.a.6. The amount of sewage sludge actually generated, processed, land applied, or disposed;

4.2.a.7. The content of heavy metals, pathogens, toxins or vectors and moisture (percent solids) present in the sewage sludge;

4.2.a.8. Each location that the sewage sludge is stored, land applied or otherwise disposed of; the amount so stored, land applied or otherwise disposed of; and the capacity of that location to accept sewage sludge;

4.2.a.9. Information relative to the quality of the sewage sludge(s) or product(s) derived from sewage sludge as required by 40CFR503, and

4.2.a.10. A detailed design and a description of the method used to collect and control leachate and surface water runoff, including the method for treatment and disposal of leachate generated.

4.2.b. Sewage Sludge Processing Facility Permit Requirements. -- All applicants for permits for sewage sludge processing facilities, except facilities located at the site where sewage sludge is generated, must submit the following additional information:

4.2.b.1. An engineering report to construct a sewage sludge processing facility must contain, at a minimum, the following:

4.2.b.1.A. A regional map, or maps, (of appropriate scale) that delineate the entire service area of the proposed facility; existing and proposed collection, processing, and disposal operations; the location of the closest population centers; and the transportation systems including highways, airports, railways and waterways;

4.2.b.1.B. A vicinity map (minimum scale of 1"=2000') that delineates the area within one mile of the facility boundaries, zoning and land use, residences, potable water supplies, surface waters, access roads, bridges, railroads, airports, historic sites, and other existing and proposed man-made or natural features relating to the project;

4.2.b.1.C. A site plan (minimum scale of 1"=200' with five foot contour intervals) that delineates property boundaries, the location of existing and proposed soil boring, monitoring wells, buildings and appurtenances, fences, gates, roads, parking areas, drainage, culverts, storage facilities or areas, loading areas; existing and proposed elevation contours and direction of prevailing

winds; and the location of residences, potable wells, surface water bodies, and drainage swales located within the site and in the site plan area; and

4.2.b.1.D. A map indicating wetlands and flood plains within 1,000 feet of the site, if any.

4.2.b.2. A description of the operation of the facility, detailed engineering plans and specifications for the entire facility, must be submitted by the applicant including at a minimum:

4.2.b.2.A. A schedule of operation, including the days and hours that the facility will be open, preparations before opening, and procedures followed after closing for the day;

4.2.b.2.B. Anticipated daily traffic flow to and from the facility, including the number of trips by private or public collection vehicles, and the quantity of material contained in each vehicle;

4.2.b.2.C. The procedure for unloading trucks (including frequency, rate, and method);

4.2.b.2.D. Special precautions or procedures for operation during wind, heavy rain, snow, and freezing conditions;

4.2.b.2.E. A description of the ultimate use for the finished compost or other product, a marketing plan for the finished compost, method for removal from the site, and a plan for use or disposal of those finished products that cannot be used in the expected manner due to poor quality or change in market conditions;

4.2.b.2.F. A (description) copy of the label or other information source, by the distributor, that outlines the type of waste the compost product was derived from, a list of any

restrictions on use, and recommended safe uses and application rates;

4.2.b.2.G. Identification of the personnel required to operate and maintain the facility and their job descriptions/responsibilities;

4.2.b.2.H. A detailed description of the source, and anticipated quality, and quantity of any bulking agent to be used in the process; and

4.2.b.2.I. A detailed description of the quantity, quality and specific source of the sewage sludge received or anticipated to be received.

4.2.b.3. The permit application must contain an operating engineering report which must include, at a minimum, the following:

4.2.b.3.A. Detailed engineering plans and specifications for the entire sewage sludge processing facility, including manufacturer's performance data for the selected equipment;

4.2.b.3.B. Contingency plans detailing corrective (or remedial) action to be taken in the event of equipment breakdown; air pollution (odors); unacceptable waste delivered to the facility; groundwater contamination; spills; and undesirable conditions such as fires, dust, noise, vectors, lack of a market for the compost product and unusual traffic conditions; and

4.2.b.3.C. An Operation and Maintenance Manual. -- The manual must contain general design information, detailed operational information and instructions. In addition, the manual must list the specific procedures used or to be used in monitoring, sampling and analyzing sewage sludge and the finished product, and record keeping requirements.

4.2.b.4. A description of the design of the facility, including:

4.2.b.4.A. The type, size, and associated detention times of equipment used in the handling, processing, and storage of sewage sludge;

4.2.b.4.B. The method of measuring, shredding, mixing, and proportioning input materials;

4.2.b.4.C. A description and sizing of the storage facilities for amendment, bulking agent, and finished product;

4.2.b.4.D. The separation, processing, storage, and ultimate disposal of materials that cannot be composted, if applicable;

4.2.b.4.E. The location of all temperature and any other type of monitoring points, and the frequency of monitoring;

4.2.b.4.F. A process flow diagram of the entire process, including all major equipment and flow streams. The flow streams must indicate the quantity of material on a wet weight, dry weight, and volumetric basis;

4.2.b.4.G. The aeration capacity of the system;

4.2.b.4.H. The method of supplying and regulating airflow;

4.2.b.4.I. The expected mass balance through the composting system;

4.2.b.4.J. A description of how the (temperature) monitoring equipment will ensure that facility qualifies as a process to further reduce pathogens, toxins, heavy metals and/or vectors; and

4.2.b.4.K. A description of the air emission collection and control technologies.

4.2.b.5. A description of existing and potential land-use of the area within one mile of the facility.

4.2.b.6. A certified copy of any municipal or county zoning restrictions, if applicable.

4.2.c. Land Application Permit Requirement. -- Persons performing land application of sewage sludge or materials derived from sewage sludge must submit the following information to the chief of the Office of Water Resources of the Division in addition to that required under subdivision 4.2.a. of this rule:

4.2.c.1. Soil analysis for all land application sites including but not limited to pH, potassium, phosphorus, nitrogen, all metals listed in Table 1 of this rule and any additional chemical analysis required by the director;

4.2.c.2. Information relative to the nitrogen content of the sludge(s) or product(s) derived from sewage sludge to be land applied;

4.2.c.3. A soils map with application sites clearly defined;

4.2.c.4. An agreement between the preparer of sewage sludge(s) or material(s) derived from sewage sludge, the applier, and the owner of the land application site indicating each party's concurrence with the application, and certifying that each will comply with applicable requirements of 40CFR503. and this rule;

4.2.c.5. A description of existing and future uses of the land application site;

4.2.c.6. Information relative to past application(s) of sewage sludge or material(s) derived from sewage sludge as necessary to comply with section 40CFR503.12 and this rule;

4.2.c.7. Information relative to past fertilizer applications to the site;

4.2.c.8. In addition to the chemical analyses required in subdivision 4.2.a of this rule, any additional chemical analyses of sewage sludge(s) or material(s) derived from sewage sludge, requested by the chief of the Office of Water Resources of the Division, including, but not limited to sodium, chloride, fluoride, calcium and sulfates;

4.2.c.9. A description of the methods to be used for land application;

4.2.c.10. A description of the methods for transportation of sludge to the site;

4.2.c.11. A copy of the NPDES permit for the POTW from which the sludge or material originated;

4.2.c.12. Information relative to the significant industrial users of the POTW from which the sludge or material originated;

4.2.c.13. A description of the methods by which pathogen control and vector attraction reduction are being achieved; and

4.2.c.14. A description of the methods to be utilized to adjust and maintain the soil to a minimum pH of 6.2 for at least 5 years from the date of application.

§33-1-5. General, Processing Facility, and Land Application Permit Requirements.

5.1. Permit General Requirements. -- All permits issued pursuant to this rule shall contain the following:

5.1.a. Any requirement of 40CFR503, including but not limited to:

5.1.a.1. Limitations on the concentrations of pollutants (heavy metals), toxins, vectors and pathogens in the sewage sludge or sewage sludge products;

5.1.a.2. Requirements relative to monitoring sewage sludge and sewage sludge product quality and reporting the results of those

analyses for pH, percent solids, organic nitrogen, potassium, phosphorus, calcium, magnesium, total nitrogen, ammonia nitrogen, pathogen test results, vector attraction verification; and all heavy metals listed in Table 1 of this rule except that the frequency of monitoring shall be as described in Appendix A of this rule; except that permits issued for land application of domestic septage shall contain requirements to monitor the soil at the land application sites in lieu of sampling individual domestic septic tank systems. Such permits for domestic septage shall contain a provision requiring a manifest listing each source of domestic septage and certifying that the domestic septage contains no industrial or commercial waste products;

5.1.a.3. Requirements relative to reporting and certification;

5.1.a.4. Requirement to pay fees as identified in section 6 of this rule;

5.1.a.5. Requirements for the proper collection, control and disposal of leachate and stormwater runoff for the protection of groundwater, surface waters, and potable waters in the area;

5.1.a.6. Requirements to retain records for the facility for a minimum of five years;

5.1.a.7. Requirements to monitor and report monthly to the Division the specific source and quantity of sewage sludge generated, treated, stored, processed, composted, disposed, or placed;

5.1.a.8. Requirements not to exceed a commercial solid waste facility's tonnage limits, where applicable;

5.1.a.9. Requirements to provide copies of monthly reports to the county or regional solid waste authority in which the facility or land application site(s) is located;

5.1.a.10. Any other requirements, including additional monitoring, determined to

be necessary by the director to insure compliance with state and federal regulations;

5.2. Processing Facility Permit Requirements. -- In addition to the requirements of subsection 5.1. of this rule, any solid waste facility permit issued to a sewage sludge processing facility, pursuant to this rule, must contain the following:

5.2.a. Operational requirements relative to pathogen control in accordance with 40CFR503.32. and its Appendix B;

5.2.b. Operational requirements relative to vector attraction reduction in accordance with 40CFR503.33;

5.2.c. Requirements to routinely monitor and report information relative to the quality of raw materials used in the sewage sludge processing facility including but not limited to: sewage sludge, bulking agents, and kiln dust; except that the frequency of monitoring shall be as described in Appendix A of this rule;

5.2.d. Limitations for the pollutant concentrations of the end product of the sewage sludge processing facility;

5.2.e. Labeling requirements as per 40CFR503.14.e, if applicable, and subsection 3.2.b of this rule;

5.2.f. Requirements for the implementation of practices to prevent the contamination of ground and surface waters, including liners if necessary;

5.2.g. For commercial sewage sludge processing facilities, requirements for reporting in accordance with 33CSR1 subsection 4.12.; and

5.2.h. Requirements for the implementation of practices to protect air quality in and around the facility.

5.3. Land Application Permit Requirements. -- In addition to the requirements of subsection 5.1 of this rule, any land application permit issued pursuant to this rule shall contain the following:

5.3.a. Requirements delineating the sites for which land application is approved;

5.3.b. Limitations on the maximum amount of sewage sludge allowed to be land applied;

5.3.c. Requirements implementing the siting restrictions and location standards of subsection 3.2 of this rule;

5.3.d. Requirements limiting the types of crops that may be grown on land used for application of sewage sludge and the time between application of sewage sludge and the harvesting of crops, in accordance with 40CFR503.32.(b);

5.3.e. Restrictions on animal grazing and public access, in accordance with 40CFR503.32.(b);

5.3.f. Applicable vector attraction reduction requirements of 40CFR503.33; and

5.3.g. Applicable pathogen reduction requirements of 40CFR503.32 and its Appendix B; except that domestic septage shall be held at or above a pH of 12.0 for a period of at least two hours before being applied to land at any location.

§33-1-6. Fee and Bonding Requirements.

6.1. Applicability. -- Any producer, processor, or transporter of sewage sludge for land application shall be subject to non-refundable fees, as described herein, which shall be used to cover the costs of the sewage sludge management program. The fees established herein in subdivisions 6.4.a and 6.4.b of this rule shall be assessed on forms prescribed by the chief of the Office of Water Resources of the Division and shall be paid to said chief quarterly.

6.2. Water Quality Management Fund. -- Fees collected for land application shall be deposited in the special revenue fund designated the "Water Quality Management Fund" established under the provisions of W. Va. Code §22-11-10 except as otherwise specified herein.

6.3. Bonding. -- The director may require a surety bond, deposit or similar instrument in an amount sufficient to cover the cost of future environmental remediation from producers, processors, or transporters of sewage sludge.

6.4. Fee Assessments.

6.4.a. Producers, processors, or transporters of sewage sludge or material derived from sewage sludge for land application shall be assessed a sewage sludge management program fee calculated as \$5.00 per actual ton of sludge times the proportion of solids in the sludge for sludge with maximum metals concentrations not exceeding those listed in Table 1 of this rule.

6.4.b. All sewage sludge placed in, or used in a landfill disposal cell by a solid waste facility shall be subject to the same tipping and other fees as levied on the disposal of solid waste under W. Va. Code §22; Provided, That no such fees, excepting assessment fees required by this subdivision, shall be levied upon the application of sewage sludge to land outside a solid waste facility in accordance with the statute and this rule.

6.4.c. Fees generated pursuant to subdivision 6.4.a. shall be reviewed periodically by the director and shall be adjusted as necessary to assure that total collections shall not exceed \$200,000 per year.

APPENDIX A
FREQUENCY OF MONITORING

AMOUNT OF SEWAGE SLUDGE RECEIVED FREQUENCY (actual dry tons per 365 day period)	OF MONITORING
Greater than zero but less than 290	once every 6 months
Equal to or greater than 290 but less than 1,500	once per quarter (4 times per year)
Equal to or greater than 1,500 but less than 15,000	once per month (12 times per year)
Equal to or greater than 15,000	once per week

TABLE 1
MAXIMUM CONCENTRATION OF METALS IN SEWAGE SLUDGE
FOR LAND APPLICATION

Metal	Concentration (mg/kg)
Arsenic	41 20
Cadmium	10 39
Chromium	1000
Copper	1000 1500
Lead	250
Mercury	10
Molybdenum	18
Nickel	200
Selenium	36
Zinc	2500 2800

TABLE 2
PROVISIONAL MAXIMUM CONCENTRATION OF METALS IN SEWAGE SLUDGE
FOR PRODUCERS NOT MEETING TABLE 1 CRITERIA

Metal	Concentration (mg/kg)
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
Selenium	100
Zinc	7500

TABLE 3
MAXIMUM ALLOWABLE SOIL CONCENTRATIONS

Metal	Concentration (mg/kg)	
Arsenic	18.0	13.0
Cadmium	5.0	2.4
Chromium	300.0	290
Copper	300.0	92
Lead	70.0	85
Mercury	2.0	2.4
Molybdenum	4.0	4.6
Nickel	74.0	83*
Selenium	7.0	10
Zinc	500.0	290**

* For sandy to silt loam soils with a permeability greater than 2.0 inches per hour, the maximum allowable soil concentration for nickel is 50 mg/kg.

** For those sites with greater than 30% legume species, the maximum allowable soil concentration for zinc is 130 mg/kg for sandy to silt loam soils with permeability greater than 2.0 inches per hour and 200 mg/kg for other soil types.

Federal Counterpart Regulation

PART 503—STANDARDS FOR THE USE OR DISPOSAL OF SEWAGE SLUDGE

Subpart A—General Provisions

- Sec.
- 503.1 Purpose and applicability.
 - 503.2 Compliance period.
 - 503.3 Permits and direct enforceability
 - 503.4 Relationship to other regulations.
 - 503.5 Additional or more stringent requirements.
 - 503.6 Exclusions.
 - 503.7 Requirement for a person who prepares sewage sludge.
 - 503.8 Sampling and analysis.
 - 503.9 General definitions.

Subpart B—Land Application

- 503.10 Applicability.
- 503.11 Special definitions.
- 503.12 General requirements.
- 503.13 Pollutant limits.
- 503.14 Management practices.
- 503.15 Operational standards—pathogens and vector attraction reduction.
- 503.16 Frequency of monitoring.
- 503.17 Recordkeeping.
- 503.18 Reporting.

Subpart C—Surface Disposal

- 503.20 Applicability.
- 503.21 Special definitions.
- 503.22 General requirements.
- 503.23 Pollutant limits (other than domestic septage).
- 503.24 Management practices.
- 503.25 Operational standards—pathogens and vector attraction reduction.
- 503.26 Frequency of monitoring.
- 503.27 Recordkeeping.
- 503.28 Reporting.

Subpart D—Pathogens and Vector Attraction Reduction

- 503.30 Scope.
- 503.31 Special definitions.
- 503.32 Pathogens.
- 503.33 Vector attraction reduction.

Subpart E—Incineration

- 503.40 Applicability.
- 503.41 Special definitions.
- 503.42 General requirements.
- 503.43 Pollutant limits.
- 503.44 Operational standard—total hydrocarbons.
- 503.45 Management practices.
- 503.46 Frequency of monitoring.
- 503.47 Recordkeeping.
- 503.48 Reporting.

APPENDIX A TO PART 503—PROCEDURE TO DETERMINE THE ANNUAL WHOLE SLUDGE APPLICATION RATE FOR A SEWAGE SLUDGE

APPENDIX B TO PART 503—PATHOGEN TREATMENT PROCESSES

AUTHORITY: Sections 405 (d) and (e) of the Clean Water Act, as amended by Pub. L. 95-217, sec. 54(d), 91 Stat. 1591 (33 U.S.C. 1345 (d) and (e)); and Pub. L. 100-4, title IV, sec. 406 (a), (b), 101 Stat., 71, 72 (33 U.S.C. 1251 *et seq.*).

SOURCE: 58 FR 9387, Feb. 19, 1993, unless otherwise noted.

Subpart A—General Provisions

§503.1 Purpose and applicability.

(a) *Purpose.* (1) This part establishes standards, which consist of general requirements, pollutant limits, management practices, and operational standards, for the final use or disposal of sewage sludge generated during the treatment of domestic sewage in a treatment works. Standards are included in this part for sewage sludge applied to the land, placed on a surface disposal site, or fired in a sewage sludge incinerator. Also included in this part are pathogen and alternative vector attraction reduction requirements for sewage sludge applied to the land or placed on a surface disposal site.

(2) In addition, the standards in this part include the frequency of monitoring and recordkeeping requirements when sewage sludge is applied to the land, placed on a surface disposal site, or fired in a sewage sludge incinerator. Also included in this part are reporting requirements for Class I sludge management facilities, publicly owned treatment works (POTWs) with a design flow rate equal to or greater than one million gallons per day, and POTWs that serve 10,000 people or more.

(b) *Applicability.* (1) This part applies to any person who prepares sewage sludge, applies sewage sludge to the land, or fires sewage sludge in a sewage sludge incinerator and to the owner/operator of a surface disposal site.

(2) This part applies to sewage sludge applied to the land, placed on a surface disposal site, or fired in a sewage sludge incinerator.

(3) This part applies to the exit gas from a sewage sludge incinerator stack.

(4) This part applies to land where sewage sludge is applied, to a surface disposal site, and to a sewage sludge incinerator.

§503.2 Compliance period.

(a) Compliance with the standards in this part shall be achieved as expeditiously as practicable, but in no case later than February 19, 1994. When compliance with the standards requires construction of new pollution control facilities, compliance

§ 503.3

with the standards shall be achieved as expeditiously as practicable, but in no case later than February 19, 1995.

(b) The requirements for frequency of monitoring, recordkeeping, and reporting in this part for total hydrocarbons in the exit gas from a sewage sludge incinerator are effective February 19, 1994 or, if compliance with the operational standard for total hydrocarbons in this part requires the construction of new pollution control facilities, February 19, 1995.

(c) All other requirements for frequency of monitoring, recordkeeping, and reporting in this part are effective on July 20, 1993.

§ 503.3 Permits and direct enforceability.

(a) Permits. The requirements in this part may be implemented through a permit:

(1) Issued to a "treatment works treating domestic sewage", as defined in 40 CFR 122.2, in accordance with 40 CFR parts 122 and 124 by EPA or by a State that has a State sludge management program approved by EPA in accordance with 40 CFR part 123 or 40 CFR part 501 or

(2) Issued under subtitle C of the Solid Waste Disposal Act; part C of the Safe Drinking Water Act; the Marine Protection, Research, and Sanctuaries Act of 1972; or the Clean Air Act. "Treatment works treating domestic sewage" shall submit a permit application in accordance with either 40 CFR 122.21 or an approved State program.

(b) Direct enforceability. No person shall use or dispose of sewage sludge through any practice for which requirements are established in this part except in accordance with such requirements.

§ 503.4 Relationship to other regulations.

Disposal of sewage sludge in a municipal solid waste landfill unit, as defined in 40 CFR 258.2, that complies with the requirements in 40 CFR part 258 constitutes compliance with section 405(d) of the CWA. Any person who prepares sewage sludge that is disposed in a municipal solid waste landfill unit shall ensure that the sewage sludge meets the requirements in 40 CFR part 258 concerning the quality of materials disposed in a municipal solid waste landfill unit.

§ 503.5 Additional or more stringent requirements.

(a) On a case-by-case basis, the permitting authority may impose requirements for the use or disposal of sewage sludge in addition to or more stringent than the requirements in this part when necessary to protect public health and the environment from any adverse effect of a pollutant in the sewage sludge.

(b) Nothing in this part precludes a State or political subdivision thereof or interstate agency from imposing requirements for the use or disposal of sewage sludge more stringent than the requirements in this part or from imposing additional requirements for the use or disposal of sewage sludge.

§ 503.6 Exclusions.

(a) *Treatment processes.* This part does not establish requirements for processes used to treat domestic sewage or for processes used to treat sewage sludge prior to final use or disposal, except as provided in § 503.32 and § 503.33.

(b) *Selection of a use or disposal practice.* This part does not require the selection of a sewage sludge use or disposal practice. The determination of the manner in which sewage sludge is used or disposed is a local determination.

(c) *Co-firing of sewage sludge.* This part does not establish requirements for sewage sludge co-fired in an incinerator with other wastes or for the incinerator in which sewage sludge and other wastes are co-fired. Other wastes do not include auxiliary fuel, as defined in 40 CFR 503.41(b), fired in a sewage sludge incinerator.

(d) *Sludge generated at an industrial facility.* This part does not establish requirements for the use or disposal of sludge generated at an industrial facility during the treatment of industrial wastewater, including sewage sludge generated during the treatment of industrial wastewater combined with domestic sewage.

(e) *Hazardous sewage sludge.* This part does not establish requirements for the use or disposal of sewage sludge determined to be hazardous in accordance with 40 CFR part 261.

(f) *Sewage sludge with high PCB concentration.* This part does not establish requirements for the use or disposal of sewage sludge with a concentration of polychlorinated biphenyls (PCBs) equal to or greater than 50 milligrams per kilogram of total solids (dry weight basis).

(g) *Incinerator ash.* This part does not establish requirements for the use or disposal of ash generated during the firing of sewage sludge in a sewage sludge incinerator.

(h) *Grit and screenings.* This part does not establish requirements for the use or disposal of grit (e.g., sand, gravel, cinders, or other materials with a high specific gravity) or screenings (e.g., relatively large materials such as rags) generated during preliminary treatment of domestic sewage in a treatment works.

(i) *Drinking water treatment sludge.* This part does not establish requirements for the use or disposal of sludge generated during the treatment of either surface water or ground water used for drinking water.

(j) *Commercial and industrial septage.* This part does not establish requirements for the use or disposal of commercial septage, industrial septage, a mixture of domestic septage and commercial septage, or a mixture of domestic septage and industrial septage.

§ 503.7 Requirement for a person who prepares sewage sludge.

Any person who prepares sewage sludge shall ensure that the applicable requirements in this part are met when the sewage sludge is applied to the land, placed on a surface disposal site, or fired in a sewage sludge incinerator.

§ 503.8 Sampling and analysis.

(a) *Sampling.* Representative samples of sewage sludge that is applied to the land, placed on a surface disposal site, or fired in a sewage sludge incinerator shall be collected and analyzed.

(b) *Methods.* The materials listed below are incorporated by reference in this part. These incorporations by reference were approved by the Director of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. The materials are incorporated as they exist on the date of approval, and notice of any change in these materials will be published in the FEDERAL REGISTER. They are available for inspection at the Office of the Federal Register, 7th Floor, suite 700, 800 North Capitol Street, NW., Washington, DC, and at the Office of Water Docket, room L-102, U.S. Environmental Protection Agency, 401 M Street, SW., Washington, DC. Copies may be obtained from the standard producer or publisher listed in the regulation. Methods in the materials listed below shall be used to analyze samples of sewage sludge.

(1) *Enteric viruses.* ASTM Designation: D 4994-89, "Standard Practice for Recovery of Viruses From Wastewater Sludges", 1992 Annual Book of ASTM Standards: Section 11—Water and Environmental Technology, ASTM, 1916 Race Street, Philadelphia, PA 19103-1187.

(2) *Fecal coliform.* Part 9221 E. or Part 9222 D., "Standard Methods for the Examination of Water and Wastewater", 18th Edition, 1992, American Public Health Association, 1015 15th Street, NW., Washington, DC 20005.

(3) *Helminth ova.* Yanko, W.A., "Occurrence of Pathogens in Distribution and Marketing Municipal Sludges", EPA 600/1-87-014, 1987. National Technical Information Service, 5285 Port Royal Road, Springfield, Virginia 22161 (PB 88-154273/AS).

(4) *Inorganic pollutants.* "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846, Second Edition (1982) with Updates I (April 1984) and II (April

1985) and Third Edition (November 1986) with Revision I (December 1987). Second Edition and Updates I and II are available from the National Technical Information Service, 5285 Port Royal Road, Springfield, Virginia 22161 (PB-87-120-291). Third Edition and Revision I are available from Superintendent of Documents, Government Printing Office, 941 North Capitol Street, NE., Washington, DC 20002 (Document Number 955-001-00000-1).

(5) *Salmonella sp. bacteria.* Part 9260 D., "Standard Methods for the Examination of Water and Wastewater", 18th Edition, 1992, American Public Health Association, 1015 15th Street, NW., Washington, DC 20005; or

Kenner, B.A. and H.P. Clark, "Detection and enumeration of *Salmonella* and *Pseudomonas aeruginosa*", Journal of the Water Pollution Control Federation, Vol. 46, no. 9, September 1974, pp. 2163-2171. Water Environment Federation, 601 Wythe Street, Alexandria, Virginia 22314.

(6) *Specific oxygen uptake rate.* Part 2710 B., "Standard Methods for the Examination of Water and Wastewater", 18th Edition, 1992, American Public Health Association, 1015 15th Street, NW., Washington, DC 20005.

(7) *Total, fixed, and volatile solids.* Part 2540 G., "Standard Methods for the Examination of Water and Wastewater", 18th Edition, 1992, American Public Health Association, 1015 15th Street, NW., Washington, DC 20005.

§ 503.9 General definitions.

(a) *Apply sewage sludge or sewage sludge applied to the land* means land application of sewage sludge.

(b) *Base flood* is a flood that has a one percent chance of occurring in any given year (i.e., a flood with a magnitude equalled once in 100 years).

(c) *Class I sludge management facility* is any publicly owned treatment works (POTW), as defined in 40 CFR 501.2, required to have an approved pretreatment program under 40 CFR 403.8(a) (including any POTW located in a State that has elected to assume local program responsibilities pursuant to 40 CFR 403.10(e)) and any treatment works treating domestic sewage, as defined in 40 CFR 122.2, classified as a Class I sludge management facility by the EPA Regional Administrator, or, in the case of approved State programs, the Regional Administrator in conjunction with the State Director, because of the potential for its sewage sludge use or disposal practice to affect public health and the environment adversely.

(d) *Cover crop* is a small grain crop, such as oats, wheat, or barley, not grown for harvest.

(e) *CWA* means the Clean Water Act (formerly referred to as either the Federal Water Pollution

§ 503.9

Act or the Federal Water Pollution Control Act Amendments of 1972), Public Law 92-500, as amended by Public Law 95-217, Public Law 95-576, Public Law 96-483, Public Law 97-117, and Public Law 100-4.

(f) *Domestic septage* is either liquid or solid material removed from a septic tank, cesspool, portable toilet, Type III marine sanitation device, or similar treatment works that receives only domestic sewage. Domestic septage does not include liquid or solid material removed from a septic tank, cesspool, or similar treatment works that receives either commercial wastewater or industrial wastewater and does not include grease removed from a grease trap at a restaurant.

(g) *Domestic sewage* is waste and wastewater from humans or household operations that is discharged to or otherwise enters a treatment works.

(h) *Dry weight basis* means calculated on the basis of having been dried at 105 degrees Celsius until reaching a constant mass (i.e., essentially 100 percent solids content).

(i) *EPA* means the United States Environmental Protection Agency.

(j) *Feed crops* are crops produced primarily for consumption by animals.

(k) *Fiber crops* are crops such as flax and cotton.

(l) *Food crops* are crops consumed by humans. These include, but are not limited to, fruits, vegetables, and tobacco.

(m) *Ground water* is water below the land surface in the saturated zone.

(n) *Industrial wastewater* is wastewater generated in a commercial or industrial process.

(o) *Municipality* means a city, town, borough, county, parish, district, association, or other public body (including an intermunicipal Agency of two or more of the foregoing entities) created by or under State law; an Indian tribe or an authorized Indian tribal organization having jurisdiction over sewage sludge management; or a designated and approved management Agency under section 208 of the CWA, as amended. The definition includes a special district created under State law, such as a water district, sewer district, sanitary district, utility district, drainage district, or similar entity, or an integrated waste management facility as defined in section 201(e) of the CWA, as amended, that has as one of its principal responsibilities the treatment, transport, use, or disposal of sewage sludge.

(p) *Permitting authority* is either EPA or a State with an EPA-approved sludge management program.

(q) *Person* is an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

(r) *Person who prepares sewage sludge* is either the person who generates sewage sludge during the treatment of domestic sewage in a treatment works or the person who derives a material from sewage sludge.

(s) *Place sewage sludge or sewage sludge placed* means disposal of sewage sludge on a surface disposal site.

(t) *Pollutant* is an organic substance, an inorganic substance, a combination of organic and inorganic substances, or a pathogenic organism that, after discharge and upon exposure, ingestion, inhalation, or assimilation into an organism either directly from the environment or indirectly by ingestion through the food chain, could, on the basis of information available to the Administrator of EPA, cause death, disease, behavioral abnormalities, cancer, genetic mutations, physiological malfunctions (including malfunction in reproduction), or physical deformations in either organisms or offspring of the organisms.

(u) *Pollutant limit* is a numerical value that describes the amount of a pollutant allowed per unit amount of sewage sludge (e.g., milligrams per kilogram of total solids); the amount of a pollutant that can be applied to a unit area of land (e.g., kilograms per hectare); or the volume of a material that can be applied to a unit area of land (e.g., gallons per acre).

(v) *Runoff* is rainwater, leachate, or other liquid that drains overland on any part of a land surface and runs off of the land surface.

(w) *Sewage sludge* is solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works. Sewage sludge includes, but is not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment processes; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screenings generated during preliminary treatment of domestic sewage in a treatment works.

(x) *State* is one of the United States of America, the District of Columbia, the Commonwealth of Puerto Rico, the Virgin Islands, Guam, American Samoa, the Trust Territory of the Pacific Islands, the Commonwealth of the Northern Mariana Islands, and an Indian Tribe eligible for treatment as a State pursuant to regulations promulgated under the authority of section 518(e) of the CWA.

(y) *Store or storage of sewage sludge* is the placement of sewage sludge on land on which the sewage sludge remains for two years or less. This does not include the placement of sewage sludge on land for treatment.

(z) *Treat or treatment of sewage sludge* is the preparation of sewage sludge for final use or dis-

posal. This includes, but is not limited to, thickening, stabilization, and dewatering of sewage sludge. This does not include storage of sewage sludge.

(aa) *Treatment works* is either a federally owned, publicly owned, or privately owned device or system used to treat (including recycle and reclaim) either domestic sewage or a combination of domestic sewage and industrial waste of a liquid nature.

(bb) *Wetlands* means those areas that are inundated or saturated by surface water or ground water at a frequency and duration to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

Subpart B—Land Application

§ 503.10 Applicability.

(a) This subpart applies to any person who prepares sewage sludge that is applied to the land, to any person who applies sewage sludge to the land, to sewage sludge applied to the land, and to the land on which sewage sludge is applied.

(b)(1) *Bulk sewage sludge*. The general requirements in § 503.12 and the management practices in § 503.14 do not apply when bulk sewage sludge is applied to the land if the bulk sewage sludge meets the pollutant concentrations in § 503.13(b)(3), the Class A pathogen requirements in § 503.32(a), and one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8).

(2) The Regional Administrator of EPA or, in the case of a State with an approved sludge management program, the State Director, may apply any or all of the general requirements in § 503.12 and the management practices in § 503.14 to the bulk sewage sludge in § 503.10(b)(1) on a case-by-case basis after determining that the general requirements or management practices are needed to protect public health and the environment from any reasonably anticipated adverse effect that may occur from any pollutant in the bulk sewage sludge.

(c)(1) The general requirements in § 503.12 and the management practices in § 503.14 do not apply when a bulk material derived from sewage sludge is applied to the land if the derived bulk material meets the pollutant concentrations in § 503.13(b)(3), the Class A pathogen requirements in § 503.32(a), and one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8).

(2) The Regional Administrator of EPA or, in the case of a State with an approved sludge management program, the State Director, may apply

any or all of the general requirements in § 503.12 or the management practices in § 503.14 to the bulk material in § 503.10(c)(1) on a case-by-case basis after determining that the general requirements or management practices are needed to protect public health and the environment from any reasonably anticipated adverse effect that may occur from any pollutant in the bulk sewage sludge.

(d) The requirements in this subpart do not apply when a bulk material derived from sewage sludge is applied to the land if the sewage sludge from which the bulk material is derived meets the pollutant concentrations in § 503.13(b)(3), the Class A pathogen requirements in § 503.32(a), and one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8).

(e) *Sewage sludge sold or given away in a bag or other container for application to the land*. The general requirements in § 503.12 and the management practices in § 503.14 do not apply when sewage sludge is sold or given away in a bag or other container for application to the land if the sewage sludge sold or given away in a bag or other container for application to the land meets the pollutant concentrations in § 503.13(b)(3), the Class A pathogen requirements in § 503.32(a), and one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8).

(f) The general requirements in § 503.12 and the management practices in § 503.14 do not apply when a material derived from sewage sludge is sold or given away in a bag or other container for application to the land if the derived material meets the pollutant concentrations in § 503.13(b)(3), the Class A pathogen requirements in § 503.32(a), and one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8).

(g) The requirements in this subpart do not apply when a material derived from sewage sludge is sold or given away in a bag or other container for application to the land if the sewage sludge from which the material is derived meets the pollutant concentrations in § 503.13(b)(3), the Class A pathogen requirements in § 503.32(a), and one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8).

§ 503.11 Special definitions.

(a) *Agricultural land* is land on which a food crop, a feed crop, or a fiber crop is grown. This includes range land and land used as pasture.

(b) *Agronomic rate* is the whole sludge application rate (dry weight basis) designed:

(1) To provide the amount of nitrogen needed by the food crop, feed crop, fiber crop, cover crop, or vegetation grown on the land; and

§ 503.12

(2) To minimize the amount of nitrogen in the sewage sludge that passes below the root zone of the crop or vegetation grown on the land to the ground water.

(c) *Annual pollutant loading rate* is the maximum amount of a pollutant that can be applied to a unit area of land during a 365 day period.

(d) *Annual whole sludge application rate* is the maximum amount of sewage sludge (dry weight basis) that can be applied to a unit area of land during a 365 day period.

(e) *Bulk sewage sludge* is sewage sludge that is not sold or given away in a bag or other container for application to the land.

(f) *Cumulative pollutant loading rate* is the maximum amount of an inorganic pollutant that can be applied to an area of land.

(g) *Forest* is a tract of land thick with trees and underbrush.

(h) *Land application* is the spraying or spreading of sewage sludge onto the land surface; the injection of sewage sludge below the land surface; or the incorporation of sewage sludge into the soil so that the sewage sludge can either condition the soil or fertilize crops or vegetation grown in the soil.

(i) *Monthly average* is the arithmetic mean of all measurements taken during the month.

(j) *Other container* is either an open or closed receptacle. This includes, but is not limited to, a bucket, a box, a carton, and a vehicle or trailer with a load capacity of one metric ton or less.

(k) *Pasture* is land on which animals feed directly on feed crops such as legumes, grasses, grain stubble, or stover.

(l) *Public contact site* is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.

(m) *Range land* is open land with indigenous vegetation.

(n) *Reclamation site* is drastically disturbed land that is reclaimed using sewage sludge. This includes, but is not limited to, strip mines and construction sites.

§ 503.12 General requirements.

(a) No person shall apply sewage sludge to the land except in accordance with the requirements in this subpart.

(b) No person shall apply bulk sewage sludge subject to the cumulative pollutant loading rates in § 503.13(b)(2) to agricultural land, forest, a public contact site, or a reclamation site if any of the cumulative pollutant loading rates in § 503.13(b)(2) has been reached.

(c) No person shall apply domestic septage to agricultural land, forest, or a reclamation site dur-

ing a 365 day period if the annual application rate in § 503.13(c) has been reached during that period.

(d) The person who prepares bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall provide the person who applies the bulk sewage sludge written notification of the concentration of total nitrogen (as N on a dry weight basis) in the bulk sewage sludge.

(e)(1) The person who applies sewage sludge to the land shall obtain information needed to comply with the requirements in this subpart.

(2)(i) Before bulk sewage sludge subject to the cumulative pollutant loading rates in § 503.13(b)(2) is applied to the land, the person who proposes to apply the bulk sewage sludge shall contact the permitting authority for the State in which the bulk sewage sludge will be applied to determine whether bulk sewage sludge subject to the cumulative pollutant loading rates in § 503.13(b)(2) has been applied to the site since July 20, 1993.

(ii) If bulk sewage sludge subject to the cumulative pollutant loading rates in § 503.13(b)(2) has not been applied to the site since July 20, 1993, the cumulative amount for each pollutant listed in Table 2 of § 503.13 may be applied to the site in accordance with § 503.13(a)(2)(i).

(iii) If bulk sewage sludge subject to the cumulative pollutant loading rates in § 503.13(b)(2) has been applied to the site since July 20, 1993, and the cumulative amount of each pollutant applied to the site in the bulk sewage sludge since that date is known, the cumulative amount of each pollutant applied to the site shall be used to determine the additional amount of each pollutant that can be applied to the site in accordance with § 503.13(a)(2)(i).

(iv) If bulk sewage sludge subject to the cumulative pollutant loading rates in § 503.13(b)(2) has been applied to the site since July 20, 1993, and the cumulative amount of each pollutant applied to the site in the bulk sewage sludge since that date is not known, an additional amount of each pollutant shall not be applied to the site in accordance with § 503.13(a)(2)(i).

(f) When a person who prepares bulk sewage sludge provides the bulk sewage sludge to a person who applies the bulk sewage sludge to the land, the person who prepares the bulk sewage sludge shall provide the person who applies the sewage sludge notice and necessary information to comply with the requirements in this subpart.

(g) When a person who prepares sewage sludge provides the sewage sludge to another person who prepares the sewage sludge, the person who provides the sewage sludge shall provide the person who receives the sewage sludge notice and nec-

essary information to comply with the requirements in this subpart.

(h) The person who applies bulk sewage sludge to the land shall provide the owner or lease holder of the land on which the bulk sewage sludge is applied notice and necessary information to comply with the requirements in this subpart.

(i) Any person who prepares bulk sewage sludge that is applied to land in a State other than the State in which the bulk sewage sludge is prepared shall provide written notice, prior to the initial application of bulk sewage sludge to the land application site by the applier, to the permitting authority for the State in which the bulk sewage sludge is proposed to be applied. The notice shall include:

(1) The location, by either street address or latitude and longitude, of each land application site.

(2) The approximate time period bulk sewage sludge will be applied to the site.

(3) The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who prepares the bulk sewage sludge.

(4) The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk sewage sludge.

(j) Any person who applies bulk sewage sludge subject to the cumulative pollutant loading rates in § 503.13(b)(2) to the land shall provide written notice, prior to the initial application of bulk sewage sludge to a land application site by the applier, to the permitting authority for the State in which the bulk sewage sludge will be applied and the permitting authority shall retain and provide access to the notice. The notice shall include:

(1) The location, by either street address or latitude and longitude, of the land application site.

(2) The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) of the person who will apply the bulk sewage sludge.

§ 503.13 Pollutant limits.

(a) Sewage sludge. (1) Bulk sewage sludge or sewage sludge sold or given away in a bag or other container shall not be applied to the land if the concentration of any pollutant in the sewage sludge exceeds the ceiling concentration for the pollutant in Table 1 of § 503.13.

(2) If bulk sewage sludge is applied to agricultural land, forest, a public contact site, or a reclamation site, either:

(i) The cumulative loading rate for each pollutant shall not exceed the cumulative pollutant loading rate for the pollutant in Table 2 of § 503.13; or

(ii) The concentration of each pollutant in the sewage sludge shall not exceed the concentration for the pollutant in Table 3 of § 503.13.

(3) If bulk sewage sludge is applied to a lawn or a home garden, the concentration of each pollutant in the sewage sludge shall not exceed the concentration for the pollutant in Table 3 of § 503.13.

(4) If sewage sludge is sold or given away in a bag or other container for application to the land, either:

(i) The concentration of each pollutant in the sewage sludge shall not exceed the concentration for the pollutant in Table 3 of § 503.13; or

(ii) The product of the concentration of each pollutant in the sewage sludge and the annual whole sludge application rate for the sewage sludge shall not cause the annual pollutant loading rate for the pollutant in Table 4 of § 503.13 to be exceeded. The procedure used to determine the annual whole sludge application rate is presented in appendix A of this part.

(b) Pollutant concentrations and loading rates—sewage sludge.

(1) Ceiling concentrations.

TABLE 1 OF § 503.13.—CEILING CONCENTRATIONS

Pollutant	Ceiling concentration (milligrams per kilogram) ¹
Arsenic	75
Cadmium	85
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
Selenium	100
Zinc	7500

¹ Dry weight basis.

(2) Cumulative pollutant loading rates.

TABLE 2 OF § 503.13.—CUMULATIVE POLLUTANT LOADING RATES

Pollutant	Cumulative pollutant loading rate (kilograms per hectare)
Arsenic	41
Cadmium	39
Copper	1500
Lead	300
Mercury	17
Nickel	420
Selenium	100
Zinc	2800

(3) Pollutant concentrations.

§ 503.14

TABLE 3 OF § 503.13.—POLLUTANT CONCENTRATIONS

Pollutant	Monthly average concentration (milligrams per kilogram) ¹
Arsenic	41
Cadmium	39
Copper	1500
Lead	300
Mercury	17
Nickel	420
Selenium	100
Zinc	2800

¹ Dry weight basis.

(4) Annual pollutant loading rates.

TABLE 4 OF § 503.13.—ANNUAL POLLUTANT LOADING RATES

Pollutant	Annual pollutant loading rate (kilograms per hectare per 365 day period)
Arsenic	2.0
Cadmium	1.9
Copper	75
Lead	15
Mercury	0.85
Nickel	21
Selenium	5.0
Zinc	140

(c) Domestic septage.

The annual application rate for domestic septage applied to agricultural land, forest, or a reclamation site shall not exceed the annual application rate calculated using equation (1).

$$AAR = \frac{N}{0.0026} \quad \text{Eq. (1)}$$

Where:

AAR=Annual application rate in gallons per acre per 365 day period.

N=Amount of nitrogen in pounds per acre per 365 day period needed by the crop or vegetation grown on the land.

[58 FR 9387, Feb. 19, 1993, as amended at 58 FR 9099, Feb. 25, 1994; 60 FR 54769, Oct. 25, 1995]

§ 503.14 Management practices.

(a) Bulk sewage sludge shall not be applied to the land if it is likely to adversely affect a threatened or endangered species listed under section 4 of the Endangered Species Act or its designated critical habitat.

(b) Bulk sewage sludge shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk sewage sludge enters a wetland or other waters of the United States, as defined in 40 CFR 122.2, except as provided in a permit issued pursuant to section 402 or 404 of the CWA.

(c) Bulk sewage sludge shall not be applied to agricultural land, forest, or a reclamation site that is 10 meters or less from waters of the United States, as defined in 40 CFR 122.2, unless otherwise specified by the permitting authority.

(d) Bulk sewage sludge shall be applied to agricultural land, forest, a public contact site, or a reclamation site at a whole sludge application rate that is equal to or less than the agronomic rate for the bulk sewage sludge, unless, in the case of a reclamation site, otherwise specified by the permitting authority.

(e) Either a label shall be affixed to the bag or other container in which sewage sludge that is sold or given away for application to the land, or an information sheet shall be provided to the person who receives sewage sludge sold or given away in an other container for application to the land. The label or information sheet shall contain the following information:

(1) The name and address of the person who prepared the sewage sludge that is sold or given away in a bag or other container for application to the land.

(2) A statement that application of the sewage sludge to the land is prohibited except in accordance with the instructions on the label or information sheet.

(3) The annual whole sludge application rate for the sewage sludge that does not cause any of the annual pollutant loading rates in Table 4 of § 503.13 to be exceeded.

§ 503.15 Operational standards—pathogens and vector attraction reduction.

(a) *Pathogens—sewage sludge.* (1) The Class A pathogen requirements in § 503.32(a) or the Class B pathogen requirements and site restrictions in § 503.32(b) shall be met when bulk sewage sludge is applied to agricultural land, forest, a public contact site, or a reclamation site.

(2) The Class A pathogen requirements in § 503.32(a) shall be met when bulk sewage sludge is applied to a lawn or a home garden.

(3) The Class A pathogen requirements in § 503.32(a) shall be met when sewage sludge is sold or given away in a bag or other container for application to the land.

(b) *Pathogens—domestic septage.* The requirements in either § 503.32 (c)(1) or (c)(2) shall be

met when domestic septage is applied to agricultural land, forest, or a reclamation site.

(c) *Vector attraction reduction—sewage sludge.* (1) One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(10) shall be met when bulk sewage sludge is applied to agricultural land, forest, a public contact site, or a reclamation site.

(2) One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) shall be met when bulk sewage sludge is applied to a lawn or a home garden.

(3) One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) shall be met when sewage sludge is sold or given away in a bag or other container for application to the land.

(d) *Vector attraction reduction—domestic septage.* The vector attraction reduction requirements in § 503.33(b)(9), (b)(10), or (b)(12) shall be met when domestic septage is applied to agricultural land, forest, or a reclamation site.

§ 503.16 Frequency of monitoring.

(a) *Sewage sludge.* (1) The frequency of monitoring for the pollutants listed in Table 1, Table 2, Table 3 and Table 4 of § 503.13; the pathogen density requirements in § 503.32(a) and in § 503.32(b)(2) through (b)(4); and the vector attraction reduction requirements § 503.33 (b)(1) through § 503.33(b)(8) shall be the frequency in Table 1 of § 503.16.

TABLE 1 OF § 503.16.—FREQUENCY OF MONITORING—LAND APPLICATION

Amount of sewage sludge ¹ (metric tons per 365 day period)	Frequency
Greater than zero but less than 290.	Once per year.
Equal to or greater than 290 but less than 1,500.	Once per quarter (four times per year).
Equal to or greater than 1,500 but less than 15,000.	Once per 60 days (six times per year).
Equal to or greater than 15,000.	Once per month (12 times per year).

¹ Either the amount of bulk sewage sludge applied to the land or the amount of sewage sludge received by a person who prepares sewage sludge that is sold or given away in a bag or other container for application to the land (dry weight basis).

(2) After the sewage sludge has been monitored for two years at the frequency in Table 1 of § 503.16, the permitting authority may reduce the frequency of monitoring for pollutant concentrations and for the pathogen density requirements in § 503.32 (a)(5)(ii) and (a)(5)(iii), but in no case shall the frequency of monitoring be less than once per year when sewage sludge is applied to the land.

(b) *Domestic septage.* If either the pathogen requirements in § 503.32(c)(2) or the vector attraction reduction requirements in § 503.33(b)(12) are met when domestic septage is applied to agricultural land, forest, or a reclamation site, each container of domestic septage applied to the land shall be monitored for compliance with those requirements.

(Approved by the Office of Management and Budget under control number 2040-0157)

§ 503.17 Recordkeeping.

(a) *Sewage sludge.* (1) The person who prepares the sewage sludge in § 503.10(b)(1) or (e) shall develop the following information and shall retain the information for five years:

(i) The concentration of each pollutant listed in Table 3 of § 503.13 in the sewage sludge.

(ii) The following certification statement:

"I certify, under penalty of law, that the Class A pathogen requirements in § 503.32(a) and the vector attraction reduction requirement in [insert one of the vector attraction reduction requirements in § 503.33(b)(1) through § 503.33(b)(8)] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

(iii) A description of how the Class A pathogen requirements in § 503.32(a) are met.

(iv) A description of how one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) is met.

(2) The person who derives the material in § 503.10 (c)(1) or (f) shall develop the following information and shall retain the information for five years:

(i) The concentration of each pollutant listed in Table 3 of § 503.13 in the material.

(ii) The following certification statement:

"I certify, under penalty of law, that the Class A pathogen requirements in § 503.32(a) and the vector attraction reduction requirement in [insert one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8)] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and the vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

(iii) A description of how the Class A pathogen requirements in § 503.32(a) are met.

§ 503.17

(iv) A description of how one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) is met.

(3) If the pollutant concentrations in § 503.13(b)(3), the Class A pathogen requirements in § 503.32(a), and the vector attraction reduction requirements in either § 503.33 (b)(9) or (b)(10) are met when bulk sewage sludge is applied to agricultural land, forest, a public contact site, or a reclamation site:

(i) The person who prepares the bulk sewage sludge shall develop the following information and shall retain the information for five years.

(A) The concentration of each pollutant listed in Table 3 of § 503.13 in the bulk sewage sludge.

(B) The following certification statement:

"I certify, under penalty of law, that the pathogen requirements in § 503.32(a) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

(C) A description of how the pathogen requirements in § 503.32(a) are met.

(ii) The person who applies the bulk sewage sludge shall develop the following information and shall retain the information for five years.

(A) The following certification statement:

"I certify, under penalty of law, that the management practices in § 503.14 and the vector attraction reduction requirement in [insert either § 503.33 (b)(9) or (b)(10)] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

(B) A description of how the management practices in § 503.14 are met for each site on which bulk sewage sludge is applied.

(C) A description of how the vector attraction reduction requirements in either § 503.33(b)(9) or (b)(10) are met for each site on which bulk sewage sludge is applied.

(4) If the pollutant concentrations in § 503.13(b)(3) and the Class B pathogen requirements in § 503.32(b) are met when bulk sewage sludge is applied to agricultural land, forest, a public contact site, or a reclamation site:

(i) The person who prepares the bulk sewage sludge shall develop the following information and shall retain the information for five years:

(A) The concentration of each pollutant listed in Table 3 of § 503.13 in the bulk sewage sludge.

(B) The following certification statement:

"I certify under, penalty of law, that the Class B pathogen requirements in § 503.32(b) and the vector attraction reduction requirement in [insert one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) if one of those requirements is met] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements [and vector attraction reduction requirements if applicable] have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

(C) A description of how the Class B pathogen requirements in § 503.32(b) are met.

(D) When one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) is met, a description of how the vector attraction reduction requirement is met.

(ii) The person who applies the bulk sewage sludge shall develop the following information and shall retain the information for five years.

(A) The following certification statement:

"I certify, under penalty of law, that the management practices in § 503.14, the site restrictions in § 503.32(b)(5), and the vector attraction reduction requirements in [insert either § 503.33 (b)(9) or (b)(10), if one of those requirements is met] have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices and site restrictions [and the vector attraction reduction requirements if applicable] have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

(B) A description of how the management practices in § 503.14 are met for each site on which bulk sewage sludge is applied.

(C) A description of how the site restrictions in § 503.32(b)(5) are met for each site on which bulk sewage sludge is applied.

(D) When the vector attraction reduction requirement in either § 503.33 (b)(9) or (b)(10) is met, a description of how the vector attraction reduction requirement is met.

(5) If the requirements in § 503.13(a)(2)(i) are met when bulk sewage sludge is applied to agricultural land, forest, a public contact site, or a reclamation site:

(i) The person who prepares the bulk sewage sludge shall develop the following information and shall retain the information for five years.

(A) The concentration of each pollutant listed in Table 1 of § 503.13 in the bulk sewage sludge.

(B) The following certification statement:

"I certify, under penalty of law, that the pathogen requirements in [insert either § 503.32(a) or § 503.32(b)] and the vector attraction reduction requirement in [insert one of the vector attraction reduction requirements in

§ 503.33 (b)(1) through (b)(8) if one of those requirements is met] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements [and vector attraction reduction requirements] have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

(C) A description of how the pathogen requirements in either § 503.32 (a) or (b) are met.

(D) When one of the vector attraction requirements in § 503.33 (b)(1) through (b)(8) is met, a description of how the vector attraction requirement is met.

(ii) The person who applies the bulk sewage sludge shall develop the following information, retain the information in § 503.17 (a)(5)(ii)(A) through (a)(5)(ii)(G) indefinitely, and retain the information in § 503.17 (a)(5)(ii)(H) through (a)(5)(ii)(M) for five years.

(A) The location, by either street address or latitude and longitude, of each site on which bulk sewage sludge is applied.

(B) The number of hectares in each site on which bulk sewage sludge is applied.

(C) The date and time bulk sewage sludge is applied to each site.

(D) The cumulative amount of each pollutant (i.e., kilograms) listed in Table 2 of § 503.13 in the bulk sewage sludge applied to each site, including the amount in § 503.12(e)(2)(iii).

(E) The amount of sewage sludge (i.e., metric tons) applied to each site.

(F) The following certification statement:

"I certify, under penalty of law, that the requirements to obtain information in § 503.12(e)(2) have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the requirements to obtain information have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

(G) A description of how the requirements to obtain information in § 503.12(e)(2) are met.

(H) The following certification statement:

"I certify, under penalty of law, that the management practices in § 503.14 have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

(I) A description of how the management practices in § 503.14 are met for each site on which bulk sewage sludge is applied.

(J) The following certification statement when the bulk sewage sludge meets the Class B pathogen requirements in § 503.32(b):

"I certify, under penalty of law, that the site restrictions in § 503.32(b)(5) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the site restrictions have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

(K) A description of how the site restrictions in § 503.32(b)(5) are met for each site on which Class B bulk sewage sludge is applied.

(L) The following certification statement when the vector attraction reduction requirement in either § 503.33 (b)(9) or (b)(10) is met:

"I certify, under penalty of law, that the vector attraction reduction requirement in [insert either § 503.33(b)(9) or § 503.33(b)(10)] has been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the vector attraction reduction requirement has been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

(M) If the vector attraction reduction requirements in either § 503.33 (b)(9) or (b)(10) are met, a description of how the requirements are met.

(6) If the requirements in § 503.13(a)(4)(ii) are met when sewage sludge is sold or given away in a bag or other container for application to the land, the person who prepares the sewage sludge that is sold or given away in a bag or other container shall develop the following information and shall retain the information for five years:

(i) The annual whole sludge application rate for the sewage sludge that does not cause the annual pollutant loading rates in Table 4 of § 503.13 to be exceeded.

(ii) The concentration of each pollutant listed in Table 4 of § 503.13 in the sewage sludge.

(iii) The following certification statement:

"I certify, under penalty of law, that the management practice in § 503.14(e), the Class A pathogen requirement in § 503.32(a), and the vector attraction reduction requirement in [insert one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8)] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practice, pathogen requirements, and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification."

§ 503.18

cation including the possibility of fine and imprisonment.”

(iv) A description of how the Class A pathogen requirements in § 503.32(a) are met.

(v) A description of how one of the vector attraction requirements in § 503.33 (b)(1) through (b)(8) is met.

(b) *Domestic septage*. When domestic septage is applied to agricultural land, forest, or a reclamation site, the person who applies the domestic septage shall develop the following information and shall retain the information for five years:

(1) The location, by either street address or latitude and longitude, of each site on which domestic septage is applied.

(2) The number of acres in each site on which domestic septage is applied.

(3) The date and time domestic septage is applied to each site.

(4) The nitrogen requirement for the crop or vegetation grown on each site during a 365 day period.

(5) The rate, in gallons per acre per 365 day period, at which domestic septage is applied to each site.

(6) The following certification statement:

“I certify, under penalty of law, that the pathogen requirements in [insert either § 503.32(c)(1) or § 503.32(c)(2)] and the vector attraction reduction requirements in [insert § 503.33(b)(9), § 503.33(b)(10), or § 503.33(b)(12)] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.”

(7) A description of how the pathogen requirements in either § 503.33 (c)(1) or (c)(2) are met.

(8) A description of how the vector attraction reduction requirements in § 503.33 (b)(9), (b)(10), or (b)(12) are met.

(Approved by the Office of Management and Budget under control number 2040-0157)

§ 503.18 Reporting.

(a) Class I sludge management facilities, POTWs (as defined in 40 CFR 501.2) with a design flow rate equal to or greater than one million gallons per day, and POTWs that serve 10,000 people or more shall submit the following information to the permitting authority:

(1) The information in § 503.17(a), except the information in § 503.17 (a)(3)(ii), (a)(4)(ii) and in (a)(5)(ii), for the appropriate requirements on February 19 of each year.

(2) The information in § 503.17 (a)(5)(ii)(A) through (a)(5)(ii)(G) on [insert the month and day from the date of publication of this rule] of each year when 90 percent or more of any of the cumulative pollutant loading rates in Table 2 of § 503.13 is reached at a site.

(Approved by the Office of Management and Budget under control number 2040-0157)

Subpart C—Surface Disposal

§ 503.20 Applicability.

(a) This subpart applies to any person who prepares sewage sludge that is placed on a surface disposal site, to the owner/operator of a surface disposal site, to sewage sludge placed on a surface disposal site, and to a surface disposal site.

(b) This subpart does not apply to sewage sludge stored on the land or to the land on which sewage sludge is stored. It also does not apply to sewage sludge that remains on the land for longer than two years when the person who prepares the sewage sludge demonstrates that the land on which the sewage sludge remains is not an active sewage sludge unit. The demonstration shall include the following information, which shall be retained by the person who prepares the sewage sludge for the period that the sewage sludge remains on the land:

(1) The name and address of the person who prepares the sewage sludge.

(2) The name and address of the person who either owns the land or leases the land.

(3) The location, by either street address or latitude and longitude, of the land.

(4) An explanation of why sewage sludge needs to remain on the land for longer than two years prior to final use or disposal.

(5) The approximate time period when the sewage sludge will be used or disposed.

(c) This subpart does not apply to sewage sludge treated on the land or to the land on which sewage sludge is treated.

§ 503.21 Special definitions.

(a) *Active sewage sludge unit* is a sewage sludge unit that has not closed.

(b) *Aquifer* is a geologic formation, group of geologic formations, or a portion of a geologic formation capable of yielding ground water to wells or springs.

(c) *Contaminate an aquifer* means to introduce a substance that causes the maximum contaminant level for nitrate in 40 CFR 141.11 to be exceeded in ground water or that causes the existing concentration of nitrate in ground water to increase when the existing concentration of nitrate in the ground water exceeds the maximum contaminant level for nitrate in 40 CFR 141.11.

(d) *Cover* is soil or other material used to cover sewage sludge placed on an active sewage sludge unit.

(e) *Displacement* is the relative movement of any two sides of a fault measured in any direction.

(f) *Fault* is a fracture or zone of fractures in any materials along which strata on one side are displaced with respect to strata on the other side.

(g) *Final cover* is the last layer of soil or other material placed on a sewage sludge unit at closure.

(h) *Holocene time* is the most recent epoch of the Quaternary period, extending from the end of the Pleistocene epoch to the present.

(i) *Leachate collection system* is a system or device installed immediately above a liner that is designed, constructed, maintained, and operated to collect and remove leachate from a sewage sludge unit.

(j) *Liner* is soil or synthetic material that has a hydraulic conductivity of 1×10^{-7} centimeters per second or less.

(k) *Lower explosive limit for methane gas* is the lowest percentage of methane gas in air, by volume, that propagates a flame at 25 degrees Celsius and atmospheric pressure.

(l) *Qualified ground-water scientist* is an individual with a baccalaureate or post-graduate degree in the natural sciences or engineering who has sufficient training and experience in ground-water hydrology and related fields, as may be demonstrated by State registration, professional certification, or completion of accredited university programs, to make sound professional judgments regarding ground-water monitoring, pollutant fate and transport, and corrective action.

(m) *Seismic impact zone* is an area that has a 10 percent or greater probability that the horizontal ground level acceleration of the rock in the area exceeds 0.10 gravity once in 250 years.

(n) *Sewage sludge unit* is land on which only sewage sludge is placed for final disposal. This does not include land on which sewage sludge is either stored or treated. Land does not include waters of the United States, as defined in 40 CFR 122.2.

(o) *Sewage sludge unit boundary* is the outermost perimeter of an active sewage sludge unit.

(p) *Surface disposal site* is an area of land that contains one or more active sewage sludge units.

(q) *Unstable area* is land subject to natural or human-induced forces that may damage the structural components of an active sewage sludge unit. This includes, but is not limited to, land on which the soils are subject to mass movement.

§ 503.22 General requirements.

(a) No person shall place sewage sludge on an active sewage sludge unit unless the requirements in this subpart are met.

(b) An active sewage sludge unit located within 60 meters of a fault that has displacement in Holocene time; located in an unstable area; or located in a wetland, except as provided in a permit issued pursuant to section 402 of the CWA, shall close by March 22, 1994, unless, in the case of an active sewage sludge unit located within 60 meters of a fault that has displacement in Holocene time, otherwise specified by the permitting authority.

(c) The owner/operator of an active sewage sludge unit shall submit a written closure and post closure plan to the permitting authority 180 days prior to the date that the active sewage sludge unit closes. The plan shall describe how the sewage sludge unit will be closed and, at a minimum, shall include:

(1) A discussion of how the leachate collection system will be operated and maintained for three years after the sewage sludge unit closes if the sewage sludge unit has a liner and leachate collection system.

(2) A description of the system used to monitor for methane gas in the air in any structures within the surface disposal site and in the air at the property line of the surface disposal site, as required in § 503.24(j)(2).

(3) A discussion of how public access to the surface disposal site will be restricted for three years after the last sewage sludge unit in the surface disposal site closes.

(d) The owner of a surface disposal site shall provide written notification to the subsequent owner of the site that sewage sludge was placed on the land.

§ 503.23 Pollutant limits (other than domestic septage).

(a) Active sewage sludge unit without a liner and leachate collection system.

(1) Except as provided in § 503.23 (a)(2) and (b), the concentration of each pollutant listed in Table 1 of § 503.23 in sewage sludge placed on an active sewage sludge unit shall not exceed the concentration for the pollutant in Table 1 of § 503.23.

TABLE 1 OF § 503.23.—POLLUTANT CONCENTRATIONS—ACTIVE SEWAGE SLUDGE UNIT WITHOUT A LINER AND LEACHATE COLLECTION

Pollutant	Concentration (milligrams per kilogram ¹)
Arsenic	73
Chromium	600
Nickel	420

¹ Dry weight basis.

(2) Except as provided in § 503.23(b), the concentration of each pollutant listed in Table 1 of

§ 503.24

§ 503.23 in sewage sludge placed on an active sewage sludge unit whose boundary is less than 150 meters from the property line of the surface disposal site shall not exceed the concentration determined using the following procedure.

(i) The actual distance from the active sewage sludge unit boundary to the property line of the surface disposal site shall be determined.

(ii) The concentration of each pollutant listed in Table 2 of § 503.23 in the sewage sludge shall not exceed the concentration in Table 2 of § 503.23 that corresponds to the actual distance in § 503.23(a)(2)(i).

TABLE 2 OF § 503.23.—POLLUTANT CONCENTRATIONS—ACTIVE SEWAGE SLUDGE UNIT WITHOUT A LINER AND LEACHATE COLLECTION SYSTEM THAT HAS A UNIT BOUNDARY TO PROPERTY LINE DISTANCE LESS THAN 150 METERS

Unit boundary to property line Distance (meters)	Pollutant concentration ¹		
	Arsenic (mg/kg)	Chromium (mg/kg)	Nickel (mg/kg)
0 to less than 25	30	200	210
25 to less than 50	34	220	240
50 to less than 75	39	260	270
75 to less than 100	46	300	320
100 to less than 125	53	360	390
125 to less than 150	62	450	420

¹ Dry weight basis.

(b) Active sewage sludge unit without a liner and leachate collection system—site-specific limits.

(1) At the time of permit application, the owner/operator of a surface disposal site may request site-specific pollutant limits in accordance with § 503.23(b)(2) for an active sewage sludge unit without a liner and leachate collection system when the existing values for site parameters specified by the permitting authority are different from the values for those parameters used to develop the pollutant limits in Table 1 of § 503.23 and when the permitting authority determines that site-specific pollutant limits are appropriate for the active sewage sludge unit.

(2) The concentration of each pollutant listed in Table 1 of § 503.23 in sewage sludge placed on an active sewage sludge unit without a liner and leachate collection system shall not exceed either the concentration for the pollutant determined during a site-specific assessment, as specified by the permitting authority, or the existing concentration of the pollutant in the sewage sludge, whichever is lower.

§ 503.24 Management practices.

(a) Sewage sludge shall not be placed on an active sewage sludge unit if it is likely to adversely

affect a threatened or endangered species listed under section 4 of the Endangered Species Act or its designated critical habitat.

(b) An active sewage sludge unit shall not restrict the flow of a base flood.

(c) When a surface disposal site is located in a seismic impact zone, an active sewage sludge unit shall be designed to withstand the maximum recorded horizontal ground level acceleration.

(d) An active sewage sludge unit shall be located 60 meters or more from a fault that has displacement in Holocene time, unless otherwise specified by the permitting authority.

(e) An active sewage sludge unit shall not be located in an unstable area.

(f) An active sewage sludge unit shall not be located in a wetland, except as provided in a permit issued pursuant to section 402 or 404 of the CWA.

(g)(1) Run-off from an active sewage sludge unit shall be collected and shall be disposed in accordance with National Pollutant Discharge Elimination System permit requirements and any other applicable requirements.

(2) The run-off collection system for an active sewage sludge unit shall have the capacity to handle run-off from a 24-hour, 25-year storm event.

(h) The leachate collection system for an active sewage sludge unit that has a liner and leachate collection system shall be operated and maintained during the period the sewage sludge unit is active and for three years after the sewage sludge unit closes.

(i) Leachate from an active sewage sludge unit that has a liner and leachate collection system shall be collected and shall be disposed in accordance with the applicable requirements during the period the sewage sludge unit is active and for three years after the sewage sludge unit closes.

(j)(1) When a cover is placed on an active sewage sludge unit, the concentration of methane gas in air in any structure within the surface disposal site shall not exceed 25 percent of the lower explosive limit for methane gas during the period that the sewage sludge unit is active and the concentration of methane gas in air at the property line of the surface disposal site shall not exceed the lower explosive limit for methane gas during the period that the sewage sludge unit is active.

(2) When a final cover is placed on a sewage sludge unit at closure, the concentration of methane gas in air in any structure within the surface disposal site shall not exceed 25 percent of the lower explosive limit for methane gas for three years after the sewage sludge unit closes and the concentration of methane gas in air at the property line of the surface disposal site shall not exceed the lower explosive limit for methane gas for three years after the sewage sludge unit closes, unless otherwise specified by the permitting authority.

(k) A food crop, a feed crop, or a fiber crop shall not be grown on an active sewage sludge unit, unless the owner/operator of the surface disposal site demonstrates to the permitting authority that through management practices public health and the environment are protected from any reasonably anticipated adverse effects of pollutants in sewage sludge when crops are grown.

(l) Animals shall not be grazed on an active sewage sludge unit, unless the owner/operator of the surface disposal site demonstrates to the permitting authority that through management practices public health and the environment are protected from any reasonably anticipated adverse effects of pollutants in sewage sludge when animals are grazed.

(m) Public access to a surface disposal site shall be restricted for the period that the surface disposal site contains an active sewage sludge unit and for three years after the last active sewage sludge unit in the surface disposal site closes.

(n)(1) Sewage sludge placed on an active sewage sludge unit shall not contaminate an aquifer.

(2) Results of a ground-water monitoring program developed by a qualified ground-water scientist or a certification by a qualified ground-water scientist shall be used to demonstrate that sewage sludge placed on an active sewage sludge unit does not contaminate an aquifer.

§ 503.25 Operational standards—pathogens and vector attraction reduction.

(a) *Pathogens—sewage sludge (other than domestic septage).* The Class A pathogens requirements in § 503.32(a) or one of the Class B pathogen requirements in § 503.32 (b)(2) through (b)(4) shall be met when sewage sludge is placed on an active sewage sludge unit, unless the vector attraction reduction requirement in § 503.33(b)(11) is met.

(b) *Vector attraction reduction—sewage sludge (other than domestic septage).* One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(11) shall be met when sewage sludge is placed on an active sewage sludge unit.

(c) *Vector attraction reduction—domestic septage.* One of the vector attraction reduction requirement in § 503.33 (b)(9) through (b)(12) shall be met when domestic septage is placed on an active sewage sludge unit.

§ 503.26 Frequency of monitoring.

(a) *Sewage sludge (other than domestic septage).* (1) The frequency of monitoring for the pollutants in Tables 1 and 2 of § 503.23; the pathogen density requirements in § 503.32(a) and in § 503.32 (b)(2) through (b)(4); and the vector attraction reduction requirements in § 503.33 (b)(1)

through (b)(8) for sewage sludge placed on an active sewage sludge unit shall be the frequency in Table 1 of § 503.26.

TABLE 1 OF § 503.26.—FREQUENCY OF MONITORING—SURFACE DISPOSAL

Amount of sewage sludge ¹ (metric tons per 365 day period)	Frequency
Greater than zero but less than 290.	Once per year.
Equal to or greater than 290 but less than 1,500.	Once per quarter (four times per year).
Equal to or greater than 1,500 but less than 15,000.	Once per 60 days (six times per year).
Equal to or greater than 15,000.	Once per month (12 times per year).

¹ Amount of sewage sludge placed on an active sewage sludge unit (dry weight basis).

(2) After the sewage sludge has been monitored for two years at the frequency in Table 1 of § 503.26, the permitting authority may reduce the frequency of monitoring for pollutant concentrations and for the pathogen density requirements in § 503.32 (a)(5)(ii) and (a)(5)(iii), but in no case shall the frequency of monitoring be less than once per year when sewage sludge is placed on an active sewage sludge unit.

(b) *Domestic septage.* If the vector attraction reduction requirements in § 503.33(b)(12) are met when domestic septage is placed on an active sewage sludge unit, each container of domestic septage shall be monitored for compliance with those requirements.

(c) *Air.* Air in structures within a surface disposal site and at the property line of the surface disposal site shall be monitored continuously for methane gas during the period that the surface disposal site contains an active sewage sludge unit on which the sewage sludge is covered and for three years after a sewage sludge unit closes when a final cover is placed on the sewage sludge.

(Approved by the Office of Management and Budget under control number 2040-0157)

§ 503.27 Recordkeeping.

(a) When sewage sludge (other than domestic septage) is placed on an active sewage sludge unit:

(1) The person who prepares the sewage sludge shall develop the following information and shall retain the information for five years.

(i) The concentration of each pollutant listed in Table 1 of § 503.23 in the sewage sludge when the pollutant concentrations in Table 1 of § 503.23 are met.

(ii) The following certification statement:

"I certify, under penalty of law, that the pathogen requirements in [insert § 503.32(a), § 503.32(b)(2), § 503.32(b)(3), or § 503.32(b)(4) when one of those re-

§ 503.28

quirements is met] and the vector attraction reduction requirements in [insert one of the vector attraction reduction requirements in § 503.33(b)(1) through § 503.33(b)(8) when one of those requirements is met] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine the [pathogen requirements and vector attraction reduction requirements if appropriate] have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.”

(iii) A description of how the pathogen requirements in § 503.32 (a), (b)(2), (b)(3), or (b)(4) are met when one of those requirements is met.

(iv) A description of how one of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) is met when one of those requirements is met.

(2) The owner/operator of the surface disposal site, shall develop the following information and shall retain that information for five years.

(i) The concentration of each pollutant listed in Table 2 of § 503.23 in the sewage sludge when the pollutant concentrations in Table 2 of § 503.23 are met or when site-specific pollutant limits in § 503.23(b) are met.

(ii) The following certification statement:

“I certify, under penalty of law, that the management practices in § 503.24 and the vector attraction reduction requirement in [insert one of the requirements in § 503.33 (b)(9) through (b)(11) if one of those requirements is met] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices [and the vector attraction reduction requirements if appropriate] have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.”

(iii) A description of how the management practices in § 503.24 are met.

(iv) A description of how the vector attraction reduction requirements in § 503.33 (b)(9) through (b)(11) are met if one of those requirements is met.

(b) When domestic septage is placed on a surface disposal site:

(1) If the vector attraction reduction requirements in § 503.33(b)(12) are met, the person who places the domestic septage on the surface disposal site shall develop the following information and shall retain the information for five years:

(i) The following certification statement:

“I certify, under penalty of law, that the vector attraction reduction requirements in § 503.33(b)(12) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the

vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.”

(ii) A description of how the vector attraction reduction requirements in § 503.33(b)(12) are met.

(2) The owner/operator of the surface disposal site shall develop the following information and shall retain that information for five years:

(i) The following certification statement:

“I certify, under penalty of law, that the management practices in § 503.24 and the vector attraction reduction requirements in [insert § 503.33(b)(9) through § 503.33(b)(11) when one of those requirements is met] have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices [and the vector attraction reduction requirements if appropriate] have been met. I am aware that there are significant penalties for false certification including the possibility of fine or imprisonment.”

(ii) A description of how the management practices in § 503.24 are met.

(iii) A description how the vector attraction reduction requirements in § 503.33(b)(9) through § 503.33(b)(11) are met if one of those requirements is met.

(Approved by the Office of Management and Budget under control number 2040-0157)

§ 503.28 Reporting.

Class I sludge management facilities, POTWs (as defined in 40 CFR 501.2) with a design flow rate equal to or greater than one million gallons per day, and POTWs that serve 10,000 people or more shall submit the information in § 503.27(a) to the permitting authority on February 19 of each year.

(Approved by the Office of Management and Budget under control number 2040-0157)

Subpart D—Pathogens and Vector Attraction Reduction

§ 503.30 Scope.

(a) This subpart contains the requirements for a sewage sludge to be classified either Class A or Class B with respect to pathogens.

(b) This subpart contains the site restrictions for land on which a Class B sewage sludge is applied.

(c) This subpart contains the pathogen requirements for domestic septage applied to agricultural land, forest, or a reclamation site.

(d) This subpart contains alternative vector attraction reduction requirements for sewage sludge that is applied to the land or placed on a surface disposal site.

§ 503.31 Special definitions.

(a) *Aerobic digestion* is the biochemical decomposition of organic matter in sewage sludge into carbon dioxide and water by microorganisms in the presence of air.

(b) *Anaerobic digestion* is the biochemical decomposition of organic matter in sewage sludge into methane gas and carbon dioxide by microorganisms in the absence of air.

(c) *Density of microorganisms* is the number of microorganisms per unit mass of total solids (dry weight) in the sewage sludge.

(d) *Land with a high potential for public exposure* is land that the public uses frequently. This includes, but is not limited to, a public contact site and a reclamation site located in a populated area (e.g., a construction site located in a city).

(e) *Land with a low potential for public exposure* is land that the public uses infrequently. This includes, but is not limited to, agricultural land, forest, and a reclamation site located in an unpopulated area (e.g., a strip mine located in a rural area).

(f) *Pathogenic organisms* are disease-causing organisms. These include, but are not limited to, certain bacteria, protozoa, viruses, and viable helminth ova.

(g) *pH* means the logarithm of the reciprocal of the hydrogen ion concentration.

(h) *Specific oxygen uptake rate (SOUR)* is the mass of oxygen consumed per unit time per unit mass of total solids (dry weight basis) in the sewage sludge.

(i) *Total solids* are the materials in sewage sludge that remain as residue when the sewage sludge is dried at 103 to 105 degrees Celsius.

(j) *Unstabilized solids* are organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

(k) *Vector attraction* is the characteristic of sewage sludge that attracts rodents, flies, mosquitos, or other organisms capable of transporting infectious agents.

(l) *Volatile solids* is the amount of the total solids in sewage sludge lost when the sewage sludge is combusted at 550 degrees Celsius in the presence of excess air.

§ 503.32 Pathogens.

(a) *Sewage sludge—Class A.* (1) The requirement in § 503.32(a)(2) and the requirements in either § 503.32(a)(3), (a)(4), (a)(5), (a)(6), (a)(7), or (a)(8) shall be met for a sewage sludge to be classified Class A with respect to pathogens.

(2) The Class A pathogen requirements in § 503.32 (a)(3) through (a)(8) shall be met either prior to meeting or at the same time the vector attraction reduction requirements in § 503.33, except

the vector attraction reduction requirements in § 503.33 (b)(6) through (b)(8), are met.

(3) *Class A—Alternative 1.* (i) Either the density of fecal coliform in the sewage sludge shall be less than 1000 Most Probable Number per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge shall be less than three Most Probable Number per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or give away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10 (b), (c), (e), or (f).

(ii) The temperature of the sewage sludge that is used or disposed shall be maintained at a specific value for a period of time.

(A) When the percent solids of the sewage sludge is seven percent or higher, the temperature of the sewage sludge shall be 50 degrees Celsius or higher; the time period shall be 20 minutes or longer; and the temperature and time period shall be determined using equation (2), except when small particles of sewage sludge are heated by either warmed gases or an immiscible liquid.

$$D = \frac{131,700,000}{10^{0.1400t}} \quad \text{Eq. (2)}$$

Where,

D=time in days.

t=temperature in degrees Celsius.

(B) When the percent solids of the sewage sludge is seven percent or higher and small particles of sewage sludge are heated by either warmed gases or an immiscible liquid, the temperature of the sewage sludge shall be 50 degrees Celsius or higher; the time period shall be 15 seconds or longer; and the temperature and time period shall be determined using equation (2).

(C) When the percent solids of the sewage sludge is less than seven percent and the time period is at least 15 seconds, but less than 30 minutes, the temperature and time period shall be determined using equation (2).

(D) When the percent solids of the sewage sludge is less than seven percent; the temperature of the sewage sludge is 50 degrees Celsius or higher; and the time period is 30 minutes or longer, the temperature and time period shall be determined using equation (3).

$$D = \frac{50,070,000}{10^{0.1400t}} \quad \text{Eq. (3)}$$

§ 503.32

Where,

D=time in days.

t=temperature in degrees Celsius.

(4) *Class A—Alternative 2.* (i) Either the density of fecal coliform in the sewage sludge shall be less than 1000 Most Probable Number per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge shall be less than three Most Probable Number per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or give away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10 (b), (c), (e), or (f).

(ii)(A) The pH of the sewage sludge that is used or disposed shall be raised to above 12 and shall remain above 12 for 72 hours.

(B) The temperature of the sewage sludge shall be above 52 degrees Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12.

(C) At the end of the 72 hour period during which the pH of the sewage sludge is above 12, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50 percent.

(5) *Class A—Alternative 3.* (i) Either the density of fecal coliform in the sewage sludge shall be less than 1000 Most Probable Number per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in sewage sludge shall be less than three Most Probable Number per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or give away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10 (b), (c), (e), or (f).

(ii)(A) The sewage sludge shall be analyzed prior to pathogen treatment to determine whether the sewage sludge contains enteric viruses.

(B) When the density of enteric viruses in the sewage sludge prior to pathogen treatment is less than one Plaque-forming Unit per four grams of total solids (dry weight basis), the sewage sludge is Class A with respect to enteric viruses until the next monitoring episode for the sewage sludge.

(C) When the density of enteric viruses in the sewage sludge prior to pathogen treatment is equal to or greater than one Plaque-forming Unit per four grams of total solids (dry weight basis), the sewage sludge is Class A with respect to enteric viruses when the density of enteric viruses in the sewage sludge after pathogen treatment is less

than one Plaque-forming Unit per four grams of total solids (dry weight basis) and when the values or ranges of values for the operating parameters for the pathogen treatment process that produces the sewage sludge that meets the enteric virus density requirement are documented.

(D) After the enteric virus reduction in paragraph (a)(5)(ii)(C) of this section is demonstrated for the pathogen treatment process, the sewage sludge continues to be Class A with respect to enteric viruses when the values for the pathogen treatment process operating parameters are consistent with the values or ranges of values documented in paragraph (a)(5)(ii)(C) of this section.

(iii)(A) The sewage sludge shall be analyzed prior to pathogen treatment to determine whether the sewage sludge contains viable helminth ova.

(B) When the density of viable helminth ova in the sewage sludge prior to pathogen treatment is less than one per four grams of total solids (dry weight basis), the sewage sludge is Class A with respect to viable helminth ova until the next monitoring episode for the sewage sludge.

(C) When the density of viable helminth ova in the sewage sludge prior to pathogen treatment is equal to or greater than one per four grams of total solids (dry weight basis), the sewage sludge is Class A with respect to viable helminth ova when the density of viable helminth ova in the sewage sludge after pathogen treatment is less than one per four grams of total solids (dry weight basis) and when the values or ranges of values for the operating parameters for the pathogen treatment process that produces the sewage sludge that meets the viable helminth ova density requirement are documented.

(D) After the viable helminth ova reduction in paragraph (a)(5)(iii)(C) of this section is demonstrated for the pathogen treatment process, the sewage sludge continues to be Class A with respect to viable helminth ova when the values for the pathogen treatment process operating parameters are consistent with the values or ranges of values documented in paragraph (a)(5)(iii)(C) of this section.

(6) *Class A—Alternative 4.* (i) Either the density of fecal coliform in the sewage sludge shall be less than 1000 Most Probable Number per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge shall be less than three Most Probable Number per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or give away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10 (b), (c), (e), or (f).

(ii) The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or give away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10 (b), (c), (e), or (f), unless otherwise specified by the permitting authority.

(iii) The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or give away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10 (b), (c), (e), or (f), unless otherwise specified by the permitting authority.

(7) *Class A—Alternative 5.* (i) Either the density of fecal coliform in the sewage sludge shall be less than 1000 Most Probable Number per gram of total solids (dry weight basis), or the density of *Salmonella*, sp. bacteria in the sewage sludge shall be less than three Most Probable Number per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or given away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10(b), (c), (e), or (f).

(ii) Sewage sludge that is used or disposed shall be treated in one of the Processes to Further Reduce Pathogens described in appendix B of this part.

(8) *Class A—Alternative 6.* (i) Either the density of fecal coliform in the sewage sludge shall be less than 1000 Most Probable Number per gram of total solids (dry weight basis), or the density of *Salmonella*, sp. bacteria in the sewage sludge shall be less than three Most Probable Number per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or given away in a bag or other container for application to the land; or at the time the sewage sludge or material derived from sewage sludge is prepared to meet the requirements in § 503.10(b), (c), (e), or (f).

(ii) Sewage sludge that is used or disposed shall be treated in a process that is equivalent to a Process to Further Reduce Pathogens, as determined by the permitting authority.

(b) *Sewage sludge—Class B.* (1)(i) The requirements in either § 503.32(b)(2), (b)(3), or (b)(4) shall be met for a sewage sludge to be classified Class B with respect to pathogens.

(ii) The site restrictions in § 503.32(b)(5) shall be met when sewage sludge that meets the Class B pathogen requirements in § 503.32(b)(2), (b)(3), or (b)(4) is applied to the land.

(2) *Class B—Alternative 1.* (i) Seven samples of the sewage sludge shall be collected at the time the sewage sludge is used or disposed.

(ii) The geometric mean of the density of fecal coliform in the samples collected in paragraph (b)(2)(i) of this section shall be less than either 2,000,000 Most Probable Number per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

(3) *Class B—Alternative 2.* Sewage sludge that is used or disposed shall be treated in one of the Processes to Significantly Reduce Pathogens described in appendix B of this part.

(4) *Class B—Alternative 3.* Sewage sludge that is used or disposed shall be treated in a process that is equivalent to a Process to Significantly Reduce Pathogens, as determined by the permitting authority.

(5) *Site restrictions.* (i) Food crops with harvested parts that touch the sewage sludge/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of sewage sludge.

(ii) Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of sewage sludge when the sewage sludge remains on the land surface for four months or longer prior to incorporation into the soil.

(iii) Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of sewage sludge when the sewage sludge remains on the land surface for less than four months prior to incorporation into the soil.

(iv) Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of sewage sludge.

(v) Animals shall not be allowed to graze on the land for 30 days after application of sewage sludge.

(vi) Turf grown on land where sewage sludge is applied shall not be harvested for one year after application of the sewage sludge when the harvested turf is placed on either land with a high potential for public exposure or a lawn, unless otherwise specified by the permitting authority.

(vii) Public access to land with a high potential for public exposure shall be restricted for one year after application of sewage sludge.

§ 503.33

(viii) Public access to land with a low potential for public exposure shall be restricted for 30 days after application of sewage sludge.

(c) *Domestic septage.* (1) The site restrictions in § 503.32(b)(5) shall be met when domestic septage is applied to agricultural land, forest, or a reclamation site; or

(2) The pH of domestic septage applied to agricultural land, forest, or a reclamation site shall be raised to 12 or higher by alkali addition and, without the addition of more alkali, shall remain at 12 or higher for 30 minutes and the site restrictions in § 503.32 (b)(5)(i) through (b)(5)(iv) shall be met.

§ 503.33 Vector attraction reduction.

(a)(1) One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(10) shall be met when bulk sewage sludge is applied to agricultural land, forest, a public contact site, or a reclamation site.

(2) One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) shall be met when bulk sewage sludge is applied to a lawn or a home garden.

(3) One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(8) shall be met when sewage sludge is sold or given away in a bag or other container for application to the land.

(4) One of the vector attraction reduction requirements in § 503.33 (b)(1) through (b)(11) shall be met when sewage sludge (other than domestic septage) is placed on an active sewage sludge unit.

(5) One of the vector attraction reduction requirements in § 503.33 (b)(9), (b)(10), or (b)(12) shall be met when domestic septage is applied to agricultural land, forest, or a reclamation site and one of the vector attraction reduction requirements in § 503.33 (b)(9) through (b)(12) shall be met when domestic septage is placed on an active sewage sludge unit.

(b)(1) The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38 percent (see calculation procedures in "Environmental Regulations and Technology—Control of Pathogens and Vector Attraction in Sewage Sludge", EPA-625/R-92/013, 1992, U.S. Environmental Protection Agency, Cincinnati, Ohio 45268).

(2) When the 38 percent volatile solids reduction requirement in § 503.33(b)(1) cannot be met for an anaerobically digested sewage sludge, vector attraction reduction can be demonstrated by digesting a portion of the previously digested sewage sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30 and 37 degrees Celsius. When at the end of the 40 days, the volatile solids in the

sewage sludge at the beginning of that period is reduced by less than 17 percent, vector attraction reduction is achieved.

(3) When the 38 percent volatile solids reduction requirement in § 503.33(b)(1) cannot be met for an aerobically digested sewage sludge, vector attraction reduction can be demonstrated by digesting a portion of the previously digested sewage sludge that has a percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20 degrees Celsius. When at the end of the 30 days, the volatile solids in the sewage sludge at the beginning of that period is reduced by less than 15 percent, vector attraction reduction is achieved.

(4) The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20 degrees Celsius.

(5) Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40 degrees Celsius and the average temperature of the sewage sludge shall be higher than 45 degrees Celsius.

(6) The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali, shall remain at 12 or higher for two hours and then at 11.5 or higher for an additional 22 hours.

(7) The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75 percent based on the moisture content and total solids prior to mixing with other materials.

(8) The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90 percent based on the moisture content and total solids prior to mixing with other materials.

(9)(i) Sewage sludge shall be injected below the surface of the land.

(ii) No significant amount of the sewage sludge shall be present on the land surface within one hour after the sewage sludge is injected.

(iii) When the sewage sludge that is injected below the surface of the land is Class A with respect to pathogens, the sewage sludge shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.

(10)(i) Sewage sludge applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.

(ii) When sewage sludge that is incorporated into the soil is Class A with respect to pathogens, the sewage sludge shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

(11) Sewage sludge placed on an active sewage sludge unit shall be covered with soil or other material at the end of each operating day.

(12) The pH of domestic septage shall be raised to 12 or higher by alkali addition and, without the addition of more alkali, shall remain at 12 or higher for 30 minutes.

Subpart E—Incineration

§ 503.40 Applicability.

(a) This subpart applies to a person who fires sewage sludge in a sewage sludge incinerator, to a sewage sludge incinerator, and to sewage sludge fired in a sewage sludge incinerator.

(b) This subpart applies to the exit gas from a sewage sludge incinerator stack.

(c) The management practice in § 503.45(a), the frequency of monitoring requirement for total hydrocarbon concentration in § 503.46(b) and the recordkeeping requirements for total hydrocarbon concentration in § 503.47(c) and (n) do not apply if the following conditions are met:

(1) The exit gas from a sewage sludge incinerator stack is monitored continuously for carbon monoxide.

(2) The monthly average concentration of carbon monoxide in the exit gas from a sewage sludge incinerator stack, corrected for zero percent moisture and to seven percent oxygen, does not exceed 100 parts per million on a volumetric basis.

(3) The person who fires sewage sludge in a sewage sludge incinerator retains the following information for five years:

(i) The carbon monoxide concentrations in the exit gas; and

(ii) A calibration and maintenance log for the instrument used to measure the carbon monoxide concentration.

(4) Class I sludge management facilities, POTWs (as defined in 40 CFR 501.2) with a design flow rate equal to or greater than one million gallons per day, and POTWs that serve a population of 10,000 people or greater submit the monthly average carbon monoxide concentrations in the exit gas to the permitting authority on February 19 of each year.

[58 FR 9387, Feb. 19, 1993, as amended at 59 FR 9099, Feb. 25, 1994]

§ 503.41 Special definitions.

(a) *Air pollution control device* is one or more processes used to treat the exit gas from a sewage sludge incinerator stack.

(b) *Auxiliary fuel* is fuel used to augment the fuel value of sewage sludge. This includes, but is not limited to, natural gas, fuel oil, coal, gas generated during anaerobic digestion of sewage sludge, and municipal solid waste (not to exceed 30 percent of the dry weight of sewage sludge and auxiliary fuel together). Hazardous wastes are not auxiliary fuel.

(c) *Control efficiency* is the mass of a pollutant in the sewage sludge fed to an incinerator minus the mass of that pollutant in the exit gas from the incinerator stack divided by the mass of the pollutant in the sewage sludge fed to the incinerator.

(d) *Dispersion factor* is the ratio of the increase in the ground level ambient air concentration for a pollutant at or beyond the property line of the site where the sewage sludge incinerator is located to the mass emission rate for the pollutant from the incinerator stack.

(e) *Fluidized bed incinerator* is an enclosed device in which organic matter and inorganic matter in sewage sludge are combusted in a bed of particles suspended in the combustion chamber gas.

(f) *Hourly average* is the arithmetic mean of all measurements, taken during an hour. At least two measurements must be taken during the hour.

(g) *Incineration* is the combustion of organic matter and inorganic matter in sewage sludge by high temperatures in an enclosed device.

(h) *Monthly average* is the arithmetic mean of the hourly averages for the hours a sewage sludge incinerator operates during the month.

(i) *Risk specific concentration* is the allowable increase in the average daily ground level ambient air concentration for a pollutant from the incineration of sewage sludge at or beyond the property line of the site where the sewage sludge incinerator is located.

(j) *Sewage sludge feed rate* is either the average daily amount of sewage sludge fired in all sewage sludge incinerators within the property line of the site where the sewage sludge incinerators are located for the number of days in a 365 day period that each sewage sludge incinerator operates, or the average daily design capacity for all sewage sludge incinerators within the property line of the site where the sewage sludge incinerators are located.

(k) *Sewage sludge incinerator* is an enclosed device in which only sewage sludge and auxiliary fuel are fired.

(l) *Stack height* is the difference between the elevation of the top of a sewage sludge incinerator stack and the elevation of the ground at the base of the stack when the difference is equal to or less

than 65 meters. When the difference is greater than 65 meters, stack height is the creditable stack height determined in accordance with 40 CFR 51.100 (ii).

(m) *Total hydrocarbons* means the organic compounds in the exit gas from a sewage sludge incinerator stack measured using a flame ionization detection instrument referenced to propane.

(n) *Wet electrostatic precipitator* is an air pollution control device that uses both electrical forces and water to remove pollutants in the exit gas from a sewage sludge incinerator stack.

(o) *Wet scrubber* is an air pollution control device that uses water to remove pollutants in the exit gas from a sewage sludge incinerator stack.

§ 503.42 General requirements.

No person shall fire sewage sludge in a sewage sludge incinerator except in compliance with the requirements in this subpart.

§ 503.43 Pollutant limits.

(a) Firing of sewage sludge in a sewage sludge incinerator shall not violate the requirements in the National Emission Standard for Beryllium in subpart C of 40 CFR part 61.

(b) Firing of sewage sludge in a sewage sludge incinerator shall not violate the requirements in the National Emission Standard for Mercury in subpart E of 40 CFR part 61.

(c) *Pollutant limit—lead.* (1) The daily concentration of lead in sewage sludge fed to a sewage sludge incinerator shall not exceed the concentration calculated using Equation (4).

$$C = \frac{0.1 \times \text{NAAQS} \times 86,400}{\text{DF} \times (1 - \text{CE}) \times \text{SF}} \quad \text{Eq. (4)}$$

Where:

C=Daily concentration of lead in sewage sludge in milligrams per kilogram of total solids (dry weight basis).

NAAQS=National Ambient Air Quality Standard for lead in micrograms per cubic meter.

DF=Dispersion factor in micrograms per cubic meter per gram per second.

CE=Sewage sludge incinerator control efficiency for lead in hundredths.

SF=Sewage sludge feed rate in metric tons per day (dry weight basis).

(2)(i) When the sewage sludge stack height is 65 meters or less, the actual sewage sludge incinerator stack height shall be used in an air dispersion model specified by the permitting authority to

determine the dispersion factor (DF) in equation (4).

(ii) When the sewage sludge incinerator stack height exceeds 65 meters, the creditable stack height shall be determined in accordance with 40 CFR 51.100(ii) and the creditable stack height shall be used in an air dispersion model specified by the permitting authority to determine the dispersion factor (DF) in equation (4).

(3) The control efficiency (CE) in equation (5) shall be determined from a performance test of the sewage sludge incinerator, as specified by the permitting authority.

(d) *Pollutant limit—arsenic, cadmium, chromium, and nickel.* (1) The daily concentration for arsenic, cadmium, chromium, and nickel in sewage sludge fed to a sewage sludge incinerator each shall not exceed the concentration calculated using equation (5).

$$C = \frac{\text{RSC} \times 86,400}{\text{DF} \times (1 - \text{CE}) \times \text{SF}} \quad \text{Eq. (5)}$$

Where:

C=Daily concentration of arsenic, cadmium, chromium, or nickel in sewage sludge in milligrams per kilogram of total solids (dry weight basis).

CE=Sewage sludge incinerator control efficiency for arsenic, cadmium, chromium, or nickel in hundredths.

DF=Dispersion factor in micrograms per cubic meter per gram per second.

RSC=Risk specific concentration in micrograms per cubic meter. S

F=Sewage sludge feed rate in metric tons per day (dry weight basis).

(2) The risk specific concentrations for arsenic, cadmium, and nickel used in equation (6) shall be obtained from Table 1 of § 503.43.

TABLE 1 OF § 503.43.—RISK SPECIFIC CONCENTRATION ARSENIC, CADMIUM, AND NICKEL

Pollutant	Risk specific concentration (micrograms per cubic meter)
Arsenic	0.023
Cadmium	0.057
Nickel	2.0

(3) The risk specific concentration for chromium used in equation (5) shall be obtained from Table 2 of § 503.43 or shall be calculated using equation (6), as specified by the permitting authority.

TABLE 2 OF § 503.43.—RISK SPECIFIC CONCENTRATION—CHROMIUM

Type of incinerator	Risk specific concentration (micrograms per cubic meter)
Fluidized bed with wet scrubber	0.65
Fluidized bed with wet scrubber and wet electrostatic precipitator	0.23
Other types with wet scrubber	0.064
Other types with wet scrubber and wet electrostatic precipitator	0.016

$$RSC = \frac{0.0085}{r} \quad \text{Eq. (6)}$$

Where:

RSC=risk specific concentration for chromium in micrograms per cubic meter used in equation (5).

r=decimal fraction of the hexavalent chromium concentration in the total chromium concentration measured in the exit gas from the sewage sludge incinerator stack in hundredths.

(4)(i) When the sewage sludge incinerator stack height is equal to or less than 65 meters, the actual sewage sludge incinerator stack height shall be used in an air dispersion model, as specified by the permitting authority, to determine the dispersion factor (DF) in equation (5).

(ii) When the sewage sludge incinerator stack height is greater than 65 meters, the creditable stack height shall be determined in accordance with 40 CFR 51.100(ii) and the creditable stack height shall be used in an air dispersion model, as specified by the permitting authority, to determine the dispersion factor (DF) in equation (5).

(5) The control efficiency (CE) in equation (5) shall be determined from a performance test of the sewage sludge incinerator, as specified by the permitting authority.

§ 503.44 Operational standard—total hydrocarbons.

(a) The total hydrocarbons concentration in the exit gas from a sewage sludge incinerator shall be corrected for zero percent moisture by multiplying the measured total hydrocarbons concentration by the correction factor calculated using equation (7).

$$\text{Correction factor (percent moisture)} = \frac{1}{(1-X)} \quad \text{Eq. (7)}$$

Where:

X=decimal fraction of the percent moisture in the sewage sludge incinerator exit gas in hundredths.

(b) The total hydrocarbons concentration in the exit gas from a sewage sludge incinerator shall be

corrected to seven percent oxygen by multiplying the measured total hydrocarbons concentration by the correction factor calculated using equation (8).

$$\text{Correction factor (oxygen)} = \frac{14}{(21-Y)} \quad \text{Eq. (8)}$$

Where:

Y=Percent oxygen concentration in the sewage sludge incinerator stack exit gas (dry volume/dry volume).

(c) The monthly average concentration for total hydrocarbons in the exit gas from a sewage sludge incinerator stack, corrected for zero percent moisture using the correction factor from equation (7) and to seven percent oxygen using the correction factor from equation (8), shall not exceed 100 parts per million on a volumetric basis when measured using the instrument required by § 503.45(a).

§ 503.45 Management practices.

(a)(1) An instrument that measures and records the total hydrocarbons concentration in the sewage sludge incinerator stack exit gas continuously shall be installed, calibrated, operated, and maintained for each sewage sludge incinerator, as specified by the permitting authority.

(2) The total hydrocarbons instrument shall employ a flame ionization detector; shall have a heated sampling line maintained at a temperature of 150 degrees Celsius or higher at all times; and shall be calibrated at least once every 24-hour operating period using propane.

(b) An instrument that measures and records the oxygen concentration in the sewage sludge incinerator stack exit gas continuously shall be installed, calibrated, operated, and maintained for each sewage sludge incinerator, as specified by the permitting authority.

(c) An instrument that measures and records information used to determine the moisture content in the sewage sludge incinerator stack exit gas continuously shall be installed, calibrated, operated, and maintained for each sewage sludge incinerator, as specified by the permitting authority.

(d) An instrument that measures and records combustion temperatures continuously shall be installed, calibrated, operated, and maintained for each sewage sludge incinerator, as specified by the permitting authority.

(e) The maximum combustion temperature for a sewage sludge incinerator shall be specified by the permitting authority and shall be based on information obtained during the performance test of the sewage sludge incinerator to determine pollutant control efficiencies.

(f) The values for the operating parameters for the sewage sludge incinerator air pollution control

§ 503.46

device shall be specified by the permitting authority and shall be based on information obtained during the performance test of the sewage sludge incinerator to determine pollutant control efficiencies.

(g) Sewage sludge shall not be fired in a sewage sludge incinerator if it is likely to adversely affect a threatened or endangered species listed under section 4 of the Endangered Species Act or its designated critical habitat.

§ 503.46 Frequency of monitoring.

(a) *Sewage sludge.* (1) The frequency of monitoring for beryllium and mercury shall be specified by the permitting authority.

(2) The frequency of monitoring for arsenic, cadmium, chromium, lead, and nickel in sewage sludge fed to a sewage sludge incinerator shall be the frequency in Table 1 of § 503.46.

TABLE 1 OF § 503.46.—FREQUENCY OF MONITORING—INCINERATION

Amount of sewage sludge ¹ (metric tons per 365 day period)	Frequency
Greater than zero but less than 290	Once per year.
Equal to or greater than 290 but less than 1,500.	Once per quarter (four times per year).
Equal to or greater than 1,500 but less than 15,000.	Once per 60 days (six times per year).
Equal to or greater than 15,000	Once per month (12 times per year).

¹Amount of sewage sludge fired in a sewage sludge incinerator (dry weight basis).

(3) After the sewage sludge has been monitored for two years at the frequency in Table 1 of § 503.46, the permitting authority may reduce the frequency of monitoring for arsenic, cadmium, chromium, lead, and nickel, but in no case shall the frequency of monitoring be less than once per year when sewage sludge is fired in a sewage sludge incinerator.

(b) *Total hydrocarbons, oxygen concentration, information to determine moisture content, and combustion temperatures.* The total hydrocarbons concentration and oxygen concentration in the exit gas from a sewage sludge incinerator stack, the information used to measure moisture content in the exit gas, and the combustion temperatures for the sewage sludge incinerator shall be monitored continuously.

(c) *Air pollution control device operating parameters.* The frequency of monitoring for the sewage sludge incinerator air pollution control de-

vice operating parameters shall be specified by the permitting authority.

(Approved by the Office of Management and Budget under control number 2040-0157)

§ 503.47 Recordkeeping.

(a) The person who fires sewage sludge in a sewage sludge incinerator shall develop the information in § 503.47(b) through § 503.47(n) and shall retain that information for five years.

(b) The concentration of lead, arsenic, cadmium, chromium, and nickel in the sewage sludge fed to the sewage sludge incinerator.

(c) The total hydrocarbons concentrations in the exit gas from the sewage sludge incinerator stack.

(d) Information that indicates the requirements in the National Emission Standard for beryllium in subpart C of 40 CFR part 61 are met.

(e) Information that indicates the requirements in the National Emission Standard for mercury in subpart E of 40 CFR part 61 are met.

(f) The combustion temperatures, including the maximum combustion temperature, for the sewage sludge incinerator.

(g) Values for the air pollution control device operating parameters.

(h) The oxygen concentration and information used to measure moisture content in the exit gas from the sewage sludge incinerator stack.

(i) The sewage sludge feed rate.

(j) The stack height for the sewage sludge incinerator.

(k) The dispersion factor for the site where the sewage sludge incinerator is located.

(l) The control efficiency for lead, arsenic, cadmium, chromium, and nickel for each sewage sludge incinerator.

(m) The risk specific concentration for chromium calculated using equation (6), if applicable.

(n) A calibration and maintenance log for the instruments used to measure the total hydrocarbons concentration and oxygen concentration in the exit gas from the sewage sludge incinerator stack, the information needed to determine moisture content in the exit gas, and the combustion temperatures.

(Approved by the Office of Management and Budget under control number 2040-0157)

§ 503.48 Reporting.

Class I sludge management facilities, POTWs (as defined in 40 CFR 501.2) with a design flow rate equal to or greater than one million gallons per day, and POTWs that serve a population of 10,000 people or greater shall submit the informa-

tion in § 503.47(b) through § 503.47(h) to the permitting authority on February 19 of each year.

(Approved by the Office of Management and Budget under control number 2040-0157)

APPENDIX A TO PART 503—PROCEDURE TO DETERMINE THE ANNUAL WHOLE SLUDGE APPLICATION RATE FOR A SEWAGE SLUDGE

Section 503.13(a)(4)(ii) requires that the product of the concentration for each pollutant listed in Table 4 of § 503.13 in sewage sludge sold or given away in a bag or other container for application to the land and the annual whole sludge application rate (AWSAR) for the sewage sludge not cause the annual pollutant loading rate for the pollutant in Table 4 of § 503.13 to be exceeded. This appendix contains the procedure used to determine the AWSAR for a sewage sludge that does not cause the annual pollutant loading rates in Table 4 of § 503.13 to be exceeded.

The relationship between the annual pollutant loading rate (APLR) for a pollutant and the annual whole sludge application rate (AWSAR) for 1a sewage sludge is shown in equation (1).

$$APLR=C \times AWSAR \times 0.001 \quad (1)$$

Where:

APLR=Annual pollutant loading rate in kilograms per hectare per 365 day period.

C=Pollutant concentration in milligrams, per kilogram of total solids (dry weight basis).

AWSAR=Annual whole sludge application rate in metric tons per hectare per 365 day period (dry weight basis).

0.001=A conversion factor.

To determine the AWSAR, equation (1) is rearranged into equation (2):

$$AWSAR=\frac{APLR}{C \times 0.001} \quad (2)$$

The procedure used to determine the AWSAR for a sewage sludge is presented below.

Procedure:

1. Analyze a sample of the sewage sludge to determine the concentration for each of the pollutants listed in Table 4 of § 503.13 in the sewage sludge.

2. Using the pollutant concentrations from Step 1 and the APLRs from Table 4 of § 503.13, calculate an AWSAR for each pollutant using equation (2) above.

3. The AWSAR for the sewage sludge is the lowest AWSAR calculated in Step 2.

APPENDIX B TO PART 503—PATHOGEN TREATMENT PROCESSES

A. Processes to Significantly Reduce Pathogens (PSRP)

1. Aerobic digestion—Sewage sludge is agitated with air or oxygen to maintain aerobic conditions for a specific

mean cell residence time at a specific temperature. Values for the mean cell residence time and temperature shall be between 40 days at 20 degrees Celsius and 60 days at 15 degrees Celsius.

2. Air drying—Sewage sludge is dried on sand beds or on paved or unpaved basins. The sewage sludge dries for a minimum of three months. During two of the three months, the ambient average daily temperature is above zero degrees Celsius.

3. Anaerobic digestion—Sewage sludge is treated in the absence of air for a specific mean cell residence time at a specific temperature. Values for the mean cell residence time and temperature shall be between 15 days at 35 to 55 degrees Celsius and 60 days at 20 degrees Celsius.

4. Composting—Using either the within-vessel, static aerated pile, or windrow composting methods, the temperature of the sewage sludge is raised to 40 degrees Celsius or higher and remains at 40 degrees Celsius or higher for five days. For four hours during the five days, the temperature in the compost pile exceeds 55 degrees Celsius.

5. Lime stabilization—Sufficient lime is added to the sewage sludge to raise the pH of the sewage sludge to 12 after two hours of contact.

B. Processes to Further Reduce Pathogens (PFRP)

1. Composting—Using either the within-vessel composting method or the static aerated pile composting method, the temperature of the sewage sludge is maintained at 55 degrees Celsius or higher for three days.

Using the windrow composting method, the temperature of the sewage sludge is maintained at 55 degrees or higher for 15 days or longer. During the period when the compost is maintained at 55 degrees or higher, there shall be a minimum of five turnings of the windrow.

2. Heat drying—Sewage sludge is dried by direct or indirect contact with hot gases to reduce the moisture content of the sewage sludge to 10 percent or lower. Either the temperature of the sewage sludge particles exceeds 80 degrees Celsius or the wet bulb temperature of the gas in contact with the sewage sludge as the sewage sludge leaves the dryer exceeds 80 degrees Celsius.

3. Heat treatment—Liquid sewage sludge is heated to a temperature of 180 degrees Celsius or higher for 30 minutes.

4. Thermophilic aerobic digestion—Liquid sewage sludge is agitated with air or oxygen to maintain aerobic conditions and the mean cell residence time of the sewage sludge is 10 days at 55 to 60 degrees Celsius.

5. Beta ray irradiation—Sewage sludge is irradiated with beta rays from an accelerator at dosages of at least 1.0 megarad at room temperature (ca. 20 degrees Celsius).

6. Gamma ray irradiation—Sewage sludge is irradiated with gamma rays from certain isotopes, such as Cobalt 60 and Cesium 137, at room temperature (ca. 20 degrees Celsius).

7. Pasteurization—The temperature of the sewage sludge is maintained at 70 degrees Celsius or higher for 30 minutes or longer.