



Felton Ernest, Brandolyn <brandolyn.feltonernest@wv.gov>

Re: Public Comment and Update to 87 CSR 01 with 2.2.a.1 and Section 16 Agricultural Exemption

1 message

Tyree, Kenneth E <kenneth.e.tyree@wv.gov>
To: "Felton Ernest, Brandolyn" <brandolyn.feltonernest@wv.gov>

Tue, Apr 15, 2025 at 10:43 AM

The following language I would like to submit as an addendum to what I previously had submitted during the earlier public comment period:

2.2.a. Sprinkler Protection and Area Limitations.

2.2.a.1. Approved automatic sprinkler systems in accordance with the applicable NFPA Standard for Sprinkler Systems will be installed in all new buildings used for any occupancy except for Industrial occupancies without special or high hazard use or structures with the exception of Industrial occupancies except those classified as a high hazard occupancy except those classified as a high hazard occupancy. Storage occupancies shall also be included in the exemption with the exception of buildings containing high-piled storage, bulk storage of tires, and mini-storage buildings as identified in NFPA 1, Section 13.3.2.26. This exemption shall include an exemption from the height and area requirements found in Section 2.2.a. of this rule as previously described; others exceeding the area limitations noted in the chart at the end of this subsection, or as required by occupancy chapters of the applicable NFPA codes and other NFPA codes, where no conflicts in the language exist. Sprinkler protection for occupancies covered by section 2 of this rule are required to provide sprinkler protection regardless of area limitations. See Table 2.2.a. below.

Please note: I've added exemptions to Storage Occupancies with the exception of high-piled storage, bulk storage of tires, and mini-storage buildings which are a unique potential high hazard. Please place the entirety of this email as a part of the public comment.

Also, I believe this will clear up a misunderstanding concerning Agricultural exemption and particularly the process for obtaining the exemption. We made need to reach our to Agriculture's General Counsel, Lora Walker to make her aware of my following suggestion (adding Section 16.3):

§87-1-16. Exemption for agricultural purposes.


16.1. If a property owner or other responsible party claims exemption from the State Fire Code based on the agricultural purposes exemption identified in subsection 1.6. of this rule, it would be based upon W. Va. Code §15A-11-3, that "buildings or structures utilized primarily for agricultural purposes shall be exempt from the provisions of the State Building Code, the State Fire Code, and any county or municipal building code or ordinance that is or may be adopted".

16.2. The term "agricultural purposes" means the raising, cultivation, drying, harvesting, marketing, production, or storage of agricultural products, including both crops and livestock, for sale or use in agriculture or agricultural production, or the storage of machinery or equipment used in support of agricultural production.

16.3. To obtain approval consideration for this exemption; a formal request will be made directly to the WV Department of Agriculture. If approved, the exemption shall be provided to this agency from the submitter or the Department of Agriculture.

Respectfully,

Kenneth E. Tyree Jr., CFPS
State Fire Marshal
State DHS Liaison with Faith Community
 West Virginia State Fire Marshal's Office
 1700 MacCorkle Ave SE, 4th Floor North
 Charleston WV 25314
 304.558.2191, Ext 20740
 304.558.2537 (fax)
 kenneth.e.tyree@wv.gov (Email)
www.firemarshal.wv.gov (web)



Challenges build character; anyone can hold the helm when the sea is calm.

CONFIDENTIALITY NOTE: This e-mail message is for the sole use of the intended recipient(s) and may contain sensitive West Virginia State Fire Commission information, and/or confidential, privileged or law enforcement sensitive information. Do not forward this e-mail to another person without the approval of the original sender. Any unauthorized review, use, disclosure or distribution is strictly prohibited and may be subject to criminal penalty. If you are not the intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message.

On Mon, Mar 17, 2025 at 1:44 PM Tyree, Kenneth E <kenneth.e.tyree@wv.gov> wrote:
 If you look at yours you repeated the line twice; I've corrected it in what's attached and added language to clarify where no conflicting language exist within NFPA codes that may co-exist (i.e. NFPA 1 and NFPA 101) may have some conflicting language.

Kenneth E. Tyree Jr., CFPS
State Fire Marshal
State DHS Liaison with Faith Community
 West Virginia State Fire Marshal's Office
 1700 MacCorkle Ave SE, 4th Floor North
 Charleston WV 25314
 304.558.2191, Ext 20740
 304.558.2537 (fax)
 kenneth.e.tyree@wv.gov (Email)
www.firemarshal.wv.gov (web)



Challenges build character; anyone can hold the helm when the sea is calm.

CONFIDENTIALITY NOTE: This e-mail message is for the sole use of the intended recipient(s) and may contain sensitive West Virginia State Fire Commission information, and/or confidential, privileged or law enforcement sensitive information. Do not forward this e-mail to another person without the approval of the original sender. Any unauthorized review, use, disclosure or distribution is strictly prohibited and may be subject to criminal penalty. If you are not the intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message.

On Mon, Mar 17, 2025 at 1:17 PM Felton Ernest, Brandolyn <brandolyn.feltonernest@wv.gov> wrote:
 Sir,
 I have saved your email and memorandum as a "public comment" on the Fire Code, during the public comment period.
 I have reworked section 2.2.a.1. consistent with the language in the memorandum.
 Please review what I have highlighted in yellow and let me know what you think.
 Thanks.

--

Brandolyn N. Felton-Ernest, Esq.

Deputy General Counsel

Department of Homeland Security

Office of the Cabinet Secretary

1900 Kanawha Blvd., East

Building 1, Suite 400-W

Charleston, WV 25305

Office Phone – (304) 558-2930

Direct Dial - (304) 205-6834

Mobile Phone – (304) 553-2698

Fax - (304) 558-6221

CONFIDENTIAL: ATTORNEY - CLIENT PRIVILEGED COMMUNICATION

The information contained in this electronic message is legally privileged and confidential under applicable law and is intended for the use of the individual/s or entity named above. If the recipient of this message is not the above-named recipient, you are hereby notified that any dissemination, copy or disclosure of this communication is strictly prohibited. If you have received this communication in error, please notify the sender at 304.558.2930.