



WEST VIRGINIA SECRETARY OF STATE
KRIS WARNER
ADMINISTRATIVE LAW DIVISION

eFILED
7/29/2026 10:22:04 AM
Office of West Virginia
Secretary Of State

**NOTICE OF AGENCY APPROVAL OF A PROPOSED RULE AND FILING WITH THE LEGISLATIVE RULE-
MAKING REVIEW COMMITTEE**

AGENCY: Health TITLE-SERIES: 64-15
RULE TYPE: Legislative Amendment to Existing Rule: Yes Repeal of existing rule: No
RULE NAME: 64-15 Cross-Connection Control and Backflow Prevention

PRIMARY CONTACT

NAME: Virginia M Payne
ADDRESS: 321 Capitol Street
Charleston, WV 25301
EMAIL: virginia.m.payne@wv.gov
PHONE NUMBER: 304-389-9183

CITE STATUTORY AUTHORITY: W. Va. Code §16-1-4

EXPLANATION OF THE STATUTORY AUTHORITY FOR THE LEGISLATIVE RULE, INCLUDING A DETAILED SUMMARY OF THE EFFECT OF EACH PROVISION OF THE LEGISLATIVE RULE WITH CITATION TO THE SPECIFIC STATUTORY PROVISION WHICH EMPOWERS THE AGENCY TO ENACT SUCH RULE PROVISION:

W. Va. Code §16-1-4 and §16-1-9a

IS THIS FILING SOLELY FOR THE SUNSET PROVISION REQUIREMENTS IN W. VA. CODE §29A-3-19(e)? No

IF YES, DO YOU CERTIFY THAT THE ONLY CHANGES TO THE RULE ARE THE FILING DATE, EFFECTIVE DATE AND AN EXTENSION OF THE SUNSET DATE? No

DATE eFiled FOR NOTICE OF HEARING OR PUBLIC COMMENT PERIOD: 6/25/2026

DATE OF PUBLIC HEARING(S) OR PUBLIC COMMENT PERIOD ENDED: 7/25/2026

COMMENTS RECEIVED: No

(IF YES, PLEASE UPLOAD IN THE COMMENTS RECEIVED FIELD COMMENTS RECEIVED AND RESPONSES TO COMMENTS)

PUBLIC HEARING: No

(IF YES, PLEASE UPLOAD IN THE PUBLIC HEARING FIELD PERSONS WHO APPEARED AT THE HEARING(S) AND TRANSCRIPTS)

RELEVANT FEDERAL STATUTES OR REGULATIONS: No

WHAT OTHER NOTICE, INCLUDING ADVERTISING, DID YOU GIVE OF THE HEARING?

N/A

SUMMARY OF THE CONTENT OF THE LEGISLATIVE RULE, AND A DETAILED DESCRIPTION OF THE RULE'S PURPOSE AND ALL PROPOSED CHANGES TO THE RULE:

This legislative rule governs cross-connection control and backflow prevention for public water systems. Amendments to the rule include technical cleanup and updated requirements for backflow prevention devices installed in low-hazard systems.

STATEMENT OF CIRCUMSTANCES WHICH REQUIRE THE RULE:

Changes made during the 2026 legislative session require amendment of the rule.

SUMMARIZE IN A CLEAR AND CONCISE MANNER THE OVERALL ECONOMIC IMPACT OF THE PROPOSED LEGISLATIVE RULE:

A. ECONOMIC IMPACT ON REVENUES OF STATE GOVERNMENT:

None

B. ECONOMIC IMPACT ON SPECIAL REVENUE ACCOUNTS:

None

C. ECONOMIC IMPACT OF THE LEGISLATIVE RULE ON THE STATE OR ITS RESIDENTS:

None

D. FISCAL NOTE DETAIL:

Effect of Proposal	Fiscal Year		
	2026 Increase/Decrease (use "-")	2027 Increase/Decrease (use "-")	Fiscal Year (Upon Full Implementation)
1. Estimated Total Cost	0	0	0
Personal Services	0	0	0
Current Expenses	0	0	0
Repairs and Alterations	0	0	0
Assets	0	0	0
Other	0	0	0
2. Estimated Total Revenues	0	0	0

E. EXPLANATION OF ABOVE ESTIMATES (INCLUDING LONG-RANGE EFFECT):

N/A

BY CHOOSING 'YES', I ATTEST THAT THE PREVIOUS STATEMENT IS TRUE AND CORRECT.

Yes

Virginia M Payne -- By my signature, I certify that I am the person authorized to file legislative rules, in accordance with West Virginia Code §29A-3-11 and §39A-3-2.

**TITLE 64
LEGISLATIVE RULE
DEPARTMENT OF HEALTH
BUREAU FOR PUBLIC HEALTH**

**SERIES 15
CROSS-CONNECTION CONTROL AND BACKFLOW PREVENTION**

§64-15-1. General.

1.1. Scope. -- This legislative rule governs cross-connection control and backflow prevention for public water systems. This rule should be read in conjunction with W. Va. Code §16-1-9, §16-1-9a, §16-1-17, and §16-1-18.

1.2. Authority. -- W. Va. Code §16-1-4 and §16-1-9a.

1.3. Filing Date. -- ~~March 27, 2024.~~

1.4. Effective Date. -- ~~March 27, 2024.~~

1.5. Sunset Provision. -- This rule shall terminate and have no further force or effect on August 1, ~~2029~~ 2032.

§64-15-2. Application and Enforcement.

2.1. Application. -- This legislative rule applies to any owner, operator, or customer of a public water system.

2.2. Enforcement. -- This rule is enforced by the ~~Commissioner of the Bureau for Public Health~~ Secretary of the Department of Health, or his or her designee.

§64-15-3. Definitions.

All terms contained in this rule shall have the same meaning as set forth in W. Va. Code §16-1-2. This section sets forth definitions for terms that are not otherwise defined, but that appear through this rule

3.1. Air Gap Separation. -- A physical separation between the free-flowing discharge end of a water supply pipe and the flood level rim of a vessel open to the atmosphere having a minimum unobstructed vertical distance between the supply pipe equal to twice its inside diameter or one inch, whichever is greater.

3.2. Approved. -- Accepted by the ~~Commissioner~~ Secretary as being suitable for the proposed use.

3.3. Approved Backflow Prevention Assembly. -- A double check valve assembly, reduced pressure backflow prevention assembly, other devices or methods approved by the ~~Commissioner~~ Secretary for preventing backflow.

3.4. Auxiliary Water Supply. -- Any water source or system available within the building or premises other than the community public water system including, but not limited to, individual wells, springs, and cisterns. A private water storage tank supplied by a community public water system is considered an auxiliary water supply unless its design meets the most current minimum design standards required for storage tanks for community public water systems, and the water contained in them is potable.

3.5. Backflow. -- The flow of water or other liquids, mixtures, or substances into the distributing pipes of a potable supply of water from any source or sources other than its intended source. Backsiphonage is one type of backflow.

~~3.6. Commissioner. — The Commissioner of the Bureau for Public Health or his or her designee.~~

~~3.7.~~ 3.6. Cross-Connection. -- Any physical connection or arrangement between two otherwise separate systems or sources, one of which contains potable water and the other either water, steam, gas, or chemical of unknown or questionable safety whereby there may be a flow from one system or source to the other, the direction of flow depending on the pressure differential between the two systems.

~~3.8.~~ 3.7. Degree of Hazard. -- The potential risk to health and potential adverse effects upon the public water system based on the probability of backflow occurring and the type or nature of the contaminant.

~~3.9.~~ 3.8. Double Check Valve Assembly. -- An arrangement or device consisting of two single, independently acting watertight check valves with connections for testing the water-tightness of each check valve.

~~3.10.~~ 3.9. Flood Level Rim. -- The edge of the vessel or receptacle from which water overflows.

~~3.11.~~ 3.10. Health Hazard. -- Any condition, device, or practice that in the judgment of the ~~Commissioner~~ Secretary creates or may create a danger to the health and well-being of the water customer.

3.11. High-Hazard System. -- A hazard that is conducive to the introduction of waterborne disease organisms, or harmful chemical, physical, or radioactive substances into a public water system, and that presents an unreasonable risk to health.

~~3.12.~~ 3.12. Interchangeable Connection. -- An arrangement or device that allows the alternate but not simultaneous use of two sources of water.

3.13. Low-Hazard System. -- A hazard that could cause aesthetic problems or have a detrimental secondary effect on the quality of the public potable water supply.

~~3.13.~~ 3.14. Low-Suction Pressure Cut-Off Controller. -- An arrangement or device designed to shut off a pump when the pressure at the suction side of the pump falls below a specified level.

~~3.14.~~ 3.15. Person. -- An individual, partnership, association, syndicate, company, firm, trust, corporation, government corporation, institution, department, division, bureau, agency, or any entity recognized by law.

~~3.15.~~ 3.16. Potable Water. -- Water free from impurities in amounts sufficient to cause disease or harmful physiological effects, with bacteriological, chemical, physical, and radiological quality conforming to applicable regulations and standards of the bureau for public health.

~~3.16. Public Water System (PWS). — Any water supply or system that regularly supplies or offers to supply water for human consumption through pipes or other constructed conveyances, if serving at least an average of 25 individuals per day for at least 60 days per year, or which has at least 15 service connections, and shall include: (1) Any collection, treatment, storage, and distribution facilities under the control of the owner or operator of the system that are used primarily in connection with the system; and (2) Any collection or pretreatment storage facilities not under the control of the owner or operator of the PWS that are used primarily in connection with the system. A PWS does not include a system that meets all of the~~

~~following conditions: (1) Consists only of distribution and storage facilities and does not have any collection and treatment facilities; (2) Obtains all of its water from, but is not owned or operated by, a PWS that otherwise meets the definition; (3) Does not sell water to any person; and (4) Is not a carrier conveying passengers in interstate commerce.~~

~~3-17.~~ 3.17. Reduced Pressure Backflow Prevention Assembly. -- A device containing a minimum of two independently acting check valves, an automatically operated pressure differential relief valve located between the two check valves and watertight valves located at each end of the assembly, with connections for testing the operation of the device.

~~3-18.~~ 3.18. Severe Health Hazard. -- A hazard to the health of the user that could reasonably be expected to result in significant morbidity or death.

~~3-19.~~ 3.19. Unprotected Cross-Connection -- Any cross-connection with no approved backflow prevention assembly, air gap separation, double check valve assembly, or reduced pressure backflow prevention assembly installed.

~~3-20.~~ 3.20. Water Customer. -- The owner or person in charge of any building or premises supplied by or in any manner connected to a community public water system.

~~3-21.~~ 3.21. Water Service Line. -- A pipe or water line, with or without a meter and valves, through which the water customer conveys the water from the public water system to the initial point of use.

§64-15-4. Cross-Connections.

4.1. No person shall install or maintain an unprotected cross-connection in a public water system.

4.2. The public water system shall not install a water service connection to any premises where a violation of subsection 4.1 of this rule exists.

4.3. After giving written notice to the water customer with an opportunity for administrative due process, the public water system shall discontinue water service to any premises:

4.3.1. Where an unprotected cross-connection or unauthorized connection exists;

4.3.2. Where a required backflow prevention method has been removed or bypassed; or

4.3.3. When the public water system is denied entry to the water customer's premises to confirm compliance with this rule.

4.4. When the public water system finds deficiencies in a water customer's premises, as listed in subsection 4.3 of this section, the public water system shall;

4.4.1. Ensure that the public water system ceases water service to those premises until the deficiencies are corrected; and

4.4.2. Notifies the owner, person occupying, or in charge of the premises of the findings and orders that the cross-connection be removed or that an approved backflow prevention method be installed prior to water service resuming.

§64-15-5. When Protection Is Required.

5.1. The ~~Commissioner~~ Secretary or his or her designee may determine, upon conducting a risk assessment, that any water supply system must be equipped with a backflow prevention assembly to protect the health and sanitation of water, whether publicly or privately owned: *Provided*, That water supply systems shall not require a backflow prevention assembly unless any of the following are met:

5.1.1. It cross-connects with a sprinkler or fire suppression system;

5.1.2. It cross-connects with an auxiliary water source or water well;

5.1.3. It cross-connects with any fluid storage tank, tub, pool, or cistern 85 gallons or larger with a public water inlet that can be below the water level;

5.1.4. It cross-connects with a boiler system;

5.1.5. It cross-connects with any land irrigation system; or

5.1.6. The property serviced by the public water supply is a funeral home or mortuary, restaurant, dry cleaner, medical facility, beauty and nail salon, car wash, multi-tenant retail space, commercial building three stories or taller, or commercial space with a dedicated fire service/sprinkler system, industrial facility, salvage and/or wastewater facility, food processing facility, recycling facility where cross-connected to the public water supply, correctional facility, or any other customer using chemicals harmful to human health that are cross-connected to the public water supply.

§64-15-6. Type of Protection and Circumstances When Protection Is Required.

6.1. The type of protection required under this rule depends on the degree of hazard that exists or may exist, as determined by the ~~Commissioner~~ Secretary, or his or her designee, and shall involve the installation of:

6.1.1. An approved air gap separation when the ~~Commissioner~~ Secretary, or his or her designee, determines that contamination with substances could cause a severe health hazard;

6.1.2. An approved air gap separation or approved reduced pressure principle backflow prevention assembly when the ~~Commissioner~~ Secretary, or his or her designee, determines that contamination with substances could cause a health hazard; or

6.1.3. An approved double-check valve assembly, approved reduced pressure principle backflow prevention assembly, or an approved air gap separation when the ~~Commissioner~~ Secretary, or his or her designee, determines that contamination with substances could degrade the water quality of the public water system.

6.2. When the ~~Commissioner~~ Secretary, or his or her designee, does not approve any point of connection between a public water system and an auxiliary water supply, the water customer shall install an approved air gap separation or an approved interchangeable connection with a reduced backflow prevention assembly.

6.3. When a water customer installs a booster pump on the premises served by a public water system, or on the service line to the premises, the customer shall install a check valve on the discharge and a low-suction pressure cut-off controller designed to shut off the booster pump when the pressure in the service line on the suction side of the pump drops to 20 pounds per square inch gauge or less.

6.4. On premises where backflow prevention assemblies are required by this rule, and the public interest requires continuous uninterrupted service, the water customer shall install two approved backflow prevention assemblies in parallel and shall properly valve them to permit continuous operation, or service to the premises shall be from two separate water service lines each protected by an approved backflow prevention assembly.

6.5. Water customers that are open to the public shall be required to install internal backflow prevention methods as part of the public water system's approved backflow prevention program in section 8 of this rule.

§64-15-7. Backflow Prevention Assemblies.

7.1. The ~~Commissioner~~ Secretary, or his or her designee, shall approve installation of an approved backflow prevention assembly at a location and in a manner that best facilitates testing and servicing in accordance with the approved cross connection and backflow prevention program in section 8.2. of this rule.

7.2. The water customer shall purchase, install, maintain, and test any backflow prevention assembly according to this rule.

7.3. When any approved backflow prevention assembly is found to be defective, the water customer shall immediately notify the public water system of any defect and within 10 days shall repair, overhaul, replace, and test the assembly again at the water customer's expense.

§64-15-8. Plans, Surveys, Investigations, and Testing.

8.1. The water customer shall provide the public water system with all drawings, plans, specifications, and other data related to the backflow prevention assemblies so that the public water system can ensure the water customer's compliance with this rule.

8.2. The public water system shall establish a cross-connection and backflow prevention program approved by the ~~Commissioner~~ Secretary.

8.3. The water customer shall furnish information on water use practices for facilities within the water customer's premises, including plumbing diagrams, drawings, or plans, at the request of the public water system.

8.4. The water customer on any premises that under this rule requires the installation of backflow prevention assemblies is responsible for getting the assemblies inspected and for the cost of the required inspections.

8.4.1. The water customer shall ensure that a person certified by the ~~Commissioner~~ Secretary as a certified backflow assembly tester inspects and tests the backflow prevention assemblies upon installation and ~~at least every 12 months after that~~ once every three years thereafter for low-hazard systems and annually for high-hazard systems; and

8.4.2. The certified backflow assembly tester shall provide records of all inspections and tests to the public water system within 15 days of the inspection or test.

8.5. The public water system shall maintain records of all inspections, surveys, tests, and corrective actions taken for a period of at least two years and provide the information to the ~~Commissioner~~ Secretary

upon request.

8.6. The public water system shall request permission from a potential water customer to inspect the premises and dwellings formerly served by individual wells when the public water system believes unprotected cross-connections may exist. If the potential water customer does not allow the inspection, the refusal will be grounds not to supply water service.

8.7. No provisions of this rule shall relieve the water customer of the responsibility for conducting surveys of water use practices on his or her premises to determine whether there are actual or potential unprotected cross-connections.

8.8. Requirements of this rule shall be in accordance with all applicable guidelines contained in the West Virginia Bureau for Public Health Manual, EW-114, "Cross-Connection and Backflow Prevention Manual," 2002.

§64-15-9. Enforcement.

9.1. This rule is enforced under W. Va. Code §16-1-6, §16-1-9, §16-1-9a, §16-1-17, §16-1-18, and other applicable code provisions.

§64-15-10. Penalties.

10.1. Any person who violates any provision of this rule or orders issued under this rule is subject to injunction, criminal prosecution, and criminal, civil, and administrative fines, all as provided in W. Va. Code §16-1-9, §16-1-9a, §16-1-17, and §16-1-18.

§64-15-11. Administrative Due Process.

11.1. Those persons adversely affected by the enforcement of this rule may request a contested case hearing in accordance with the Bureau for Public Health procedural rule, Rules of Procedure for Contested Case Hearings and Declaratory Rulings, 64 CSR 1 and the Administrative Procedures Act, W. Va. Code §29A-5-1, et seq.