

WEST VIRGINIA
SECRETARY OF STATE
KEN HECHLER
ADMINISTRATIVE LAW DIVISION

Form #4

Do Not Mark In this Box

FILED

OCT 5 12 52 PM '94

OFFICE OF WEST VIRGINIA
SECRETARY OF STATE

NOTICE OF RULE MODIFICATION OF A PROPOSED RULE

AGENCY: STATE FIRE COMMISSION TITLE NUMBER: 87

CITE AUTHORITY Chapter 29, Article 3, Section 5

AMENDMENT TO AN EXISTING RULE: YES NO

IF YES, SERIES NUMBER OF RULE BEING AMENDED: 1

TITLE OF RULE BEING AMENDED: State Fire Code

IF NO, SERIES NUMBER OF NEW RULE BEING PROPOSED:

TITLE OF RULE BEING PROPOSED:

THE ABOVE PROPOSED LEGISLATIVE RULE, FOLLOWING REVIEW BY THE LEGISLATIVE RULE MAKING REVIEW COMMITTEE IS HEREBY MODIFIED AS A RESULT OF REVIEW AND COMMENT BY THE LEGISLATIVE RULE-MAKING REVIEW COMMITTEE. THE ATTACHED MODIFICATIONS ARE FILED WITH THE SECRETARY OF STATE.

Bill L. Spencer / WJSTB
Bill L. Spencer, Chairman by
Walter Smittle III, State Fire Marshal

13.20

14 17.19. Visitation to home county. The regional jail
15 authority shall provide transportation to the inmate's
16 home county for purposes of visitation if (1) The home
17 county has a holding facility which may be used for
18 purposes of visitation (2) The county commission and the
19 sheriff of the county agree to provide space in the
20 holding facility for purposes of visitation and to accept
21 custody of the inmate during such period of visitation
22 and (3) Additional transportation space is available on
23 regularly scheduled runs to the home county required for
24 other necessary purposes such as transporting other
25 inmates to court proceedings. Priorities for inmates
26 seeking transportation to the home county for visitation
27 shall be assigned to available space on regularly sched-
28 uled runs as follows in the following order of priority: (1)
29 Emergency circumstances (2) Transportation for inmates
30 awaiting court proceedings and not under a sentence of
31 incarceration for any crime (3) Inmates who have not
32 received a visit within a three-month period and (4)
33 Other inmates on a first-come, first-served basis in order
34 of date and time of request."

§64-6-3.-State fire commission.

87-1
amend.

1 The legislative rules filed in the state register on the
2 eighth day of August, one thousand nine hundred
3 ninety-four, modified by the state fire commission to
4 meet the objections of the legislative rule-making review
5 committee and refiled in the state register on the fifth
6 day of October, one thousand nine hundred ninety-four,
7 relating to the state fire commission (state fire code, 87
8 CSR 1), are authorized with the amendments set forth
9 below:

10 On page five, section 5, line 3, after the word "with" by
11 striking out the words "NFPA 13, Standards" and
12 inserting in lieu thereof the words "the applicable NFPA
13 standard."

14 And,

15 On page 53, by striking out all of section 14.13 and

16 inserting a new section 14.13 to read as follows:

17 14.13 Primary Care Facilities

18 Definitions:

19 Primary Care Facility: Medical care and services at
20 the point when a person first seeks assistance from the
21 health care system for the simpler and more common
22 illnesses and emergency patient treatment/stabilization,
23 and which takes ongoing responsibility for the recipi-
24 ent's health maintenance and illness. Including these
25 and similar facilities: primary care centers, local health
26 departments, rural health initiative/Kellogg Clinics, and
27 birthing centers where patients are capable of taking
28 action for self preservation. No more than three
29 non-ambulatory patients are permitted.

30 Self-Preservation: Patients and other occupants of the
31 facility must be capable of removing themselves from the
32 facility with limited assistance, either physical or verbal,
33 in an emergency, such as fire.

34 Minimum Construction Requirements:

35 A. New Construction shall meet Section 5 of this rule.

36 Exception: No new facility shall be constructed of
37 unprotected wood frame construction (Type V (000)).

38 B. Existing Construction - no requirement except
39 unprotected wood frame construction shall not be
40 acceptable unless provided with an automatic sprinkler
41 protection system.

42 Sprinkler System:

43 Automatic Sprinkler System. Design and installation
44 shall be in accordance with NFPA 13, Standard for the
45 Installation of Sprinkler Systems.

46 Occupant Load:

47 A. Occupant Load calculation will be one person per
48 100 square feet of gross floor area.

49 B. No birthing/non-ambulatory care rooms will be
50 located above or below the level of exit discharge.

51 Means of Egress Requirements:

52 Every aisle, passageway, corridor, stairways, exit
53 discharge, exit location, and access shall be in accor-
54 dance with NFPA 101, Life Safety Code, Means of Egress
55 Requirements, and as modified by this rule.

56 Number of Exits:

57 There shall be not less than two remote exits provided
58 from each floor.

59 Corridors:

60 A. No dead end corridor shall exceed 20 feet.

61 B. Travel distance to an exit shall not exceed 150 feet
62 in a nonsprinklered building or 200 feet in a sprinklered
63 building.

64 C. All corridors shall be a minimum of 44 inches in
65 clear width. Primary Care facilities accepting
66 non-ambulatory patients shall have 6 foot corridors.

67 D. Corridors shall be of smoke tight construction.

68 Doors:

69 A. Doors in Means of Egress shall be a minimum of 36
70 inches in width and comply with NFPA 101, Life Safety
71 Code.

72 B. All exit doors shall be equipped with panic hard-
73 ware.

74 C. Doors not in the means of egress shall comply with
75 NFPA 101, Life Safety Code, Means of Egress Compon-
76 nents Protection:

77 A. Vertical Openings: All openings will comply with
78 NFPA 101, Life Safety Code, Vertical Openings Require-
79 ments.

80 B. Hazardous Areas:

81 1. All hazardous areas shall be separated by one hour
82 fire resistive construction with openings protected with
83 one hour fire resistive assemblies or shall be protected
84 with an automatic sprinkler system and construction
85 that resists the passage of smoke.

86 2. General anesthetizing locations and laboratories
87 using hazardous chemicals shall be protected in accor-
88 dance with NFPA 99, Standard for Health Care Facili-
89 ties.

90 C. Interior Finish:

91 Interior finish throughout the building will be Class A.
92 Where an approved automatic sprinkler system is
93 installed, Class B or C is acceptable.

94 D. Carpet:

95 All carpet will have a critical radiant flux minimum of
96 0.45 watts per square centimeter.

97 E. Fire Alarm:

98 The fire alarm system will comply with Section 11.01
99 and 11.04 of this rule. EXCEPTION: The fire alarm
100 system is not required to be connected to a communica-
101 tion center.

102 F. Building Services:

103 Building services will comply with NFPA 101, Life
104 Safety Code, Building Service and Fire Protection
105 Equipment Requirements.

106 G. Rescue and Ventilation:

107 Sleeping rooms will have at least one outside window
108 for emergency rescue and ventilation. The window shall
109 provide a clear opening of not less than 20 inches in
110 width, 24 inches in height and 5.7 square feet in area.
111 The bottom of these window openings will be no more
112 than 44 inches above the floor.

113 H. Separation Requirements:

114 When a facility is located within a building having
115 more than one occupancy, the facility will be separated
116 from all other occupancies with a two (2) hour fire
117 barrier, or the building will be completely protected with
118 an automatic sprinkler system in accordance with NFPA
119 13, Standard for the Installation of Sprinkler System.

WEST VIRGINIA
STATE FIRE CODE

Rules
of the West Virginia
State Fire Commission

Approved by Secretary, Department of Military Affairs and Public
Safety.


Major General Joseph J. Skaff

August 5, 1994
Date


Bill L. Spencer, Chairman

July 28, 1994
Date

STATE FIRE COMMISSION
State Capitol
Charleston, West Virginia

WEST VIRGINIA STATE FIRE CODE
Rules of the
West Virginia State Fire Commission

SERIES I

INDEX

Section 1	General		
	1.01	Scope	1
	1.02	Authority	1
	1.03	Effective Date	1
	1.04	Filing Dates	1
	1.05	Exemption	1
	1.06	Incorporation of Other Documents	1
Section 2	Reporting of Fire Incidences by Fire Departments, Brigades, and Companies		2
Section 3	Unvented Heaters		2
Section 4	National Standards and Codes		
	4.01	Incorporation of National Standards and Codes	2
	4.02	National Standards and Codes - Modification of Fireworks Display Regulations	3
	4.03	National Standards and Codes - Table of Contents	
	(1)	National Fire Codes - Published by National Fire Protection Association	5-8
Section 5	Sprinkler Protection & Area Limitation		9
Section 6	Sprinkler Protection (Certain Occupancies)		11
Section 7	Carpet Used as Floor Covering		11

Section 8	Maintenance of Fire Hazard; Order for Correcting Condition, Removal of Material, Repair, Demolition, etc.; Order to Contain Notice to Comply and Right to Appeal	12
Section 9	Interference with Fire Protection Equipment	14
Section 10	High Rise Buildings - Fire Safety Standards and Requirements	14
	10.01 General	14
	10.02 Addition of Floors of Existing Buildings	15
	10.03 Automatic Fire Extinguishing Systems and Standpipe Systems	15
	10.04 Fire Alarm System	15
	10.05 Fire Department Voice Communication System	15
	10.06 High Rise Central Control Station	16
	10.07 Emergency Power	16
	10.08 Smoke Control <u>Management</u>	17
	10.09 Floor Designation	17
Section 11	Fire Alarm Systems	
	11.01 General	18-22
	11.02 Requirements for Educational Occupancy	22
	11.03 Requirements for Assembly Occupancy	23
	11.04 Requirements for Health Care Occupancy	24
	11.05 Requirements for Detention and Correction Occupancies	25
	11.06 Requirements for Residential Occupancy	26

11.07	Requirements for Mercantile Occupancy	28
11.08	Requirements for Business Occupancy	28
11.09	Requirements for Industrial Occupancy	29
11.10	Requirements for Storage Occupancy	29
Section 12	Exit Inspections and Public Life Safety Announcements	
12.01	Inspection of Exits	29
12.02	Announcements	30
12.03	Records	30
12.04	Alternatives	31
Section 13	Order of Decision of the State Fire Marshal; and Appeals and Procedure for Appeals from such Orders or Decisions	
13.01	State Fire Marshal's Order and Decisions are Final and Conclusive	31
13.02	West Virginia Code 29-3-12(g) and (i) Inquiry and Investigation	32
13.03	Appeal Petition	32
13.04	Time Requirement and Manner of Filing Appeal Petition	33
13.05	Copy of Appeal Petition to State Fire Commission	34
13.06	Scheduling Appeal Petition for and Notice of Hearing	34
13.07	Authorized Representative	35
13.08	Continuances	35
13.09	Absence of Petitioner or Counsel at the Scheduled Hearing	35
13.10	Hearing Examiner	36

13.11 Subpoenas and Subpoenas Duces Tecum	36
13.12 Evidence	38
13.13 Recording of Proceedings	39
13.14 Informal Disposition	39
13.15 Decision by the State Fire Commission	39
13.16 Judicial Review	40
Section 14 Miscellaneous Provisions	
14.01 Forest Fire Season	40
14.02 Executive Orders by the Governor on Open Burning	42
14.03 Outdoor Storage of Used Tires	42
14.04 Fireworks Defined; Labels Required	43
14.05 Unlawful Sale, Possession or Use of Fireworks; Permit for Public Display	44
14.06 Necessity of License for Electrical Work	47
14.07 Residential Board and Care Occupancies	47
<u>14.08 Storage of Fireworks Wholesale Distributors</u>	49
<u>14.09 Stopping, Standing or Parking Prohibited in Specified Places</u>	51
<u>14.10 Crossing Fire Hose</u>	52
<u>14.11 Emergency Vehicle Permits</u>	52
<u>14.12 Correctional/Detention Facilities</u>	53
<u>14.13 Rural Health Care and Birthing Center Facilities</u>	53
<u>14.14 Explosives Amendment to NFPA 495, Explosive Materials Code</u>	56
Section 15 Severability	56

FILED

Fire Commission
Legislative Rule
Series I

OCT 5 12 52 PM '94 Sec. 1

OFFICE OF WEST VIRGINIA
SECRETARY OF STATE

SECTION 1. General

1.01 Scope - ~~These~~ This rules establishes ~~the~~ the State Fire Code for the safeguarding of life and property from the hazards of fire and explosion.

1.02 Authority - ~~These~~ This legislative rules are is issued under authority of W. V. Code, Chapter 29, Article 3, Section 5 (1931, as amended), and pursuant to the provisions of W.Va. Code, Chapter 29A.

1.03 Effective Date -

1.04 Filing Date -

1.05 Exemption - This State Fire Code has no application to personal care homes caring for three or less patients or buildings used wholly as dwelling houses for no more than two families and has no application to farm structures. Provided; however, that farm structures (1) used for group sleeping accommodations for farm workers or (2) used for educational, health care or penal occupancy ~~shall~~ are not be exempt from the requirements of this State Fire Code.

1.06 Incorporation of Other Documents - This State Fire Code does not include a reprinting of all the requirements imposed by statute or by the incorporation of various National Standards and Codes cited in Section 4 of ~~these~~ this rules. For ascertaining these additional standards and requirements it is necessary to make reference to these other documents.

SECTION 2 Reporting of Fire Incidences by Fire Departments
Brigades, and Companies

Any organized public fire brigade, department or company shall report every fire and non-fire incident(s) to the State Fire Marshal on the forms provided by the State Fire Marshal. Every fire and non-fire incident response shall be reported within thirty (30) days after the date of the incident. EXCEPTION: Any fire or explosion involving human fatality, property damage in excess of \$250,000, or arson or suspected arson, shall be reported immediately.

SECTION 3 Unvented Heaters

All unvented fuel fire heaters are prohibited for all occupancies except one (1) and two (2) family dwellings.

SECTION 4 National Standards and Codes

4.01 Incorporated of National Standards and Codes -
The standards and requirements as set out and established by the ~~1990~~ 1994 edition of "The National Fire Codes" published by the National Fire Protection Association, [The National Fire Protection Association (NFPA) organized in 1896 is an independent, voluntary membership, nonprofit (tax-exempt) organization and has as it's mission the safeguarding of people, their property, and the environment from destructure fire, using scientific and engineering techniques and education] and the State Building

Code, but not including standards and requirements directed to the operation of local fire departments, NFPA 101M and Chapters ~~21~~ 22 and 23 of NFPA 101 and ~~shall~~ have the same force and effect as if set out verbatim in ~~these~~ this rules and are hereby adopted and promulgated by the State Fire Commission as a part of the State Fire Code. The State Fire Marshal shall make use of the standards and requirements within ~~said~~ the publications in all matters coming under his or her jurisdiction. A copy of ~~the said~~, The National Fire Codes has been filed with the Secretary of State and a copy of the Table of Contents of said publication is included ~~herewith~~ in Section 4.05 of this rule. Information regarding the purchase of ~~the aforesaid~~ The National Fire Codes (or separate volumes thereof) may be obtained by writing to the National Fire Protection Association, Batterymarch Park, Quincy, Massachusetts 02269.

4.02 National Standards and Codes - Modification of Fireworks Display Regulations. The "Regulations of the State Fire Marshal For The Display of Fireworks" as contained in N.F.P.A. 1123 and 1126 of the ~~1990~~ 1994 edition of The National Fire Codes ~~above referred to~~ shall have the same force and effect and shall control the same as if set out verbatim in ~~these regulations~~ in this rule and are hereby adopted and promulgated by the State Fire Commission as a part of the State Fire Code, but with numbered paragraphs A and B ~~thereof~~ changed to read as follows:

A. Upon receipt of such application at least 15 days in advance of the date set for this display, the Chief of the Fire Department shall make, or cause to be made an investigation of the site of the proposed display for the purpose of determining whether the provisions of ~~these regulations~~ this rule are complied with in the case of the particular display. He or she shall confer with the Chief of the Police Department, or the County Sheriff if the site for the proposed display is to be outside the limits of a municipality, about the application and whether issuance of a permit would be consistent with public safety. ~~Being satisfied that~~ If a display is properly lawful, the Chief of Police (or the County Sheriff, if the site of the proposed display is outside the limits of a municipality) and the Chief of Fire Department shall together endorse the application, stating that they approve the display as being in conformance with all parts of the law and with ~~these regulations~~ this rule. Failure to approve the application by either the Fire Chief or Police Chief (or County Sheriff, as the case might be) ~~shall be~~ is sufficient cause for the State Fire Marshal to deny a permit.

B. The application, following endorsement by the Chiefs of the Fire and Police Departments (or County Sheriff, as the case might be), shall be sent to the State Fire Marshal who shall then, upon receipt of evidence of financial responsibility as required by law in such cases, issue a nontransferable permit authorizing the display.

These changes to ~~said~~ the N.F.P.A. 1123 and 1126 are made to make certain it is understood that the County Sheriff (rather than City Police Chief) is the local police authority referred to in West Virginia Code 29-3-24 in those situations where the proposed site of a fireworks display is outside the limits of a municipality.

4.03 National Standards and Codes, Table of Contents

(1) National Fire Codes - Published by National Fire Protection Association, pages 5-8:

51A	Acetylene Cylinder Charging Plants—1989	Vol 2	496	Electrical Equipment, Purged and Pressurized Enclosures for—1993	Vol 7
1904	Aerial Ladder and Elevating Platform Fire Apparatus—1991	Vol 8		Electrical Fires, Investigation of—1988	Vol 12
308	Aerosol Products, Manufacture and Storage—1990	Vol 2	907M	Electrical Installations, Classification of Class I Hazardous Locations—1992	Vol 11
810	Agricultural Commodities, Milling of—1989	Vol 3	497A	Electrical Installations in Chemical Process Areas, Classification of Class II Hazardous (Classified) Locations—1991	Vol 11
90A	Air Conditioning and Ventilating Systems—1993	Vol 4	497B	Electrical Maintenance, Residential—1994	Vol 4
423	Aircraft Engine Test Facilities—1989	Vol 6	73	Electrical Safety Requirements for Employee Workplaces—1988	Vol 3
422M	Aircraft Fire Investigator's Manual—1989	Vol 11	70	Electrical Standard for Industrial Machinery—1991	Vol 4
415	Aircraft Fueling Ramp Drainage—1992	Vol 6	91	Exhaust Systems for Air Conveying of Materials—1992	Vol 4
407	Aircraft Fuel Servicing—1990	Vol 6	89	Explosion Prevention Systems—1992	Vol 3
406	Aircraft Hand Fire Extinguishers—1989	Vol 6	495	Explosive Materials Code—1992	Vol 7
409	Aircraft Hangars—1990	Vol 6	496	Explosives Motor Vehicle Terminals—1992	Vol 7
417	Aircraft Loading Walkways—1990	Vol 6	80A	Exposure Fires, Protection from—1993	Vol 10
410	Aircraft Maintenance—1989	Vol 6	51C	Feed Mills, Fire and Dust Explosions in—1989	Vol 3
403	Aircraft Rescue, Fire Fighting at Airports—1993	Vol 6	705	Field Flame Test for Textiles and Films—1993	Vol 11
412	Aircraft Rescue, Evaluating Fire Fighting Foam Equipment—1993	Vol 6	921	Fire and Explosion Investigations Guide—1992	Vol 12
			262	Fire and Smoke Characteristics of Electrical Wire and Cables, Method of Test for—1990	Vol 6
402M	Aircraft Rescue and Fire Fighting Operations—1991	Vol 11	72	Fire Alarm Code, National—1993	Vol 4
414	Aircraft Rescue and Fire Fighting Vehicles—1990	Vol 6	1901	Fire Apparatus, Pumper—1991	Vol 8
424M	Airport/Community Emergency Planning—1991	Vol 11	1410	Fire Attack, Initial—1988	Vol 8
1003	Airport Fire Fighter Qualifications—1987	Vol 7	1914	Fire Department Aerial Devices, Testing—1991	Vol 9
416	Airport Terminal Buildings—1993	Vol 6	1931	Fire Department Ground Ladders—1989	Vol 9
419	Airport Water Supply Systems—1992	Vol 11	1932	Fire Department Ground Ladders, Use, Maintenance, and Service Testing—1989	Vol 9
101*M	Alternative Approaches to Life Safety—1992	Vol 10	1561	Fire Department Incident Management System—1990	Vol 8
651	Aluminum Powder—1993	Vol 7	1581	Fire Department Infection Control Program—1992	Vol 8
65	Aluminum Processing, Finishing—1993	Vol 3	1500	Fire Department Occupational Safety and Health Program—1992	Vol 8
490	Ammonium Nitrate, Storage of—1993	Vol 7	13E	Fire Department Operations in Protected Properties—1989	Vol 10
232AM	Archives and Records Centers—1991	Vol 11	1521	Fire Department Safety Officer—1992	Vol 8
8504	Atmospheric Fluidized-Bed Boiler Operation—1993	Vol 9	1404	Fire Department Self-Contained Breathing Apparatus Program—1989	Vol 8
30A	Automotive and Marine Service Station Code—1993	Vol 2	1002	Fire Department Vehicle Driver/Operator Qualifications—1993	Vol 7
231E	Baled Cotton Storage—1989	Vol 10	80	Fire Doors and Windows—1992	Vol 4
8501	Boiler Operation, Single Burner—1992	Vol 9	10	Fire Extinguishers, Portable—1990	Vol 1
251	Building Construction and Materials, Fire Tests of—1990	Vol 6	10L	Fire Extinguishers, Port, Enabling Act—1990	Vol 10
220	Building Construction, Standard Types of—1992	Vol 5	10R	Fire Extinguishers, Portable, in Family Dwellings—1992	Vol 10
1402	Building Fire Service Training Centers—1992	Vol 12	2001	Fire Extinguishing Systems, Clean Agent—1994	Vol 9
703	Building Materials, Fire Retardant Coatings—1992	Vol 7	1001	Fire Fighting Professional Qualifications—1992	Vol 7
259	Building Materials, Test Method for Potential Heat—1993	Vol 6	704	Fire Hazards of Materials, Identification—1990	Vol 7
255	Building Materials, Test of Surface Burning Characteristics of—1990	Vol 6	1961	Fire Hose—1992	Vol 9
12	Carbon Dioxide Extinguishing Systems—1993	Vol 1	1962	Fire Hose, Care, Use and Service Testing—1993	Vol 9
40	Cellulose Nitrate Motion Picture Film—1988	Vol 2	1963	Fire Hose Connections—1993	Vol 9
654	Chemical, Dye, Pharmaceutical, and Plastic Industries, Prevention of Fire and Dust Explosions in—1988	Vol 7	906	Fire Incident Field Notes—1993	Vol 12
491M	Chemical Reactions, Hazardous—1991	Vol 11	1031	Fire Inspector, Professional Qualifications—1993	Vol 7
49	Chemicals Data, Hazardous—1991	Vol 10	1033	Fire Investigator Professional Qualifications—1993	Vol 7
97	Chimneys, Vents, Heat Producing Appliances, Terms Relating to—1992	Vol 10	1021	Fire Officer Professional Qualifications—1992	Vol 7
211	Chimneys, Vents, Fireplaces, and Solid Fuel Burning Appliances—1992	Vol 5	1	Fire Prevention Code—1992	Vol 1
260	Cigarette Ignition Resistance, Components of Furniture—1994	Vol 6	20	Fire Pumps, Centrifugal—1993	Vol 1
261	Cigarette Ignition Resistance, Upholstered Furniture Material Assemblies—1994	Vol 6	902M	Fire Reporting Field Incident Manual—1990	Vol 12
318	Cleanrooms, Protection of—1992	Vol 6	550	Firesafety Concepts Tree—1986	Vol 11
16A	Closed-Head Foam-Water Sprinkler Systems—1994	Vol 1	170	Fire Safety Symbols—1994	Vol 5
1999	Clothing, Protective for Medical Emergency Operations—1992	Vol 9	1041	Fire Service Instructor Qualifications—1992	Vol 7
1976	Clothing, Protective for Proximity Fire Fighting—1992	Vol 9	1983	Fire Service Life Safety Rope—1990	Vol 9
1971	Clothing, Protective for Structural Fire Fighting—1991	Vol 9	1201	Fire Services for the Public—1989	Vol 12
120	Coal Preparation Plants—1994	Vol 5	1124	Fireworks, Manufacture, Transportation, and Storage of—1988	Vol 8
901	Cooling, Uniform for Fire Protection—1990	Vol 12	1123	Fireworks Outdoor Display of—1990	Vol 8
37	Combustion Engines and Gas Turbines—1994	Vol 2	321	Flammable and Combustible Liquids, Classification—1991	Vol 6
1221	Communication Systems, Public Fire Service—1991	Vol 8	30	Flammable and Combustible Liquids Code—1993	Vol 2
473	Competencies for EMS Personnel—1992	Vol 7	395	Flammable and Combustible Liquids, Farm Storage of—1983	Vol 6
55	Compressed and Liquefied Gases in Portable Cylinders—1993	Vol 2	386	Flammable and Combustible Liquids, Portable Shipping Tanks—1990	Vol 6
52	Compressed Natural Gas (CNG) Vehicular Fuel Systems—1992	Vol 2	385	Flammable and Combustible Liquids, Tank Vehicles for—1990	Vol 6
75	Computer/Data Processing Equipment—1992	Vol 4	329	Flammable and Combustible Liquids, Underground Releases of—1992	Vol 11
241	Construction, Alteration, and Demolition Operations—1993	Vol 6	122	Flammable and Combustible Liquids, Underground Metal and Nonmetal Mines (Other than Coal)—1990	Vol 5
96	Cooking Operations, Ventilation Control—1994	Vol 4	328	Flammable Liquids and Gases in Manholes, Sewers—1992	Vol 11
214	Cooling Towers, Water—1992	Vol 5	325M	Flammable Liquids, Gases, Volatile Solids, Fire Hazard Properties of—1991	Vol 11
51B	Cutting and Welding Processes—1994	Vol 2	253	Floor Covering Systems, Critical Radiant Flux Test for—1990	Vol 6
124	Diesel Fuel and Diesel Equipment in Underground Mines—1988	Vol 5	11C	Foam Apparatus, Mobile—1990	Vol 1
34	Dipping and Coating Processes Using Flammable or Combustible Liquids—1989	Vol 2	296	Foam Chemicals for Wildland Fire Control—1989	Vol 6
252	Door Assemblies, Fire Tests of—1990	Vol 6	11	Foam Extinguishing Systems, Low Expansion—1994	Vol 1
17	Dry Chemical Extinguishing Systems—1990	Vol 1	11A	Foam Systems, Medium- and High-Expansion—1994	Vol 1
32	Drycleaning Plants—1990	Vol 2	16	Foam-Water Sprinkler and Spray Systems—1991	Vol 1
1452	Dwelling Fire Safety Surveys—1993	Vol 12			
850	Electric Generating Plants—1992	Vol 12			
70	Electrical Code, National—1993	Vol 3			
497M	Electrical Equipment in Haz. (Class.) Locations, Gases, Vapors, Dusts—1991	Vol 11			
70B	Electrical Equipment Maintenance—1990	Vol 10			

ALPHABETICAL INDEX—1994 NFC CONTENTS

1974	Footwear, Protective for Structural Fire Fighting—1992	Vol 9	8503	Pulverized Fuel Systems—1992	Vol 9
46	Forest Products, Storage of—1990	Vol 10	1921	Pumping Units, Portable—1993	Vol 9
54	Fuel Gas Code National—1992	Vol 2	1911	Pumps on Fire Department Apparatus, Service Tests of—1991	Vol 9
81	Fur Storage, Fumigation and Cleaning—1988	Vol 4	1125	Pyrotechnic Use Before a Proximate Audience—1992	Vol 8
85C	Furnace Explosions/Implosions in Multiple Burner Boiler-Furnaces—1991	Vol 4	40E	Pyroxylin Plastic—1993	Vol 2
86C	Furnaces, Industrial, Special Atmosphere—1991	Vol 4	150	Racetrack Stables—1991	Vol 5
86D	Furnaces, Industrial, Vacuum Atmosphere—1990	Vol 4	231C	Rack Storage of Materials—1991	Vol 6
88B	Garages, Repair—1991	Vol 4	801	Radioactive Materials, Facilities Handling—1991	Vol 11
51	Gas Systems: Oxygen-Fuel Welding, Cutting—1992	Vol 2	232	Records, Protection of—1991	Vol 6
1973	Gloves for Structural Fire Fighting—1993	Vol 9	501D	Recreational Vehicle Parks—1993	Vol 7
61B	Gran Elevators and Bulk Handling—1989	Vol 3	501 C	Recreational Vehicles—1993	Vol 7
601	Guard Service in Fire Loss Prevention—1992	Vol 7	914	Rehabilitation and Adaptive Reuse of Historic Structures—1989	Vol 12
12B	Halon 1211 Fire Extinguishing Systems—1990	Vol 1	471	Responding to Hazardous Materials Incidents—1992	Vol 11
12A	Halon 1301 Fire Extinguishing Systems—1992	Vol 1	1122	Rocketry, Code for Model—1994	Vol 8
472	Hazardous Materials Incidents Responders, Professional Competence—1992	Vol 7	231F	Roll Paper Storage—1987	Vol 6
99	Health Care Facilities—1993	Vol 5	203	Roof Coverings—1992	Vol 10
263	Heat and Visible Smoke Release Rates, Test for—	Vol 6	256	Roof Coverings, Fire Tests of—1993	Vol 6
264	Heat Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter—1992	Vol 6	231D	Rubber Tires, Storage of—1989	Vol 6
418	Helipad Roof-top Construction and Protection—1990	Vol 6	1470	Search and Rescue for Structural Collapse Incidents—1994	Vol 8
1972	Helmets, Structural Fire Fighting—1992	Vol 9	121	Self-Propelled and Mobile Surface Mining Equipment—1990	Vol 5
502	Highways, Tunnels, Bridges—1992	Vol 11	105	Smoke-Control Door Assemblies—1993	Vol 10
913	Historic Structures and Sites—1992	Vol 12	204M	Smoke and Heat Venting—1991	Vol 10
291	Hydrants, Testing and Marking—1988	Vol 11	92A	Smoke-Control Systems—1993	Vol 10
851	Hydroelectric Generating Plants—1992	Vol 12	258	Smoke Generated by Solid Materials, Standard Research Test for Measuring—1989	Vol 6
50A	Hydrogen Systems, Gaseous, at Consumer Sites—1994	Vol 2	92B	Smoke Management Systems in Malls, Atria, Large Areas—1991	Vol 10
99B	Hypobaric Facilities—1993	Vol 5	36	Solvent Extraction Plants—1993	Vol 2
904	Incident Follow-up Report Guide—1992	Vol 12	33	Spray Application Using Flammable and Combustible Materials—1989	Vol 2
82	Incinerators, Waste and Linen Handling Systems and Equipment—1994	Vol 4	1964	Spray Nozzles (Shutoff and Tip)—1993	Vol 9
600	Industrial Fire Brigades—1992	Vol 7	13	Sprinkler Systems, Installation—1994	Vol 1
505	Industrial Trucks, Powered—1992	Vol 7	13D	Sprinkler Systems, One- and Two-Family Dwellings—1994	Vol 1
1902	Initial Attack Fire Apparatus—1991	Vol 8	13R	Sprinkler Systems, Residential Occupancies up to and Including Four Stories in Height—1994	Vol 1
45	Laboratories Using Chemicals—1991	Vol 2	14	Standpipe and Hose Systems—1993	Vol 1
1405	Land-Based Fire Fighters Who Respond to Marine Vessel Fires—1990	Vol 12	61A	Starch Manufacturing and Handling—1989	Vol 3
910	Libraries and Library Collections—1991	Vol 12	77	Static Electricity—1993	Vol 10
101*	Life Safety Code—1994	Vol 5	1975	Station/Work Uniforms—1990	Vol 9
780	Lightning Protection Code—1992	Vol 7	8505	Stoker Operation—1992	Vol 12
50B	Liquefied Hydrogen Systems at Consumer Sites—1994	Vol 2	231	Storage, General—1990	Vol 5
59A	Liquefied Natural Gas, Storage and Handling—1994	Vol 3	231	Stored Electrical Energy Emergency and Standby Power Systems—1993	Vol 5
59	Liquefied Petroleum Gases at Utility Gas Plants—1992	Vol 3	111	Sulfur Fires and Explosions, Prevention—1993	Vol 7
58	Liquefied Petroleum Gases, Storage and Handling—1992	Vol 3	655	Support Function Protective Garments for Hazardous Chemical Operations—1990	Vol 9
1992	Liquid Splash-Protective Suits for Hazardous Chemical Emergencies—1990	Vol 9	1993	Tanks, Containers, Small, Cleaning—1993	Vol 6
1403	Live Fire Training Evolutions in Structures—1992	Vol 8	327	Tanks, Safe Entry of Underground Storage—1993	Vol 6
480	Magnesium, Storage, Handling—1993	Vol 7	326	Telecommunications Systems for Rural and Forestry Services—1986	Vol 11
501A	Manufactured Home Installations, Sites, and Communities—1992	Vol 7	297	Tents and Membrane Structures, Assembly Seating—1992	Vol 5
303	Mannas and Boatyards—1990	Vol 6	102	Terminals, Motor Freight—1994	Vol 7
307	Manne Terminals, Piers and Wharves—1990	Vol 6	513	Textile Wall Coverings, Evaluating Room Fire Growth Contribution of—1994	Vol 6
1582	Medical Requirements for Fire Fighters—1992	Vol 8	265	Textiles and Films, Flame Resistant Test for—1989	Vol 7
1903	Mobile Water Supply Fire Apparatus—1991	Vol 8	701	Titanium, Handling and Storage—1987	Vol 7
1125	Model Rocket Motors—1988	Vol 8	481	Training Reports and Records—1989	Vol 12
302	Motor Craft, Pleasure and Commercial—1989	Vol 5	1401	Transit Systems, Fixed Guideway—1993	Vol 5
911	Museums and Museum Collections—1991	Vol 12	130	Truck Fire Protection—1994	Vol 7
803	Nuclear Power Plants, Light Water—1993	Vol 7	512	Underground Bituminous Coal Mines—1990	Vol 5
802	Nuclear Research and Production Reactors—1993	Vol 11	123	Upholstered Furniture Components or Composites and Mattresses, Heat Release Rates for—1990	Vol 6
31	Oil Burning Equipment, Installation of—1992	Vol 2	264A	Vapor-Protective Suits for Hazardous Chemical Emergencies—1990	Vol 9
1981	Open-Circuit Self-Contained Breathing Apparatus—1992	Vol 9	1991	Venting of Deflagrations—1994	Vol 10
35	Organic Coatings, Manufacture of—1987	Vol 2	68	Vessels, Control of Gas Hazards on—1993	Vol 6
43B	Organic Peroxide Formulations—1993	Vol 2	306	Vessels, Protection During Construction, Repair and Lay-up—1990	Vol 6
1406	Outside Live Fire Training Evolutions—1993	Vol 8	312	Warm Air Heating and Air Conditioning Systems—1993	Vol 5
86	Ovens and Furnaces, Design, Location, Equipment—1990	Vol 4	90B	Wastewater Treatment and Collection Facilities—1992	Vol 11
43A	Oxidizers, Liquid and Solid Storage of—1990	Vol 2	820	Water-Based Fire Protection Systems—1992	Vol 2
50	Oxygen Systems, Bulk, at Consumer Sites—1990	Vol 2	25	Water Spray Fixed Systems—1990	Vol 1
53	Oxygen-Enriched Atmospheres, Fire Hazards in—1994	Vol 10	15	Water Supplies, Suburban and Rural Fire Fighting—1993	Vol 8
88A	Parking Structures—1991	Vol 4	1231	Water Supplies, Valves Controlling—1988	Vol 10
1982	Personal Alert Safety Systems (PASS) for Fire Fighters—1993	Vol 9	26	Water Tanks for Private Fire Protection—1993	Vol 1
43D	Pesticides in Portable Containers—1986	Vol 2	22	Wet Chemical Extinguishing Systems—1990	Vol 1
912	Places of Worship—1993	Vol 12	17A	Wetting Agents—1990	Vol 1
1141	Planned Building Groups—1990	Vol 8	18	Wildfire Control—1991	Vol 6
650	Pneumatic Conveying Systems—1990	Vol 7	295	Wildfires, Protection of Life and Property—1991	Vol 6
110	Power Systems, Emergency and Standby—1993	Vol 5	299	Window Assemblies, Fire Tests of—1990	Vol 6
1420	Pre-incident Planning for Warehouse Occupancies—1993	Vol 12	257	Wood Processing and Woodworking Facilities—1993	Vol 7
24	Private Fire Service Mains—1992	Vol 2	684	Zirconium, Production, Processing—1987	Vol 7
903	Property Survey Guide—1992	Vol 2	482		
1977	Protective Clothing and Equipment for Wildland Fire Fighting—1993	Vol 9			
1035	Public Fire and Life Safety Educator Professional Qualifications—1993	Vol 7			

NUMERICAL INDEX—1994 NFC CONTENTS

1	Fire Prevention Code—1992	Vol 1	85C	Furnace Explosions/Implosions in Multiple Burner	Vol 4
10	Portable Fire Extinguishers—1990	Vol 1		Boiler-Furnaces—1991	
10L	Model Enabling Act for the Sale or Leasing and Servicing of Portable Fire Extinguishers—1990	Vol 10	86	Ovens and Furnaces—Design, Location and Equipment—1990	Vol 4
10R	Portable Fire Extinguishers in Family Dwellings—1992	Vol 10	86C	Industrial Furnaces Using a Special Processing Atmosphere—1991	Vol 4
11	Low-Expansion Foam—1994	Vol 1	86D	Industrial Furnaces Using Vacuum as an Atmosphere—1990	Vol 4
11A	Medium- and High-Expansion Foam Systems—1994	Vol 1	88A	Parking Structures—1991	Vol 4
11C	Mobile Foam Apparatus—1990	Vol 1	88B	Repair Garages—1991	Vol 4
12	Carbon Dioxide Extinguishing Systems—1993	Vol 1	90A	Installation of Air Conditioning and Ventilating Systems—1993	Vol 4
12A	Halon 1301 Fire Extinguishing Systems—1992	Vol 1	90B	Installation of Warm Air Heating and Air Conditioning Systems—1993	Vol 4
12B	Halon 1211 Fire Extinguishing Systems—1990	Vol 1	91	Installation of Exhaust Systems for Air Conveying of Materials—1992	Vol 4
13	Installation of Sprinkler Systems—1994	Vol 1	92A	Smoke-Control Systems—1993	Vol 10
13D	Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes—1994	Vol 1	92B	Smoke Management Systems in Malls, Atria, Large Areas—1991	Vol 10
13E	Fire Department Operations in Properties Protected by Sprinkler and Standpipe Systems—1989	Vol 10	96	Ventilation Control and Fire Protection of Commercial Cooking Operations—1994	Vol 4
13R	Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height—1994	Vol 1	97	Glossary of Terms Relating to Chimneys, Vents and Heat Producing Appliances—1992	Vol 10
14	Installation of Standpipe and Hose Systems—1993	Vol 1	99	Health Care Facilities—1993	Vol 5
15	Water Spray Fixed Systems—1990	Vol 1	99B	Hypobaric Facilities—1993	Vol 5
16	Installation of Deluge Foam-Water Sprinkler Systems and Foam-Water Spray Systems—1991	Vol 1	101*	Safety to Life from Fire in Buildings and Structures—1994	Vol 5
16A	Installation of Closed-Head Foam-Water Sprinkler Systems—1994	Vol 1	101*PM	Alternative Approaches to Life Safety—1992	Vol 10
17	Dry Chemical Extinguishing Systems—1990	Vol 1	102	Assembly Seating, Tents, and Membrane Structures—1992	Vol 5
17A	Wet Chemical Extinguishing Systems—1990	Vol 1	105	Smoke-Control Door Assemblies—1993	Vol 10
18	Wetting Agents—1990	Vol 1	110	Emergency and Standby Power Systems—1993	Vol 5
20	Installation of Centrifugal Fire Pumps—1993	Vol 1	111	Stored Electrical Energy Emergency and Standby Power Systems—1993	Vol 5
22	Water Tanks for Private Fire Protection—1993	Vol 1	120	Coal Preparation Plants—1994	Vol 5
24	Installation of Private Fire Service Mains and Their Appurtenances—1992	Vol 2	121	Self-Propelled and Mobile Surface Mining Equipment—1990	Vol 5
25	Water-Based Fire Protection Systems—1992	Vol 2	122	Flammable and Combustible Liquids Within Underground Metal and Nonmetal Mines (Other than Coal)—1990	Vol 5
26	Supervision of Valves Controlling Water Supplies—1988	Vol 10	123	Fire Prevention and Control in Underground Bituminous Coal Mines—1990	Vol 5
30	Flammable and Combustible Liquids Code—1993	Vol 2	124	Diesel Fuel and Diesel Equipment in Underground Mines—1988	Vol 5
30A	Automotive and Marine Service Station Code—1993	Vol 2	130	Fixed Guideway Transit Systems—1993	Vol 5
30B	Aerosol Products, Manufacture and Storage—1990	Vol 2	150	Fire Safety in Race Track Stables—1991	Vol 5
31	Installation of Oil-Burning Equipment—1992	Vol 2	170	Fire Safety Symbols—1994	Vol 5
32	Drycleaning Plants—1990	Vol 2	203	Roof Coverings and Roof Deck Construction—1992	Vol 10
33	Spray Application Using Flammable and Combustible Materials—1989	Vol 2	204AM	Smoke and Heat Venting—1991	Vol 10
34	Dipping and Coating Processes Using Flammable or Combustible Liquids—1989	Vol 2	211	Chimneys, Fireplaces, Vents and Solid Fuel Burning Appliances—1992	Vol 5
35	Manufacture of Organic Coatings—1987	Vol 2	214	Water-Cooling Towers—1992	Vol 5
36	Solvent Extraction Plants—1993	Vol 2	220	Types of Building Construction—1992	Vol 5
37	Stationary Combustion Engines and Gas Turbines—1994	Vol 2	231	General Storage—1990	Vol 5
40	Storage and Handling of Cellulose Nitrate Motion Picture Film—1988	Vol 2	231C	Rack Storage of Materials—1991	Vol 6
40E	Storage of Pyroxylin Plastic—1993	Vol 2	231D	Storage of Rubber Tires—1989	Vol 6
43A	Storage of Liquid and Solid Oxidizers—1990	Vol 2	231E	Storage of Baled Cotton—1989	Vol 10
43B	Organic Peroxide Formulations, Storage of—1993	Vol 2	231F	Roll Paper Storage—1987	Vol 6
43D	Storage of Pesticides in Portable Containers—1986	Vol 2	232	Records, Protection of—1991	Vol 6
45	Fire Protection for Laboratories Using Chemicals—1991	Vol 2	232AM	Archives and Records Centers—1991	Vol 11
46	Storage of Forest Products—1990	Vol 10	241	Construction, Alteration, and Demolition Operations—1993	Vol 6
49	Hazardous Chemicals Data—1991	Vol 10	251	Fire Tests of Building Construction and Materials—1990	Vol 6
50	Bulk Oxygen Systems at Consumer Sites—1990	Vol 2	252	Fire Tests of Door Assemblies—1990	Vol 6
50A	Gaseous Hydrogen Systems at Consumer Sites—1994	Vol 2	253	Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source—1990	Vol 6
50B	Liquefied Hydrogen Systems at Consumer Sites—1994	Vol 2	255	Test of Surface Burning Characteristics of Building Materials—1990	Vol 6
51	Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting and Allied Processes—1992	Vol 2	256	Methods of Fire Tests of Roof Coverings—1993	Vol 6
51A	Acetylene Cylinder Charging Plants—1989	Vol 2	257	Fire Tests of Window Assemblies—1990	Vol 6
51B	Cutting and Welding Processes—1994	Vol 2	258	Research Test Method for Determining Smoke Generation of Solid Materials—1989	Vol 6
52	Compressed Natural Gas (CNG) Vehicular Fuel Systems—1992	Vol 2	259	Test Method for Potential Heat of Building Materials—1993	Vol 6
53	Fire Hazards in Oxygen-Enriched Atmospheres—1994	Vol 10	260	Cigarette Ignition Resistance of Components of Upholstered Furniture—1994	Vol 6
54	National Fuel Gas Code—1992	Vol 2	261	Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoking Cigarettes—1994	Vol 6
55	Compressed and Liquefied Gases in Portable Cylinders—1993	Vol 2	262	Method of Test for Fire and Smoke Characteristics of Electrical Wires and Cables—1990	Vol 6
58	Storage and Handling of Liquefied Petroleum Gases—1992	Vol 3	263	Heat and Visible Smoke Release Rates for Materials and Products, Method of Test for—1986	Vol 6
59	Storage and Handling of Liquefied Petroleum Gases at Utility Gas Plants—1992	Vol 3	264	Heat Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter—1992	Vol 6
59A	Liquefied Natural Gas (LNG)—1994	Vol 3	264A	Method of Test for Heat Release Rates for Upholstered Furniture Components or Composites and Mattresses Using an Oxygen Consumption Calorimeter—1990	Vol 6
61A	Fire and Dust Explosions in Facilities Manufacturing and Handling Starch—1989	Vol 3	265	Evaluating Room Fire Growth Contribution of Textile Wall Coverings—1994	Vol 6
61B	Fires and Explosions in Grain Elevators and Facilities Handling Bulk Raw Agricultural Commodities—1989	Vol 3	291	Fire Flow Testing and Marking of Hydrants—1988	Vol 11
61C	Fire and Dust Explosions in Feed Mills—1989	Vol 3	295	Wildfire Control—1991	Vol 6
61D	Fire and Dust Explosions in the Milling of Agricultural Commodities for Human Consumption—1989	Vol 3	297	Telecommunications Systems—Principles and Practices for Rural and Forestry Services—1985	Vol 11
65	Processing and Finishing of Aluminum—1993	Vol 3	298	Foam Chemicals for Wildland Fire Control—1989	Vol 6
68	Venting of Deflagrations—1994	Vol 10	299	Protection of Life and Property from Wildfire—1991	Vol 6
69	Explosion Prevention Systems—1992	Vol 3	302	Pressure and Commercial Motor Craft—1989	Vol 6
70	National Electrical Code®—1993	Vol 3	303	Mannas and Boatyards—1990	Vol 6
70B	Electrical Equipment Maintenance—1990	Vol 10	306	Control of Gas Hazards on Vessels—1993	Vol 6
70E	Electrical Safety Requirements for Employee Workplaces—1988	Vol 3	307	Marine Terminals, Piers and Wharves—1990	Vol 6
72	National Fire Alarm Code—1993	Vol 4			
73	Residential Electrical Maintenance—1994	Vol 4			
75	Protection of Electronic Computer/Data Processing Equipment—1992	Vol 4			
77	Static Electricity—1993	Vol 10			
79	Electrical Standard for Industrial Machinery—1991	Vol 4			
80	Fire Doors and Windows—1992	Vol 4			
80A	Exterior Fire Exposures—1993	Vol 10			
81	Fur Storage, Fumigation and Cleaning—1986	Vol 4			
82	Incinerators, Waste and Linen Handling Systems and Equipment—1994	Vol 4			

NUMERICAL INDEX—1994 NFC CONTENTS

312	Fire Protection of Vessels During Construction, Repair and Lay-Up—1990	Vol 8	850	Electric Generating Plants—1992	Vol 12
318	Cleanrooms—1992	Vol 8	851	Hydroelectric Generating Plants—1992	Vol 12
321	Basic Classification of Flammable and Combustible Liquids—1991	Vol 8	901	Uniform Coding for Fire Protection—1990	Vol 12
325M	Fire Hazard Properties of Flammable Liquids, Gases, and Volatile Solids—1991	Vol 11	902M	Fire Reporting Field Incident Manual—1990	Vol 12
326	Safe Entry of Underground Storage Tanks—1993	Vol 6	903	Fire Reporting Property Survey Guide—1992	Vol 12
327	Cleaning or Safeguarding Small Tanks and Containers Without Entry—1993	Vol 6	904	Incident Follow-up Report Guide—1992	Vol 12
328	Control of Flammable and Combustible Liquids and Gases in Manholes, Sewers, and Similar Underground Structures—1992	Vol 11	906	Fire Incident Field Notes—1993	Vol 12
329	Handling Underground Releases of Flammable and Combustible Liquids—1992	Vol 11	907M	Investigation of Fires of Electrical Origin—1988	Vol 12
385	Tank Vehicles for Flammable and Combustible Liquids—1990	Vol 6	910	Libraries and Library Collections—1991	Vol 12
386	Portable Shipping Tanks for Flammable and Combustible Liquids—1990	Vol 6	911	Museums and Museum Collections—1991	Vol 12
395	Storage of Flammable and Combustible Liquids on Farms and Isolated Sites—1993	Vol 6	912	Places of Worship—1993	Vol 12
402M	Aircraft Rescue and Fire Fighting Operations—1991	Vol 11	913	Historic Structures and Sites—1992	Vol 12
403	Aircraft Rescue and Fire Fighting Services at Airports—1993	Vol 6	914	Rehabilitation and Adaptive Reuse of Historic Structures—1989	Vol 12
407	Aircraft Fuel Servicing—1990	Vol 6	921	Fire and Explosion Investigations Guide—1992	Vol 12
408	Aircraft Hand Fire Extinguishers—1989	Vol 6	1001	Fire Fighter Professional Qualifications—1992	Vol 7
409	Aircraft Hangars—1990	Vol 6	1002	Fire Department Vehicle Driver/Operator Professional Qualifications—1993	Vol 7
410	Aircraft Maintenance—1989	Vol 6	1003	Airport Fire Fighter Professional Qualifications—1987	Vol 7
412	Evaluating Aircraft Rescue and Fire Fighting Foam Equipment—1993	Vol 6	1021	Fire Officer Professional Qualifications—1992	Vol 7
414	Aircraft Rescue and Fire Fighting Vehicles—1990	Vol 6	1031	Professional Qualifications for Fire Inspector—1993	Vol 7
415	Aircraft Fueling Ramp Drainage—1992	Vol 6	1033	Fire Investigator Professional Qualifications—1993	Vol 7
416	Construction and Protection of Airport Terminal Buildings—1993	Vol 6	1035	Public Fire and Life Safety Educator Professional Qualifications—1993	Vol 7
417	Construction and Protection of Aircraft Loading Walkways—1990	Vol 6	1041	Fire Service Instructor Professional Qualifications—1992	Vol 7
418	Roof-top Helipad Construction and Protection—1990	Vol 6	1122	Code for Model Rocketry—1994	Vol 8
419	Master Planning Airport Water Supply Systems for Fire Protection—1992	Vol 11	1123	Outdoor Display of Fireworks—1990	Vol 8
422M	Aircraft Fire and Explosion Investigator's Manual—1989	Vol 11	1124	Manufacture, Transportation and Storage of Fireworks—1988	Vol 8
423	Construction and Protection of Aircraft Engine Test Facilities—1989	Vol 6	1125	Model Rocket Motors—1988	Vol 8
424M	Airport/Community Emergency Planning—1991	Vol 11	1126	Use of Pyrotechnics Before a Proximate Audience—1992	Vol 8
471	Responding to Hazardous Materials Incidents—1992	Vol 11	1141	Planned Building Groups—1990	Vol 8
472	Professional Competence of Responders to Hazardous Materials Incidents—1992	Vol 7	1201	Developing Fire Protection Services for the Public—1989	Vol 12
473	Competencies for EMS Personnel—1992	Vol 7	1221	Installation, Maintenance and Use of Public Fire Service Communication Systems—1991	Vol 8
480	Storage, Handling, and Processing of Magnesium—1993	Vol 7	1231	Water Supplies for Suburban and Rural Fire Fighting—1993	Vol 8
481	Production, Processing, Handling and Storage of Titanium—1987	Vol 7	1401	Fire Protection Training Reports and Records—1989	Vol 12
482	Production, Processing, Handling and Storage of Zirconium—1987	Vol 7	1402	Building Fire Service Training Centers—1992	Vol 12
490	Storage of Ammonium Nitrate—1993	Vol 7	1403	Live Fire Training Evolutions in Structures—1992	Vol 8
491M	Hazardous Chemical Reactions—1991	Vol 11	1404	Fire Department Self-Contained Breathing Apparatus Program—1989	Vol 8
495	Explosive Materials Code—1992	Vol 7	1405	Land-Based Fire Fighters Who Respond to Marine Vessel Fires—1990	Vol 12
496	Purged and Pressurized Enclosures for Electrical Equipment in Hazardous (Classified) Locations—1993	Vol 7	1406	Outside Live Fire Training Evolutions—1993	Vol 8
497A	Classification of Class I Hazardous Locations for Electrical Installations in Chemical Process Areas—1992	Vol 11	1410	Training Standard on Initial Fire Attack—1988	Vol 8
497B	Classification of Class II Hazardous (Classified) Locations for Electrical Installations in Chemical Process Areas—1991	Vol 11	1420	Pre-incident Planning for Warehouse Occupancies—1993	Vol 12
497M	Classification of Gases, Vapors and Dusts for Electrical Equipment in Hazardous (Classified) Locations—1991	Vol 11	1452	Training Fire Department Personnel to Make Dwelling Fire Safety Surveys—1993	Vol 12
498	Explosives Motor Vehicle Terminals—1992	Vol 7	1470	Search and Rescue for Structural Collapse Incidents—1994	Vol 8
501A	Fire Safety Criteria for Manufactured Home Installations, Sites and Communities—1992	Vol 7	1500	Fire Department Occupational Safety and Health Program—1992	Vol 8
501C	Fire Safety Criteria for Recreational Vehicle—1993	Vol 7	1521	Fire Department Safety Officer—1992	Vol 8
501D	Fire Safety Criteria for Recreational Vehicle Parks and Campgrounds—1993	Vol 7	1581	Fire Department Incident Management System—1990	Vol 8
502	Fire Protection for Limited Access Highways, Tunnels, Bridges, Elevated Roadways, and Air Right Structures—1992	Vol 11	1581	Fire Department Infection Control Program—1991	Vol 8
505	Powered Industrial Trucks Including Type Designations, Areas of Use, Maintenance and Operations—1992	Vol 7	1582	Medical Requirements for Fire Fighters—1992	Vol 8
512	Truck Fire Protection—1994	Vol 7	1901	Pumper Fire Apparatus—1991	Vol 8
513	Motor Freight Terminals—1994	Vol 7	1902	Initial Attack Fire Apparatus—1991	Vol 8
550	Fire Safety Concepts Tree—1988	Vol 11	1903	Mobile Water Supply Fire Apparatus—1991	Vol 8
600	Industrial Fire Brigades—1992	Vol 7	1904	Aerial Ladder and Elevating Platform Fire Apparatus—1991	Vol 9
601	Guard Service in Fire Loss Prevention—1992	Vol 7	1911	Service Tests of Pumps on Fire Department Apparatus—1991	Vol 9
650	Pneumatic Conveying Systems for Handling Combustible Materials—1990	Vol 7	1914	Fire Department Aerial Devices, Testing—1991	Vol 9
651	Manufacture of Aluminum Powder—1993	Vol 7	1921	Fire Department Portable Pumping Units—1993	Vol 9
654	Prevention of Fire and Dust Explosions in the Chemical, Dye, Pharmaceutical, and Plastics Industries—1988	Vol 7	1931	Design, and Design Verification Tests for Fire Department Ground Ladders—1989	Vol 9
655	Sulfur Fires and Explosions—1993	Vol 7	1932	Use, Maintenance and Service Testing of Fire Department Ground Ladders—1989	Vol 9
664	Fires and Explosions in Wood Processing and Woodworking Facilities—1993	Vol 7	1981	Fire Hose—1992	Vol 11
701	Methods of Fire Tests for Flame-Resistant Textiles and Films—1989	Vol 7	1982	Care, Use, and Service Testing of Fire Hose including Connections and Nozzles—1993	Vol 11
703	Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials—1992	Vol 7	1983	Fire Hose Connections—1993	Vol 11
704	Identification of the Fire Hazards of Materials—1990	Vol 7	1971	Spray Nozzles (Shutoff and Tip)—1993	Vol 11
705	Field Flame Test for Textiles and Films—1993	Vol 11	1972	Protective Clothing for Structural Fire Fighting—1991	Vol 11
780	Lightning Protection Code—1992	Vol 7	1973	Helmets for Structural Fire Fighting—1992	Vol 11
801	Facilities Handling Radioactive Materials—1991	Vol 11	1974	Gloves for Structural Fire Fighting—1993	Vol 11
802	Nuclear Research and Production Reactors—1993	Vol 11	1975	Protective Footwear for Structural Fire Fighting—1992	Vol 11
803	Light Water Nuclear Power Plants—1993	Vol 7	1976	Station/Work Uniforms—1990	Vol 11
820	Fire Protection in Wastewater Treatment and Collection Facilities—1992	Vol 11	1977	Protective Clothing for Proximity Fire Fighting—1992	Vol 11
			1981	Protective Clothing and Equipment for Wildland Fire Fighting—1993	Vol 11
			1982	Open-Circuit Self-Contained Breathing Apparatus for Fire Fighters—1992	Vol 11
			1983	Personal Alert Safety Systems (PASS) for Fire Fighters—1993	Vol 11
			1991	Fire Service Life Safety Rope—1990	Vol 11
			1992	Vapor-Protective Suits for Hazardous Chemical Emergencies—1990	Vol 11
			1993	Liquid Splash-Protective Suits for Hazardous Chemical Emergencies—1990	Vol 11
			1999	Support Function Protective Garments for Hazardous Chemical Operations—1990	Vol 11
			2001	Protective Clothing for Medical Emergency Operations—1992	Vol 11
			8501	Clean Agent Fire Extinguishing Systems—1994	Vol 11
			8503	Single Burner Boiler Operation—1992	Vol 11
			8504	Purified Fuel Systems—1992	Vol 11
			8505	Atmospheric Fluidized-Bed Boiler Operation—1993	Vol 11
			8505	Stoker Operation—1992	Vol 11

SECTION 5 Sprinkler Protection & Area Limitations

Approved automatic sprinkler systems in accordance with NFPA 13, Standards for Sprinkler Systems, will be installed in all new buildings, used for any occupancies, exceeding the areas in the following table.

EXCEPTION: As to occupancies noted in Section 6 of these rules and regulations, sprinkler protection shall be provided as required by said Section 6. Sprinkler protection for occupancies covered by Section 6 of this rule are required to provide sprinkler protection.

Type of Construction	BUILDING HEIGHT				
	1 Story	2 Story	More than 2 stories and up to 40 ft.	More than 40 feet	More than 75 feet
Type I					
443					
Fire Resistive	40,000	40,000	10,000	Sec.10-High Rise	Sec.10-High Rise
332					
Fire Resistive	40,000	30,000	10,000	Sec.10-High Rise	Sec.10-High Rise
Type II					
222					
Protected Non-Com.	30,000	20,000	8,000	Sec.10-High Rise	Sec.10-High Rise
111					
Protected Limited Combustible	<u>30,000</u> 20,000	15,000	5,000	Sec.10-High Rise	Sec.10-High Rise
000					
Unprotected Limited	<u>10,000</u>	<u>5,000</u>	All Areas		
Unprotected Non-Com.	7,000	4,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
Type III					
211					
Protected Ordinary	9,000	6,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
200					
Non-Protected Ordinary	7,000	4,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
Type IV					
2HH					
Heavy Timber	9,000	6,000	<u>All areas</u> 3,000	NOT PERMITTED	NOT PERMITTED
Type V					
111					
Protected Wood Frame	7,000	4,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
000					
Non-Protected Wood Frame	5,000	3,000	NOT PERMITTED	NOT PERMITTED	NOT PERMITTED

Notes to Table:

- (1) The word "area" means that area enclosed by exterior or foundation walls, fire barriers, or a combination of exterior or foundation walls. A fire barrier is a continuous vertical membrane designed and constructed with a fire resistance rating of two (2) hours to limit the spread of fire and smoke. Fire barriers shall have protected openings. Buildings shall only be separated by one two hour fire barrier and areas shall be divided as equally as possible.
- (2) The phrase "not permitted" means that buildings of these heights are not permitted for the type of construction indicated.
- (3) The phrase "Section 10-High Rise" means that the building shall also comply with Section 10 of these Rules and Regulations.
- (4) Types of building construction indicated in chart are located in NFPA 220, Standard on Types of Building Construction.
- (5) Protection of Structural members in Type I and Type II construction: Columns, girders, trusses, beams, lintels, or other structural members that are required to have a fire resistance rating and that support more than two floors or one floor and roof, or support a bearing wall or a nonbearing wall more than two stories high, shall be individually protected on all sides for their length or height with materials having the required fire resistance rating. All other structural members required to have a fire resistance rating may be protected by individual encasement, by a membrane or ceiling protection which is part of an approved assembly which meets the required fire resistance rating, or by a combination of both.

SECTION 6 Sprinkler Protection (certain occupancies)

All nursing, convalescent, old age, custodial care, and long term or extended care homes or institutions, existing and new, regardless of the type of construction, shall be provided with complete automatic sprinkler protection in accordance with Standard 13 contained within the ~~afesaid~~ National Fire Codes and incorporated by reference in Section 4.01 of this rule.

EXCEPTION: Homes caring for not more than three patients.

SECTION 7 Carpet Used As Floor Covering

7.01 Flammability Requirements for Carpet Used As Floor Covering

In institutional, health care, educational and penal occupancies, carpet shall meet a minimum value of 0.45 watts per square centimeter in all corridors and exits. Carpet in all other areas of the above shall meet a minimum value of 0.22 watts per square centimeter.

Flammability requirements for carpet used as floor covering in all other occupancies shall meet a minimum value of 0.22 watts per square centimeter in all corridors and exits.

The values shall be determined by NFPA 253, the Critical Radiant Flux of Floor Covering Systems, ~~NFPA 253~~.

7.02 Smoke Generation Properties of Carpet Used as Floor Covering.

In all occupancies smoke shall not exceed a maximum value of $D_m=450$ (flaming mode).

The value shall be determined by ASTM E-662, Specific Optical Density of Smoke Generation by Solid Materials.

All test data for determining the flammability and smoke properties of carpets shall be conducted by a nationally recognized laboratory as certified by the National Voluntary Laboratory Accreditation Program.

EXCEPTION: Where an approved, automatic sprinkler system is installed and the floor is non-combustible. Class II carpet shall be permitted in any location where Class I is required. Where an approved automatic sprinkler system is installed and the floor is non-combustible and Class II carpet is permitted, no rating is required.

SECTION 8 Maintenance of Fire Hazard; Order for Correcting Condition, Removal of Material, Repair, Demolition, etc.; Order to Contain Notice to Comply and Right to Appeal.

Whenever the State Fire Marshal, by and through persons working under his or her direction, ~~shall~~ determines (based upon the State Fire Code and/or on the experience and knowledge applied in the operation of his or her office) (1) that any building or structure has been constructed, altered, or repaired in a manner violating the State Fire Code as promulgated prior to the commencement of such construction, alterations, or repairs, or (2) that any building or structure is being maintained or used in such a way as to endanger life or property from the hazards of fire or explosion, or (3) that any building or other structure or property of any kind, which, for want of repairs, or by reason of its age, dilapidated, or abandoned condition or for any other reason constitutes a fire hazards and is located or constructed

so as to constitute a danger to other buildings, property, persons, life, or limb, or (4) that in any building or upon any premises there is located any combustible, flammable, or explosive substance or material or other condition dangerous to the safety of persons occupying the building or premises and adjacent premises and property, then the State Fire Marshal shall order such condition or thing to be corrected, or combustible, flammable or explosive, items to be removed, or such building or buildings to be repaired, closed to occupants, or removed, as required by the circumstances. ~~and~~ Such order shall be promptly complied with by the owner, agent, occupant, and lessee of such premises, place, property, or thing. Any ~~such~~ order may be expressed in the alternative, e.g. allowing repair but on the failure to repair requiring demolition. Any such order by the State Fire Marshal which concludes that a fire hazard exists, ~~shall advise~~ stating what repairs, and/or demolition, must be accomplished, ~~shall advise~~ and that compliance ~~therewith shall~~ must be completed within thirty (30) days of issuance, ~~shall advise~~ and that in the event of noncompliance, the State Fire Marshal is authorized by statute to enter into and upon the premises affected by ~~such~~ the order and cause the building, structure, premises, or thing to be repaired, torn down, materials removed, and all dangerous conditions to be remedied (as the case may be) at the expense of the owner, and shall advise that

the ~~subject~~ order can be contested by entering an appeal to the State Fire Commission as outlined in Section 13 of ~~these~~ this Rules and ~~Regulations~~.

SECTION 9 Interference with Fire Protection Equipment

No person shall render any portable or fixed fire extinguishing system or device or any fire warning system inoperative or inaccessible except as may be necessary during emergencies, maintenance, drills or prescribed testing.

SECTION 10 High Rise Buildings - Fire Safety Standards and Requirements

10.01 General - All new buildings or structures more than forty (40) feet in height, measured from the lowest grade level to the floor of the highest normally occupied space used for human occupancy of the structure, ~~shall be~~ are subject to ~~the~~ this ~~rules set forth herein~~ for high rise buildings. ~~These high rise~~ This ~~rules~~ shall not nullify or interfere with existing city high rise ordinances or local laws previously adopted prior to September 8, 1975 relative to this subject. EXCEPTION: Industrial occupancies not occupied as business offices are exempted from this section.

10.02 Addition of Floors to Existing Buildings

Whenever floors are added to an existing building, which previously was not a high rise, causing building to ~~now~~ become a high rise, ~~such~~ the building shall comply with ~~High-Rise Standard~~ this rule.

10.03 Automatic Fire Extinguishing Systems & Standpipe Systems - Any building or structure as defined in Subsections 10.01 or 10.02 and used for human occupancy shall have an approved automatic fire extinguishing system throughout the entire building and standpipe systems installed in accordance with The National Fire Codes, imposed by Section 4 of ~~these~~ this Rules ~~and Regulations.~~

10.04 Fire Alarm System - The fire alarm system shall conform to the rules imposed by Section 4 and Section 11 of ~~these~~ this Rules.

10.05 Fire Department Voice Communication System - Any high rise building or structure used for human occupancy that is seventy-five (75) feet in height or greater as measured from the lowest grade level to the floor of the highest normally occupied space used for human occupancy shall have an approved electrically supervised fire department voice communication system. The Fire Department Voice Communication System shall be located at each floor level of stair enclosures, elevator lobbies, penthouse and in any elevator designated for fire dept.use.

This system shall be a telephone jack system unless specifically approved otherwise by the designated fire authority having jurisdiction.

10.06 High Rise Central Control Station - In every High Rise as defined in Subsections 10.01 and 10.02, a central control station for Fire Department operations shall be provided in a location approved by the State Fire Marshal or the designated local fire authority. The Central Control Station shall contain: (1) the fire department voice communication system panel when required, (2) fire detection and alarm system panels, (3) status indicators for the HVAC, Smoke Control System, fire pumps and emergency generator and a (4) telephone approved by designated fire authority having jurisdiction. Emergency lighting shall be provided at the Central Control Station.

10.07 Emergency Power - A permanently installed emergency power generation system conforming to The National Fire Codes imposed by Section 4 of ~~these Rules and Regulations~~ shall be provided in every high rise building 75 feet in height or greater, as measured from the lowest grade level to the floor of the floor of the highest normally occupied space used for human occupancy.

All power, lighting, signal, and communication facilities, required by ~~these~~ this rules ~~and regulations~~ or otherwise, shall be transferable automatically to the emergency power system.

The emergency system shall be of sufficient capacity to provide service for, but not limited to, the following:

- (a) The Fire Alarm System
- (b) Exit & Other Emergency Lighting
- (c) Fire Protection Equipment
- (d) The ~~Smoke Control~~ Management System
- (e) The Fire Department Elevator
- (f) The Fire Department Voice Communication System
- (g) The Fire Pumps

10.08 ~~Smoke Control~~ Management - In all high rise buildings as defined in Subsections 10.01 and 10.02 ~~an engineered~~ a smoke ~~control~~ management system designed in accordance with NFPA 92A, Smoke-Control Systems, and 92B, Smoke Management Systems in Malls, Atria and Large Areas, shall be provided ~~as~~ and acceptable to the authority having jurisdiction.

10.09 Floor Designation - All stairway doors (both on the stairway and entrance side) shall indicate the floors by number. The number shall be at least 6" block letters in a contrasting color.

SECTION 11 Fire Alarm System

11.01 General Requirements for All Occupancies

(1) All fire alarm systems including all components shall be electrically supervised. Components shall include pull stations, automatic detection, sounding devices, flow switches, tamper switches and main panel.

(2) All fire alarm systems shall be tied in ahead of the main power disconnect, unless a secondary power source is provided.

(3) All fire alarm systems wiring shall be in accordance with The National Fire Codes, imposed by Section 4 of ~~these~~ this rules. (NOTE: NEPA 70, National Electrical Code, and NEPA 72, National Fire Alarm Code)

(4) Sprinkler System(s) installed - The OS & Y and P.I.V. and other Control Valves shall be electrically supervised and tied into the trouble side of the panel.

(5) Sprinkler System(s) shall be tied in so water flow will activate the general fire alarm sounding device(s).

(6) Flow and/or pressure switches shall be annunciated separately on the main fire alarm panel.

(7) All Health Care and Detention and Correctional occupancies shall be tied into a fire department or a com

munication center responsible for receiving emergency calls with 24-hour supervision.

(8) Heating, Ventilation, Air Conditioning Systems (HVAC)

- (a) All heating, ventilation, and air conditioning systems greater than 2000 CFM and less than 15,000 CFM shall have a duct type smoke detector in the return air duct or plenum for automatic shut down, to close main fan dampers and to sound general fire alarm when activated.
- (b) All heating, ventilation, air conditioning systems greater than 15,000 CFM shall have duct type smoke detectors installed in both supply and return air duct to automatically shut down, close main fan dampers and to sound a general fire alarm when activated.
- (c) Health Care, Detention/Correctional occupancies and high rise buildings duct detectors shall be zoned to indicate the specific air handling unit at the main fire alarm panel.
- (d) 100% utilization of outside air will not require duct detector(s).
- (e) ~~Exception to 11.01(8):~~ HVAC Systems used as part of the engineered smoke ~~control~~ management systems are exempt from ~~11.01(8)~~ this subsection.

(9) Audible alarm indicating devices shall be of such character and so distributed as to be effectively heard above the ambient noise level obtained under normal conditions of occupancy. Audible alarm indicating devices shall produce signals that are distinctive from audible signals used for other purposes in the same building.

Visual signal devices shall be provided in all new fire alarm systems.

Pre-recorded or live voice evacuation instructions to occupants are permitted. Pre-recorded instructions shall be preceded by not less than 5 seconds or more than 10 seconds of a continuous alerting signal. Upon completion or failure of pre-recorded instructions, the fire alarm evacuation signal shall sound. Pre-recorded instructions shall be repeated two or more times. Live voice instructions shall be permitted to interrupt the pre-recorded message or the fire alarm evacuation signal.

Audible and visual fire alarm devices shall be used only for fire alarm system.

(10) Manual pull stations shall be located no greater than 200 feet from each other and at all exits. Manual pull stations shall be of the same general operational type. (See specific occupancy provisions for subsections of this section for additional occupancy requirements.

(11) Thermal detectors are required in the following areas in all occupancies requiring a fire alarm system and as listed or identified in NFPA 101, The Life Safety Code (~~NFPA 101~~)*

<u>AREAS</u>	<u>TYPE OF DETECTORS</u>
(a) Elevator Shafts	Fixed Temperature
(b) Attic & Cockloft Spaces	Fixed Temperature
(c) Storage Rooms	Rate of Rise
(d) Furnace or boiler rooms	Fixed Temperature
(e) Janitor Closets	Rate of Rise
(f) Kitchens	Fixed Temperature
(g) Laboratories, Home Economics, Woodworking Shops, Auto Shops, Utility Rooms, & Locker Rooms	Rate of Rise

EXCEPTION: Thermal detectors are not required in areas provided with sprinkler protection or dwelling units of apartments.

(12) Smoke detectors are required in the following areas in all occupancies requiring fire alarm systems:

- (a) Rooms and/or areas dedicated for the location of electrical distribution panels or transformers.
- (b) Stages

Smoke detectors where required by the occupancy shall be placed a maximum of 15 feet from ends of corridors or walls and 30 feet on centers and in rooms open to the corridors. Variance with these requirements must have submission of technical data to justify exceeding these distance requirements.

(13) A building or structure being used for more than one occupancy must comply with the fire alarm system requirements of the most stringent occupancy for that building or structure.

(14) Hood suppression systems shall be connected to the Fire Alarm System.

11.02 Requirements for Educational Occupancy

(1) A fire alarm system is required in every educational occupancy, and ~~such a system~~ must meet the requirements and standards as provided ~~herein~~ in this section.

Educational occupancies are ~~as~~ defined in NEPA 101, The Life Safety Code. EXCEPTION: One or two classroom buildings of less than 2500 sq. ft. gross floor area with direct exiting to the outside from each classroom.

(2) The general requirements shall be complied with in all educational occupancies as if herein restated verbatim.

(3) Open Plan Classroom Concepts ~~will~~ require a complete smoke detection system throughout the facility.

(4) Day Care Centers located in buildings other than educational facilities shall have smoke detectors installed on the ceilings of each story in front of the doors to the stairways and at no greater than 30 feet spacing in the corridors of

all floors occupied by the center. ~~Detectors shall also be installed in lounges and recreation areas in the center.~~

(5) An annunciator panel or fire alarm panel is to be readily accessible to local fire department personnel. ~~if more than one zone is provided.~~

(6) Rate of rise thermal detectors are required in all Rest Rooms having three (3) or more fixtures.

(7) Smoke detectors shall be installed in all corridors, except in a single story building with direct exiting to the exterior from every normally student occupied room via a door.

11.03 Requirements for Assembly Occupancy

(1) A fire alarm system is required in every place of assembly where:

- (a) Occupancy is subject to 300 or more occupants, or
- (b) Occupancy is subject to 100 or more occupants above or below level of exit discharge, or
- (c) The building is two (2) or more stories in height above level of exit discharge, or two (2) or more stories below level of exit discharge.

~~Such system must meet requirements and standards as provided herein.~~

Assembly occupancies are as defined in the Life Safety Code.

(2) The General Requirements shall be complied with in all places of assembly as if herein restated verbatim.

(3) Annunciator panel and/or fire alarm panel shall be readily accessible to fire department personnel. ~~if more than one zone is provided.~~

(4) Theater(s) and auditoriums are required to provide sounding audible device(s). House lights in auditoriums and theaters shall be activated by the fire alarm system.

11.04 Requirements for Health Care Occupancy

(1) A fire alarm system is required in every Health Care occupancy, and such a system must meet the requirements and standards of this rule. ~~as provided herein.~~ Health Care occupancies are as defined in NFPA 101, The Life Safety Code.

(2) The general requirements of this rule shall be complied with in all health care occupancies as if herein restated verbatim.

~~(3) Health Care occupancies are hereinafter placed in Groups A and B and these designations then used to indicate which group or groups must comply with the stated requirement(s), as follows:~~

~~—GROUPS~~

- ~~A. Hospitals and Nursing Homes~~
- ~~B. Residential - Custodial Care, Supervisory Care, Ambulatory Health Care~~

~~REQUIREMENTS~~

- ~~A and B~~ ~~(a)~~ ~~Annunciator Panel or Fire Alarm Panel is to be readily accessible to Fire Department personnel if more than one zone is provided.~~
- ~~A and B~~ ~~(b)~~ (3) An approved automatic smoke detection system shall be installed in all corridors.
- ~~A and B~~ ~~(c)~~ (4) Manual pull stations shall be installed every 50 feet throughout the facility in patient room areas starting at the end of all corridors. All other manual pull stations shall be placed in accordance with general requirements of this rule.
- ~~(d)~~ (5) Fire alarm systems shall have annunciators located at all nurse's stations, the telephone switchboard, and at the main location of the fire department's entry.

11.05 Requirements for Detention and Correction Occupancies

(1) A fire alarm system is required in every Detention and Correctional occupancy and such a system must meet the requirements and standards as provided herein in this rule. Detention and Correction occupancies are defined in NFPA 101, The Life Safety Code.

(2) The general requirements shall be complied with in all Detention and Correctional occupancies as if herein restated verbatim.

(3) The annunciator panel or fire alarm panel is to be readily accessible to fire department personnel ~~if more than one (1) zone is provided,~~ and shall also be provided in the jail control center.

(4) Manual pull stations shall be provided as set forth in general requirements of this rule. EXCEPTION: Manual pull stations may be of security type in detention sections.

(5) Smoke detectors shall be installed in all corridors. If no corridor exists, installation shall be at the highest point of the cell area(s).

(6) Dormitory style facilities shall comply with Residential requirements.

11.06 Requirements for Residential Occupancy

(1) A fire alarm system is required for each of the herein enumerated groups of residential buildings, and such system must meet the requirements and standards provided ~~herein~~. A residential building is as defined in NFPA 101, The Life Safety Code.

(2) These general requirements shall be complied with in all residential occupancies as if herein restated verbatim.

(3) Residential occupancies are ~~hereinafter~~ placed designated in two Groups, A and B. and These designations

~~or groups then used to indicate which group or groups~~ must comply with the stated requirements, as follows:

GROUPS

- A. Hotel/Motels, Dormitories, Lodging and Rooming Houses
- B. Apartments

REQUIREMENTS

- A. (Hotels/Motels/Lodging or Rooming and/or Boarding Houses, Dormitories)
 - (1) Smoke detectors shall be placed a maximum of 15 feet from ends of corridors or walls and located 30 feet on centers throughout all inside corridors. Smoke detectors shall be placed a maximum of 15 feet from ends of walls and 30 feet on centers in open bay sleeping areas.
 - (2) The annunciator panel or fire alarm panel shall be readily accessible to fire department personnel if more than one (1) zone is provided, and also shall be located at the registration desk.
 - (3) All sleeping rooms shall have an approved self-contained smoke detector(s) hard-wired in accordance with NFPA 74, Household Fire Warning Equipment.
 - (4) Motel(s)/Hotel(s) having direct exterior exiting shall have manual pull station(s) every 75 feet located on exterior walls. (Minimum requirement shall be one).
- B. Apartments
 - (1) Apartment buildings having 12 or more units or 4 or more stories in height shall have fire alarm systems. Smoke detectors shall be placed a maximum of 15 feet from the ends of corridors and walls and 30 feet on centers.

- (2) All existing apartments shall have approved self-contained smoke detector(s) located at entrance(s) to bedrooms.
- (3) All new apartments shall have an approved self-contained smoke detector(s) hard wired in accordance with NFPA 74, Household Fire Warning Equipment.

11.07 Requirements for Mercantile Occupancy

(1) A fire alarm system is required in every mercantile occupancy over 3,000 square feet, and such system must meet the requirements and standards as provided herein. Mercantile occupancies are as defined in NFPA 101, the Life Safety Code.

(2) The general requirements will be complied with in all mercantile occupancies as if herein restated verbatim.

(3) If an ~~the~~ existing Class B mercantile occupancy has a complete and approved sprinkler protection system, a fire alarm system will not be required.

11.08 Requirements for Business Occupancy

(1) A fire alarm system is required in every business occupancy where:

- (a) Occupancy is subject to 300 or more total occupants, or
- (b) Occupancy is subject to 100 or more occupants above or below level of exit discharge, or

- (c) Building two (2) or more stories
in height above level of exit
discharge or two (2) or more
stories below the level of exit
discharge.

~~Such system must meet requirements and standards
as provided herein.~~

Business occupancy are ~~as~~ is defined in NFPA 101,
The Life Safety Code.

(2) The general requirements shall be com-
plied with in all business occupancies as if herein restated ver-
batim.

11.09 Requirements for Industrial Occupancy

A fire alarm system is required in all Indus-
trial Occupancies as required in The National Fire Codes (NFPA
101, Life Safety Code) referred to in Section 4 of this ~~these~~
rules.

11.10 Requirements for Storage Occupancy

A fire alarm system is required in all Stor-
age Occupancies as required in The National Fire Codes (NFPA 101,
Life Safety Code) referred to in Section 4 of this ~~these~~ rules.

SECTION 12 Exit Inspections and Public Life Safety Announcements

12.01 Inspection of Exits. Not more than ninety (90)
minutes prior to the scheduled commencement of any noncontinuous

activity, event, performance, show, meeting, function, or other occasion for which persons will gather at a Class A or B place of assembly (as defined in ~~the 1981 edition of~~ NFPA 101, The Life Safety Code -- ~~NFPA No. 101~~) the owner (or his or her designee pursuant to written authority, instructions, or procedures) shall inspect every required exit, way of approach thereto, and way of departure therefrom. If such inspection reveals that any required means of egress is obstructed, inaccessible, locked, fastened, or otherwise unsuited for immediate use, the scheduled program shall not begin, nor shall admittance to the place of assembly be permitted, until necessary corrective action has been completed.

12.02 Announcements. Immediately prior to the start of ~~a the~~ program, the owner or his or her authorized agent shall orally notify all attendees concerning the location of the exit(s) to be used in case of fire or other emergency.

12.03 Records. Accurate record of all inspections, corrections, and notifications made pursuant to this chapter shall be kept and retained for at least two (2) years in the offices of the respective building owners. The records shall contain:

(a) A brief description of each activity, event, performance, etc., including date, time, and location;

(b) the name and signature of the person who performed each requirement of this chapter; and

(c) the date and time when each requirement was performed.

12.04 Alternatives. In cases of practical difficulty or undue hardship, or in which compliance ~~herewith~~ would not significantly increase life safety, the State Fire Marshal may approve or accept alternative means of accomplishing the objectives of this section.

SECTION 13. Orders ~~of~~ and Decisions of the State Fire Marshal; and Appeals and Procedure for Appeals from such Orders or Decisions.

Any person aggrieved by an order or final written decision of the State Fire Marshal based upon or made in the course of the administration or enforcement of the provisions of W.Va. Code Chapter 29, Article 3-1 et seq. or ~~based upon or~~ made pursuant to these rules, and desiring to contest such order or written decision may file an appeal from such order or written decision with the State Fire Commission. Preservation of the right to an appeal and the procedure for the contested case is governed by this section and by W. V. Code Chapter 29, Article 3, et. seq. and ~~W. V. Code, Chapter 29A.~~

13.01 State Fire Marshal's Order and Decisions are Final and Conclusive - Any order or final written decision of the State Fire Marshal based upon or made in the course of the administration or enforcement of the provisions of W.V. Code, Chapter

29, Article 3-1 et seq. or based upon or made pursuant to these this rules is final, unless vacated or modified upon review pursuant to the appeal rights and procedures provided by Chapter 29A the official Code of the W.V. Code and this rule.

13.02 W. V. Code 29-3-12(g) and (i) Inquiry and Investigation - The testimony which may be obtained by the State Fire Marshal pursuant to the authority in W.V. Code 29-3-12(g) and (i) shall be obtained without compliance with the provisions in these rules governing "Procedure in Contested Cases." Where appropriate, a subsequent order by the State Fire Marshal relating to the testimony so obtained shall, the same as any other order by the State Fire Marshal, be subject to the appeal rights provided in W. V. Code Chapter 29, Article 3-1, et. seq.

13.03 Appeal Petition - The appeal petition is to be typewritten, styled "Appeal Petition", and submitted with an original and one (1) copy. It shall be complete in itself so as to fully state the matters contested. No telegram, telephone call, or similar communication will be regarded as an appeal petition. The petition shall contain and include the following:

(A) a copy of the order or decision of the State Fire Marshal being contested;

(B) a clear and concise assignment of each error which the petitioner alleges to have been committed by the State

Fire Marshal in issuing said order or decision with each assignment of error being shown in separately numbered paragraphs;

(C) a clear and concise statement of fact upon which the petitioner relies as sustaining his assignment of errors;

(D) the address petitioner desires to have all notices, documents, and the final order of the State Fire Commission mailed to;

(E) the telephone number or numbers where petitioner can be contacted;

(F) the names and addresses of all persons having any ownership interest in the property which is the subject of the State Fire Marshal's order being contested;

(G) a prayer setting forth the relief sought; and

(H) the signature of the petitioner or its duly authorized officer.

13.04 Time Requirement and Manner of Filing Appeal Petition - An appeal petition must be personally delivered or mailed to the State Fire ~~Administrator~~ Commission within thirty (30) days following service upon the petitioner, or within thirty (30) days following actual receipt if service is ~~be~~ not required or for some reason is not made of the order or decision being con- tested. Any appeal petition shall be sent by certified mail, return receipt requested, and ~~are~~ timely if postmarked

within the thirty (30) day period. Any appeal petition not delivered or mailed within the thirty (30) day period is not timely filed and the order or decision of the State Fire Marshal being contested is final.

13.05 Copy of Appeal Petition to State Fire Commission - Upon receipt of an appeal petition, the State Fire ~~Administra-
ter~~ Commission shall ~~forthwith~~ supply a copy of the petition to the State Fire Commission together with an opinion by the State Fire Marshal regarding the urgency of the matter being contested. If The State Fire Marshal elects to file a response to the appeal petition, he or she shall be delivered a copy of the response to the State Fire Commission and a copy to the petitioner.

13.06 Scheduling Appeal Petition for and Notice of Hearing - The State Fire Commission through the State Fire ~~Admin-
istrator~~ Marshal shall schedule a hearing on the appeal petition giving the petitioner and the State Fire Marshal at least ten (10) days written notice of the date, time, and place of the hearing. The notice to the petitioner shall be by personal delivery or by certified mail, return receipt requested, shall contain a short and plain statement of the matters to be considered at the hearing, ~~shall contain~~ a copy of the State Fire Marshal's response, if any, to the appeal petition, and shall be mailed or personally delivered by the State Fire ~~Administrator~~ Commission Marshal no later than thirty (30) days after receipt e

of the appeal petition. A copy of the notice to the petitioner shall be supplied to the State Fire Marshal. The ~~Any~~ hearing ~~shall~~ is to be conducted at a designated location at the State Capitol in in Charleston, West Virginia, or in the discretion of the State Fire Commission at a location within the county where the premises in question are located.

13.07 Authorized Representative - The petitioner may appear individually, or by counsel.

13.08 Continuances - A motion for continuance shall not be granted unless made in writing three days before the hearing or during the hearing, in either case for good and sufficient cause. Upon consideration of a motion for continuance, the urgency of the situation shall be determined and taken into consideration. Conflicting engagements of counsel or the employment of new counsel are not good grounds for a continuance, unless set forth in a motion filed promptly after the notice of hearing has been mailed, or unless extenuating circumstances are shown, which the State Fire Commission or hearing examiner considers adequate.

13.09 Absence of Petitioner or Counsel at the Scheduled Hearing - A hearing shall not be delayed or continued due to the absence of the petitioner or his legal counsel at a hearing, after service of notice of time, date, and place. The hearing shall proceed and the case shall be submitted for decision on the part of the absent petitioner or petitioners.

13.10 Hearing Examiner - Any member of the State Fire Commission may conduct a hearing on an appeal petition, ~~issue subpoenas and subpoenas duces tecum,~~ and shall have full authority to conduct the proceedings on an appeal petition, and when acting in such capacity shall be referred to as the hearing examiner. Alternatively, the State Fire Commission may authorize and empower an impartial attorney as a hearing examiner with the specific powers listed in W. V. Code 29A-5-1(d).

13.11 Subpoenas and Subpoenas Duces Tecum - At any hearing held hereunder, the testimony of witnesses and the production of documentary evidence may be required through the use of subpoenas and subpoenas duces tecum. ~~Such subpoenas or subpoenas duces tecum may be issued at the request of the petitioner the State Fire Marshal, or of The State Fire Commission and shall be issued by and in the name of the State Fire Commission.~~ The State Fire Marshal may issue subpoenas and subpoenas duces tecum at the request of the petitioner, the hearings examiner, or the State Fire Commission.

Every such subpoena and/or subpoena duces tecum is required to prove service at least five (5) days before the return date thereof, either by personal service made by any person eighteen (18) years of age, or older, or by registered or certified mail, but a return acknowledgement signed by the person

to whom the subpoena or subpoena duces tecum is directed shall be required to prove service by registered or certified mail.

Any party requesting a subpoena or subpoena duces tecum must see that it is properly served. Service of a subpoena or subpoena duces tecum issued at the insistence of the State Fire Commission is the responsibility of such Commission.

Any public official who serves any such subpoena or subpoena duces tecum shall be entitled to the same fee as a Sheriff who serves a witness subpoena for a circuit court of this state; and fees for the attendance and travel of witnesses shall be the same as for witnesses before the circuit courts of this state. All fees shall be paid by the State Fire Commission if the subpoena or subpoena duces tecum is issued at the instance of the Commission. All such fees related to any subpoena or subpoena duces tecum issued at the instance of the petitioner or the State Fire Marshal shall be paid by the party requesting such subpoena or subpoena duces tecum.

A request for a subpoena or subpoena duces tecum shall be in writing and shall contain a statement acknowledging that the requesting party agrees to pay the required fee.

Any person receiving a subpoena or subpoena duces tecum issued hereunder shall honor the same as though it were issued by a circuit court of the state, and shall appear as a witness and/or produce such books, records, or papers in response to

such subpoena or subpoena duces tecum. In case of disobedience or neglect of any subpoena or subpoena duces tecum served on any person or the refusal of any witness to testify to any matter regarding which he or she may be lawfully interrogated, the circuit court of the county in which the hearing is being held, upon application by the State Fire Commission, shall compel obedience by attachment proceedings for contempt as in the case of disobedience of the requirements of a subpoena or subpoena duces tecum issued from such circuit court or a refusal to testify therein.

13.12 Evidence -

(A) All witnesses appearing at such hearing shall testify under oath or affirmation. Every adverse party shall have the right of cross-examination of witnesses who testify, and shall have the right to submit rebuttal evidence.

(B) All relevant and material evidence, including papers, records, agency staff memoranda and documents in the possession of the State Fire Commission or the State Fire Marshal of which either party desires to avail himself, may be offered and made a part of the record in the case.

(C) Irrelevant, immaterial, or unduly repetitious evidence shall be excluded. Except as otherwise herein stated, the rules of evidence as applied in civil cases in the circuit courts of this state shall be followed in considering the admissibility of evidence. However, when necessary to

ascertain facts not reasonably susceptible of proof under those rules, reasonably authenticated evidence not admissible thereunder may be admitted, except where precluded by the official code of W.V. or privilege, if it is of a type commonly relied upon by reasonably prudent persons ~~men~~ in the conduct of their affairs.

13.13 Record of Proceedings - All of the testimony, evidence and rulings on admissibility of evidence at any such hearing shall be recorded by a certified court reporter. An official record of the hearing will be prepared by the State Fire Commission, but a transcript, shall only be prepared if this Commission's final decision is appealed. The cost of the transcript shall be paid by the party requesting it.

13.14 Informal Disposition - At any stage of the proceedings, informal disposition may be made of any contested case by stipulation, agreed settlement, consent order, or default.

13.15 Decision by the State Fire Commission - Upon the conclusion of the hearing, the person designated by the State Fire Commission as hearing examiner shall prepare a decision supported by findings of fact and conclusions of law affirming, modifying, or vacating the earlier order of decision of the State Fire Marshal. The State Fire Commission may either accept, modify, or reject the hearing examiner's decision. If the

Commission accepts the hearing examiner's decision it shall sign the decision. If the Commission rejects or modifies the hearing examiner's decision, it shall prepare a written decision setting forth findings of facts and conclusions of law. In either event, the order signed by the State Fire Commission shall be final unless vacated or modified upon judicial review thereof. A copy of the order shall be served on all parties to the hearing and all attorneys of record, if any, in person or by certified mail, return receipt requested.

13.16 Judicial Review - The petitioner or by the State Fire Marshal may appeal the Commission's decision to the circuit court of the county where the premises are located, if the appeal is filed within thirty (30) days after the date upon which party was served with a copy of the final order or decision of the State Fire Commission. The final order signed by the State Fire Commission is final if the proceedings for judicial review are not instituted within the said thirty (30) day period.

Section 14 Miscellaneous Provisions

14.01 FOREST FIRE SEASON:

The periods of each year between March first and May thirty-first, inclusive, and October first and December thirty-first, inclusive, are hereby designated as forest fire seasons. No person shall during any such fire season, except between the

hours of four o'clock p.m. and seven o'clock a.m. prevailing time, set fire to, or procure another to set fire to, any brush, leaves, grass, debris or field containing dry grass or other inflammable material capable of spreading fire, located in or within 300 feet of any woodland, brushland, or field containing dry grass or other inflammable material. Any fire set during this time shall be extinguished prior to seven o'clock a.m. prevailing time. Such prohibition of fires between seven o'clock a.m. and four o'clock p.m. prevailing time does not include (1) small fires set for the purpose of food preparation, or providing light or warmth around which all grass, brush, stubble, or other debris has been removed for a distance of ten feet from the fire, and (2) burning which may be conducted at any time when the ground surrounding the burning site is covered by one inch or more of snow. Any person who sets or causes to be set any fire permitted by this section shall not leave such fire unattended for any period of time.

Provided that the State Fire Marshal may issue permits authorizing fires prohibited by the preceding paragraph in accordance with West Virginia State Code, Chapter 20, Article 3, Section 5 of the West Virginia Code.

14.02 EXECUTIVE ORDER BY THE GOVERNOR ON OPEN BURNING

On such occasions when the Governor of the State issues an Executive Order or Proclamation to ban open burning due to weather conditions, the fire marshal may assist in the enforcement of the provisions of the Proclamation or Executive Order.

14.03 OUTDOOR STORAGE OF USED TIRES

The storage of used tires shall comply with the following:

(1) All outdoor storage of used tires shall be free from all trash and debris within the site.

(2) The owners/operators of outdoor storage of used tires shall maintain controlled access to the property with only one entrance/exit, and ~~shall~~ install security lighting for use during evening and night time hours as designated by the State Fire Marshal.

(3) All outdoor storage of used tires shall have a perimeter security chain link fence of a minimum height of six feet.

(4) All storage of used tires, shredded or unshredded, shall be separated into individual piles on the property. No pile may exceed 50 feet by 50 feet by 15 feet in height.

(5) In the absence of an available water supply of at least 500 GPM (gallons per minute) provided by fire hydrants within

1000 feet of the facility, a minimum of 10,000 thousand gallon water supply on the site for exclusive use of fire fighting personnel shall be established.

(6) Fire lanes shall be established between all tire piles and maintained having a minimum of forty-five foot lanes capable of supporting fire apparatus. ~~and shall exist between all tire piles.~~

(7) A minimum of a fifty foot wide zone around the site perimeter inside the fence line shall be maintained.

(8) All storage piles shall have a minimum of a thirty inch high earthen dike around each tire pile as the piles are established.

(9) A maximum of eighteen tire piles may be established on a single site.

(10) No site may exceed the storage of more than three hundred thousand tires without the approval of the state fire marshal.

14.04 FIREWORKS DEFINED; LABELS REQUIRED (29-3-23)

The term "fireworks" means and includes any combustible or explosive composition, or any substance or combination of substances, or article prepared for the purpose of producing a visible or an audible effect by combustion, explosion, deflagration or detonation, and includes blank cartridges, toy pistols,

toy cannons, toy canes or toy guns in which explosives are used, the type of unmanned balloons which require Fire underneath to propel the same, firecrackers, torpedoes, skyrockets, roman candles, daygo bombs, sparklers or other fireworks of like construction and any fireworks containing any explosive or flammable compound, or any tablets or other device containing any explosive substance, except that the term "fireworks" shall not include model rockets and model rocket engines, designed, sold and used for the purpose of propelling recoverable acro models and shall not include toy pistols, toy canes, toy guns or other devices in which paper or plastic caps manufactured in accordance with the United States department of transportation regulations for packing and shipping of toy paper or plastic caps are used and toy paper or plastic caps manufactured as provided therein, the sale and use of which shall be permitted at all times. Each package containing toy paper or plastic caps offered for retail sale shall be labeled to indicate the maximum explosive content per cap.

14.05 UNLAWFUL SALE, POSSESSION OR USE OF FIREWORKS; PERMIT FOR PUBLIC DISPLAY (29-3-24)

Except as hereinafter provided, no person, firm, co-partnership or corporation shall offer for sale, possess, expose for

sale, sell at retail, keep with intent to sell at retail, or use or explode any fireworks. The granting of permits for supervised displays of fireworks by municipalities, fair associations, amusement parks, and other organizations or groups of individuals shall be in accordance with the National Fire Codes as adopted in Section 4 of this State Fire Code. The state fire marshal shall have the authority to charge a fee of ten dollars to each applicant requesting a license to be a pyrotechnic operator as set forth in this article. The state fire marshal shall charge a scaled fee for all applications requesting permits to establish a pyrotechnics display as provided in this section. All fees (as provided in ~~Rules and Regulations~~, Fees for Services Rendered, Series 5) required to be paid by the provisions of this section shall be paid to the state fire marshal and thereafter deposited by him into a special account for the operation of the state fire commission. Such permits may be granted upon application to said state fire marshal and after approval of the local police and fire authorities of the community wherein the display is proposed to be held as provided herein and the filing of a bond by the applicant as provided hereinafter. Every such display shall be handled by a competent operator licensed or certified as to competency (as provided by National Codes as adopted in Section 4 of this State Fire Code) by the state fire marshal and shall be

of such composition, character, and so located, discharged or fired as in the opinion of the chief of the fire department, after proper inspection, and of the chief of police as to not be hazardous to property or endanger any person or persons. After such privilege shall have been granted, sales, possessions, use and distribution of fireworks for such display shall be lawful for that purpose only. No permit granted hereunder shall be transferable.

The governing body or chief executive authority of the municipality shall require a bond from the licensee in a sum not less than one thousand dollars conditioned on compliance with the provisions of this article and the rules of the state fire commission, provided no municipality shall be required to file such bond.

Before any permit for a pyrotechnic display shall be issued, the person, firm or corporation making application therefor shall furnish proof of financial responsibility (as provided by National Codes as adopted in Section 4 of this ~~State Fire Code~~ rule) to satisfy claims for damages to property or personal injuries arising out of any act or omission on the part of such person, firm or corporation or any agent or employee thereof, in such amount, character and form as the state fire marshal determines to be necessary for the protection of the public.

14.06 Necessity of License for Electrical Work

No electrical work may be performed, offered or engaged in for compensation or hire within the state of West Virginia by any person, unless such person possesses a valid license issued by the state fire marshal in accordance with Chapter 29, Article 3B of the West Virginia Code. (29-3B-2)

14.07 Residential Board and Care Occupancies

Application: All facilities classified as residential board and care occupancies shall conform to the following requirements.

Definitions:

Residential Board and Care Occupancy. A building or part of a building used to provide lodging, boarding, and personal care services for four (4) up to and including ~~eight (8)~~ ten (10) residents unrelated by blood or marriage to its owners or operators.

Personal Care. "Personal Care" means protective care of a resident who does not require chronic or convalescent medical or nursing care. Personal care involves responsibility for the safety of the resident when in the building. Protective care may include a daily awareness by the management of the resident's functioning and his or her whereabouts, the arrangement of appointments and reminders of appointments for a resident, the ability and readiness to intervene if a crisis arises for a resident, supervision in areas of nutrition and medication, and actual provision of transient medical care.

Self-preservation. A person is capable of removing his or her physical self from situations involving imminent danger, such as fire.

Other definitions applicable to these requirements can be found in NFPA 101, Life Safety Code, ~~Chapter 3, 1988 edition.~~

Requirements:

- (1) All residents shall be capable of self-preservation.
- (2) Minimum Construction Required: No Requirements.
- (3) Height Requirements: Patient sleeping rooms to be located on first and second floors only.
- (4) Means of Egress: At least two (2) remote approved from each floor; at least one (1) of which shall be a door directly to the outside without traversing any corridor or space exposed to an unprotected vertical opening.
- (5) Vertical Openings: Shall be properly enclosed on at least one (1) level unless used as the primary means of egress, then shall be enclosed at both all levels with 1 hour fire rated construction.
- (6) Doors: Shall be side-hinged swinging at least 32 inches wide when located in means of egress. Bathroom doors may be 24 inches wide.
- (7) Stairs: Shall be at least Class B.
- (8) Hazardous Areas: Shall be provided with one hour fire-rated separation or provided with automatic sprinkler protection and smoke tight.
- (9) Interior Finish: Walls and ceilings shall be at least Class C throughout.
- (10) Fire Alarm: (a) Shall be approved electrically supervised and meet State Fire Code requirements for Residential: Rooming/Lodging.

(b) Individual sleeping rooms shall be provided with a single station smoke detectors hardwired in accordance with NFPA 74, Household Fire Warning Equipment.

Exception: This rule does not apply to facilities with less than four (4) residents.
- (11). Sprinkler: Automatic sprinkler system is required and shall meet NFPA 13D, Sprinkler Systems in One- and Two-Family Dwellings.

Exception: This rule does not apply to facilities with less than four (4) residents.

(12) Corridor Walls: Shall be at least twenty (20) minute fire-rated and smoketight.

(13) Corridor Doors: Shall be provided with self-closing devices or automatic closers. Shall be provided with latches suitable for keeping the door closed.

(14) Electrical System: Shall meet National Electric Code.

(15) Each sleeping room shall be provided with at least one (1) outside window for rescue/ventilation.

(16) Any carpet located in the facility shall meet State Fire Code for Residential Occupancies.

(17) No door in any means of egress shall be locked against egress when the building is occupied.

(18) Every bathroom door lock shall be designed to permit opening of the locked door from the outside in an emergency.

(19) Every closet door latch shall be such that it can be readily opened from the inside in case of emergency.

(20) Heating, ventilating, and air conditioning equipment shall comply with the provisions of NFPA 101 Sections 7-2.1 and 7-2.2 ~~1988 Edition.~~

(21) No stove or combustion heater shall be so located as to block escape in case of fire arising from malfunction of the stove or heater.

(22) All facilities shall comply with the Life Safety Code, Chapter 31, Section 7, Operating Features.

14.08 Storage of Fireworks Wholesale Distributors

Definitions: Facility shall mean any building, igloo, barn, trailer, semitrailer or other mobile property.

Storage of Fireworks: All new and existing storage facilities for interstate wholesale fireworks distribution in accordance with West Virginia Code 29-3-25 shall meet the following requirements:

(1) Each Storage facility shall be fire resistive construction.

(2) Each Storage facility containing 1000 pounds or more shall have a complete automatic sprinkler system installed in accordance with NFPA 13, Installation of Sprinkler Systems.

(3) Each Storage facility shall not be located within a residential area.

(4) Each Storage facility shall not be located within 2000 feet of any assembly, educational, health care or correctional occupancies.

(5) Storage/Sale Permits shall be issued by the State Fire Marshal's Office. Permits will be issued only upon verified compliance of these rules and payment of required fee.

(6) Owner(s) or Operator(s) shall immediately notify State Fire Marshal's Office of any lost, stolen or unaccounted fireworks within 24 hours.

(7) No Smoking shall be permitted in the facility or within 50' of a facility. Conspicuous signs indicating "Warning - No Smoking" shall be posted at frequent intervals throughout the facility.

(8) No fireworks shall be sold to any West Virginia resident.

(9) A fire alarm system with complete smoke detection shall be installed throughout the facility in accordance with the State Fire Code.

(10) Each facility shall meet the requirements of the State Fire Code.

(11) Each display area shall contain only inert fireworks and be secured to prevent unauthorized access to the display area.

(12) All sales shall be recorded and shall include the name, address, city, state and zip code, business license number and tax department number of each purchase.

(13) Daily inventory of fireworks shall be maintained for each facility.

(14) All fireworks transported by vehicle from a distribution facility shall be placarded in accordance with U. S. DOT requirements. Less than 1000 pounds shall be placarded Class C Explosives. More than 1000 pounds shall be placarded Class B Explosives. Each vehicle used to transport fireworks shall meet Chapter 5 of NFPA 1124, Code for the Manufacture, Transportation and Storage of Fireworks.

(15) Each Fire Department providing emergency services to any facility shall be notified in writing of the existence of the storage facility including information as to the type of explosives and explosive hazards. Pre-fire planning shall be completed by the fire department prior to operating the facility.

(16) The land surrounding each facility shall be kept clear of combustibles for a distance of at least 25 feet on all sides.

(17) Each storage facility shall be securely locked in accordance with NFPA 495, Explosive Material Code, Chapter 6-6.1(g).

(18) All electrical wiring and fixtures shall be in accordance with the National Electrical Code, Class II, Group E, Division I locations (Article 502 of the National Electrical Code).

(19) All Heating, Ventilation and Air Conditioning shall be in accordance with the State Fire Code. No open flaming devices on heating units shall be permitted.

(20) Each facility shall be separated from inhabited buildings, passenger railways, public highways and other storage buildings according to the distance specified in Table 2-6.5 of NFPA 1124, Code for the Manufacture, Transportation and Storage of Fireworks. (See items 3 and 4 of these this rule for prohibited locations).

14.09 Stopping, Standing or Parking Prohibited in Specified Areas.

(a) No person shall stop, stand, or park a vehicle, except when necessary to avoid conflict with other traffic or in compliance with law or the directions of a police officer or traffic-control device, in any of the following places:

- (4) Within fifteen feet of a fire hydrant;
- (10) Within twenty feet of the driveway entrance to any fire station and on the side of a street opposite the entrance to any fire station within seventy-five feet of said entrance (when properly sign-posted) (17C-13-3).

14.10 ~~Passengers on Running Boards~~

~~No person shall ride nor shall the operator permit any person to ride on the running boards of any fire apparatus while such vehicle is being operated on the streets or highways of this State. Exception: Parades~~

14.10 Crossing Fire Hose

No streetcar or vehicle shall be driven over any unprotected hose of a fire department when laid down on any street, private driveway, or streetcar track, to be used at any fire or alarm of fire, without the consent of the fire department official in command.

14.11 Emergency Vehicle Permits

(a) Authorization for all fire department vehicles and firefighters to operate Class A vehicles shall be designated by their fire chief and the State Fire Marshal's Office. Vehicles authorized by 17C-15-26 shall have red flashing warning lights and an audible signaling device, such as a siren, whistle or bell capable of emitting sound audible from a distance of not less than 500 feet. (17C-9-5 and 17C-15-26)

(b) Upon receipt of written notification from the Fire Chief of the local fire department to the State Fire Marshal requesting that an Emergency Vehicle Permit be revoked, the State Fire Marshal shall cause the permit to be revoked.

14.12 Correctional/Detention Facilities

All new correctional or detention facilities as defined in the Life Safety Code shall be protected throughout with a complete automatic sprinkler system in accordance with NFPA-13, Standard for Sprinkler Systems.

14.13 Rural Health Care and Birthing Center Facilities

Definitions:

Primary Care: Medical care and services at the point when a person first seeks assistance from the health care system for the simpler and more common illnesses, and which takes ongoing responsibility for the recipient's health maintenance and illness.

Rural Health Initiative/Kellogg Clinical Facility: A health care facility which provides primary or secondary patient care and, as such, must meet the requirements for the safety of all occupants while in the building emergency patient treatment/stabilization.

Birthing/Non-Ambulatory Facility Center: A health care facility which provides obstetrical/emergency patient care for three or less patients that are not capable of taking action for self-preservation under emergency conditions without assistance. A facility which provides patient care for three or more patients requires compliance with Life Safety Code, Ambulatory Health Care.

Secondary Care: Medical care and services provided by medical specialists/subspecialists, by cardiologists or neurosurgeons, usually upon referral or consultation.

Self-Preservation: Patients and other occupants of the facility must be capable of removing themselves from the facility with limited assistance, either physical or verbal, in an emergency, such as fire.

Minimum Construction Requirements

A. No new facility shall be constructed of unprotected wood frame construction (Type V (000)).

B. New construction shall meet Section 5 of this rule.

C. Existing unprotected wood frame construction (Type V (000)) will be accepted with a fully automatic sprinkler system installed in accordance with NFPA 13, Standard for the

Installation of Sprinkler Systems.

Automatic Sprinkler Systems

Design and installation shall be in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems.

Occupant Load:

Occupant load calculation will be one person per 100 square feet of gross floor area.

A. No birthing/non-ambulatory care rooms will be located above or below the level of exit discharge.

B. There will be no more than 3 birthing/non-ambulatory care patients in any one facility.

Means of Egress Requirements:

Every aisle, passageway, corridor, exit discharge, exit location, and access shall be in accordance with NFPA 101, Life Safety Code, Means of Egress Requirements, and as modified by this rule.

Number of Exits:

There shall be not less than two remote exits provided from each floor.

Corridors:

A. No dead end corridor shall exceed 20 feet.

B. Travel distance to an exit shall not exceed 150 feet in a nonsprinklered building or 200 feet in a sprinklered building.

Corridor Construction:

Corridors shall be of smoke tight construction.

Corridor Width:

A. All corridors on birthing/non-ambulatory care floors shall be a minimum of 6 feet in clear width.

B. All other corridors shall be a minimum of 44 inches.

Doors in the Means of Egress:

A. Shall be a minimum of 36 inches in width and comply with NFPA 101, Life Safety Code, Means of Egress Requirements.

B. All exit doors shall be equipped with panic hardware.

Exit Stairs:

Stairs will be designed in accordance with NFPA 101, Life Safety Code, Means of Egress Requirements for Stairs.

Doors:

Doors not in the means of egress shall comply with NFPA 101, Life Safety Code, Means of Egress Components.

Protection:

A. Vertical Openings: All openings will comply with NFPA 101, Life Safety Code, Vertical Openings Requirements.

B. Hazardous Areas:

1. All hazardous areas shall be separated by one hour fire resistive construction with openings protected with one hour fire resistive assemblies or shall be protected with an automatic sprinkler system and construction that resists the passage of smoke.

2. Anesthetizing locations and laboratories shall be protected in accordance with NFPA 99, Standard for Health Care Facilities.

C. Interior Finish:

Interior finish throughout the building will be Class A. Where an approved automatic sprinkler system is installed, Class B or C is acceptable.

D. Carpet:

All carpet will have a critical radiant flux minimum of 0.45 watts per square centimeter.

E. Fire Alarm:

1. The fire alarm system will comply with Section 11.01 and 11.04 of this rule. EXCEPTION: The fire alarm system is not required to be connected to a communication center.

F. Building Services:

Building services will comply with NFPA 101, Life Safety Code, Building Service and Fire Protection Equipment Requirements.

G. Rescue and Ventilation:

All birthing/non-ambulatory and sleeping rooms for health care providers will have at least one outside window for emergency rescue and ventilation. The window shall provide a clear opening of not less than 20 inches in width, 24 inches in height and 5.7 square feet in area. The bottom of these window openings will be no more than 44 inches above the floor.

H. Separation Requirements:

When a rural health facility is located within a building having more than one occupancy, the rural health facility will be separated from all other occupancies with a two (2) hour fire barrier, or the building will be completely protected with an automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler System.

14.14 Explosives Amendment to NFPA 495, Explosive Materials Code

- a. As soon as practical after all loaded blast holes (shot) are linked, they shall be immediately connected to a source of ignition and fired by a person legally permitted to do so.
- b. Pre-loading blast holes (shots) to be fired at a later time shall be prohibited. In an emergency situation, this requirement may be waived by the State Fire Marshal.

SECTION 15. Severability

The sections this rule are severable. Should any section be declared by judicial opinion unconstitutional or in any manner contrary to the laws of the State of West Virginia, that particular section shall be invalid and all other sections shall remain in full force and effect.



FILED

Oct 11 10 41 AM '94

West Virginia Legislature
Legislative Rule-Making Review Committee

OFFICE OF WEST VIRGINIA
SECRETARY OF STATE

Room M-152, State Capitol
Charleston, West Virginia 25305
(304) 340-3286

Senator Joe Manchin, III, Co-Chair
Delegate Brian A. Gallagher, Co-Chair

October 4, 1994

Debra A. Graham, Counsel
Marie Nickerson, Admr. Assistant

NOTICE OF ACTION TAKEN BY LEGISLATIVE RULE-MAKING REVIEW COMMITTEE

TO: Ken Hechler, Secretary of State, State Register

TO: Mr. Bill Spencer, Chairman
State Fire Commission
State Capitol
Charleston, WV 25305

FROM: Legislative Rule-Making Review Committee

PROPOSED RULE: State Fire Code

The Legislative Rule-Making Review Committee recommends that the West Virginia Legislature:

1. Authorize the agency to promulgate the Legislative Rule
 - (a) as originally filed _____
 - (b) as modified by the agency X
2. Authorize the agency to promulgate part of the Legislative rule; a statement of reasons for such recommendation is attached. _____
3. Authorize the agency to promulgate the Legislative rule with certain amendments; amendments and a statement of reasons for such recommendation is attached. _____
4. Authorize the agency to promulgate the Legislative rule as modified with certain amendments; amendments and a statement of reasons for such recommendation is attached. _____
5. Recommends that the rule be withdrawn; a statement of reasons for such recommendation is attached. _____

Pursuant to Code 29A-3-11(c), this notice has been filed in the State Register and with the agency proposing the rule.

cc: Walter Smittle III