

WEST VIRGINIA LEGISLATIVE RULES
BOARD OF HEALTH

Control Tests and Operating Records of
Sewage Treatment Plants Serving
Public Sewerage Systems

WEST VIRGINIA LEGISLATIVE RULES
BOARD OF HEALTH

Control Tests and Operating Records of
Sewage Treatment Plants Serving
Public Sewerage Systems

Chapter 16-1
Series XXIX
(1983)

INDEX

	Page
Section 1. General	1
Section 2. Application and Enforcement	1
Section 3. Control Tests and Operating Records	2

WEST VIRGINIA LEGISLATIVE RULES
BOARD OF HEALTH

Chapter 16-1
Series XXIX
(1983)

Subject: Control Tests and Operating Records of Sewage Treatment
Plants Serving Public Sewerage Systems

Section 1. General

1.1. Scope - These legislative rules establish the control tests and operating records for sewage treatment plants.

1.2. Authority - These legislative rules are issued under the authority of and are related to Chapter 16, Article 1, Section 7 of the West Virginia Code of 1931 as amended.

1.3. Filing Date - These legislative rules were filed on the 28th day of November, 1967, in the Secretary of State's office.

1.4. Effective Date - These legislative rules became effective on the 29th day of December, 1967.

1.5. Refiling Date - These legislative rules were refiled pursuant to Chapter 29A, Article 2, Section 5 of the West Virginia Code of 1931, as amended on the 30th day of December, 1982, in the Secretary of State's office.

Section 2. Application and Enforcement

2.1. Application - These legislative rules apply to owners or operators of sewage treatment plants.

2.2. Enforcement - The enforcement of these legislative rules is vested with the director of the West Virginia department of health or his lawful designee.

Section 3. Control Tests and Operation Records

3.1. Every sewage treatment or disposal plant serving a public sewerage system shall be equipped with testing apparatus for making the physical, chemical, and bacteriological control tests which are considered necessary by the state department of health, upon written request, shall furnish a statement of the control tests necessary for a particular plant.

3.2. There shall be regularly made at each sewage treatment or disposal plant such physical, chemical, bacteriological control tests which are considered necessary by the state department of health for the proper and safe operation of the plant.

3.3. The frequency of making such physical, chemical, and bacteriological control tests shall be determined by the state department of health.

3.4. The results of the control tests together with the record of sewage treatment plant operation shall be entered upon a permanent record form or ledger and maintained at the plant.

3.5. Each month or as otherwise directed by the state department of health the operator of the sewage treatment or disposal plant shall furnish a summary of operation and control data to the state department of health. The data shall be submitted monthly on a standard form or another form acceptable to the state department of health.

3.6. The state department of health, by specific written direction, may waive the submission of operating reports from sewage treatment or disposal plants serving 500 or less persons.